

AFFIDAVIT OF MARK DRISCOLL

Mark Driscoll, being duly sworn, deposes and says:

- (1) I am the plant manager and duly authorized representative of Pinetree Power, Inc. ("PPI") (MS337) for the purpose of certifying Class III RPS certificates in New Hampshire.
- (2) Attached to this affidavit are accurate copies of emissions data for Pinetree Power, Inc. facility for the months of January, February & March 2014.
- (3) The attached emissions data demonstrate that Pinetree Power, Inc.'s. Average NOx emission rate during the first quarter of 2014 was equal to or less than the 0.075 lbs/MMbtu threshold level required for Class III certificates.
- (4) Further, the affiant sayeth naught.


Date:

5/7/14

Mark Driscoll

Mark Driscoll

STATE OF NEW HAMPSHIRE
COUNTY OF GRAFTON, SS.



Personally appeared the person signing the above affidavit, and swore that it is true to the best of his knowledge and belief.

Date:

5/7

, 2014

Notary Public

Pamela S. Landry

Pinetree Power - Monthly Data Summary - January2014

Averages: 397.40 119.42 0.40 45.170 22.41 0.069 157.238 68968 4.67 1.07 16.72 8.25 0.97 419.48
 Totals: 85971.47 16115.86

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/Nox	CATALYST BED TEMP
1/1/2014	397.47	119.90	0.37	46.331	23.07	0.071	159.674	69197	4.70	0.93	17.10	8.45	1.34	420.89
1/2/2014	468.59	136.52	1.30	47.313	22.93	0.095	141.778	67677	5.68	1.74	14.38	7.04	0.76	402.54
1/3/2014	409.09	121.87	0.40	46.130	22.84	0.073	151.689	68751	5.08	1.86	16.19	7.97	0.88	409.90
1/4/2014	395.74	121.04	0.38	44.190	22.25	0.069	154.460	70012	5.01	1.53	17.00	8.39	1.03	411.34
1/5/2014	381.95	115.90	0.35	44.476	22.12	0.067	158.334	69183	4.53	1.07	16.87	8.32	0.20	425.11
1/6/2014	430.74	128.27	0.40	43.605	21.53	0.066	155.594	68723	4.48	0.85	16.03	7.90	0.73	424.90
1/7/2014	391.42	117.58	0.36	47.318	23.41	0.072	157.465	68833	4.63	1.04	16.57	8.18	1.07	420.71
1/8/2014	389.51	120.72	0.36	40.281	20.45	0.061	158.710	70719	4.48	1.18	16.72	8.25	1.58	421.20
1/9/2014	404.51	124.33	0.38	41.105	20.84	0.063	155.096	70487	4.76	0.98	15.96	7.87	0.81	422.48
1/10/2014	408.43	125.63	0.38	41.853	21.18	0.064	156.042	70452	4.69	1.07	16.14	7.96	1.39	419.57
1/11/2014	452.01	132.15	0.41	39.971	19.37	0.060	151.854	67302	4.39	0.82	14.31	7.06	0.58	423.09
1/12/2014	479.58	134.34	0.42	42.960	20.12	0.068	135.062	64430	5.55	0.43	11.95	5.88	0.45	411.72
1/13/2014	403.45	122.43	0.37	45.927	22.94	0.069	156.171	69519	4.52	0.85	16.07	7.92	-0.25	427.75
1/14/2014	397.48	120.93	0.36	47.080	23.54	0.070	160.357	69608	4.52	0.71	17.44	8.61	0.81	426.57
1/15/2014	382.26	116.77	0.35	48.585	24.24	0.073	161.044	69487	4.52	0.86	17.54	8.67	-0.08	429.93
1/16/2014	360.92	110.33	0.33	47.470	23.93	0.072	161.254	70231	4.57	0.81	17.59	8.67	0.42	426.13
1/17/2014	371.58	112.66	0.34	47.044	23.42	0.071	161.758	69195	4.45	0.73	17.66	8.72	0.86	429.85
1/18/2014	367.39	111.29	0.34	45.660	22.86	0.069	161.564	69662	4.49	0.82	17.62	8.69	1.22	424.62
1/19/2014	367.56	108.75	0.33	46.666	22.85	0.070	161.143	68038	4.42	0.97	17.57	8.67	1.80	425.02
1/20/2014	363.92	108.84	0.33	43.207	21.53	0.064	161.333	69417	4.38	0.80	17.71	8.73	2.41	421.61
1/21/2014	388.81	117.00	0.36	46.530	23.22	0.070	161.571	69351	4.58	1.28	17.65	8.71	1.04	420.24
1/22/2014	443.08	137.41	0.48	43.224	21.88	0.068	157.426	70480	4.84	1.73	17.18	8.48	0.89	413.24
1/23/2014	381.83	113.79	0.35	44.621	22.06	0.068	158.945	68607	4.59	1.44	17.65	8.71	0.98	414.06
1/24/2014	395.16	121.28	0.37	45.074	22.69	0.069	159.595	70072	4.71	1.66	17.83	8.79	0.86	410.98
1/25/2014	375.98	110.27	0.35	42.936	20.78	0.065	157.369	67076	4.51	1.35	17.53	8.65	1.35	414.53
1/26/2014	370.73	110.91	0.35	46.253	22.88	0.071	157.545	68733	4.72	1.14	16.56	8.18	0.93	410.99
1/27/2014	363.35	105.60	0.33	48.223	23.22	0.072	159.514	66836	4.45	0.93	16.10	7.95	0.75	417.43
1/28/2014	389.25	118.24	0.36	47.915	23.90	0.073	160.438	69390	4.65	1.10	16.94	8.36	2.71	416.03
1/29/2014	399.96	120.16	0.37	45.282	22.36	0.069	160.695	68603	4.68	1.03	17.67	8.72	0.67	419.01
1/30/2014	385.23	115.99	0.36	44.732	22.28	0.068	160.835	69246	4.67	0.89	17.46	8.61	0.96	418.39
1/31/2014	402.34	121.15	0.37	48.297	23.89	0.073	160.071	68700	4.46	0.69	17.44	8.60	0.93	424.11

Pinetree Power - Monthly Data Summary - February2014

Averages: 376.50 112.37 0.35 47.709 23.51 0.073 160.571 68511 4.66 1.10 18.08 8.92 0.93 421.64
Totals: 72676.91 15210.89

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/Nox	CATALYST BED TEMP
2/1/2014	390.04	118.17	0.36	48.992	24.59	0.074	160.754	69804	4.62	1.30	17.67	8.72	0.21	421.65
2/2/2014	389.47	116.57	0.36	49.641	24.41	0.075	160.512	68334	4.50	0.74	18.17	8.97	1.09	423.80
2/3/2014	356.55	107.67	0.33	48.080	23.94	0.074	160.282	69223	4.76	1.08	17.91	8.84	1.43	420.66
2/4/2014	365.53	108.26	0.35	47.261	23.13	0.073	160.603	67990	4.85	1.06	18.15	8.95	1.33	420.64
2/5/2014	371.41	112.27	0.34	44.796	22.18	0.068	160.974	68923	4.56	1.23	17.71	8.74	1.11	421.46
2/6/2014	375.90	110.97	0.35	48.925	23.89	0.074	160.653	67810	4.65	1.27	18.01	8.89	0.95	421.34
2/7/2014	362.78	109.20	0.34	47.944	23.82	0.074	160.964	69083	4.73	1.40	17.94	8.85	0.87	418.57
2/8/2014	377.78	112.26	0.35	48.913	24.14	0.075	160.886	68570	4.75	1.13	17.99	8.87	1.19	420.74
2/9/2014	383.43	115.90	0.36	47.431	23.68	0.073	160.933	69474	4.81	1.13	18.31	9.01	0.76	419.51
2/10/2014	376.29	111.21	0.35	48.130	23.64	0.074	160.358	68189	4.79	1.09	18.26	9.00	1.02	420.23
2/11/2014	374.10	112.03	0.35	46.709	23.25	0.072	160.531	69152	4.76	1.52	18.33	9.05	0.90	416.16
2/12/2014	350.84	104.49	0.33	48.410	23.75	0.075	160.366	68064	4.85	1.41	18.14	8.97	0.96	416.66
2/13/2014	355.25	105.56	0.33	46.956	23.01	0.072	160.611	68064	4.64	1.24	18.07	8.90	0.60	417.54
2/14/2014	387.46	111.24	0.35	49.018	23.36	0.073	160.427	66132	4.38	0.95	18.04	8.90	1.79	423.23
2/15/2014	355.33	104.73	0.33	48.483	23.62	0.073	160.719	67666	4.55	1.12	18.25	9.01	1.16	421.92
2/16/2014	379.27	111.56	0.35	49.019	23.91	0.075	160.406	67717	4.67	0.85	18.43	9.09	0.79	419.45
2/17/2014	386.03	116.63	0.36	47.602	23.80	0.073	160.416	69544	4.76	1.37	18.55	9.13	0.41	419.60
2/18/2014	384.43	114.90	0.36	46.537	22.79	0.072	161.395	68132	4.77	1.24	18.49	9.12	0.44	422.61
2/19/2014	365.42	108.07	0.34	47.897	23.52	0.072	160.218	68269	4.51	1.10	17.81	8.79	1.09	423.22
2/20/2014	350.89	102.87	0.32	47.789	23.17	0.072	160.516	67282	4.51	0.90	17.80	8.78	0.88	427.27
2/21/2014	369.13	110.68	0.34	47.358	23.47	0.072	160.086	68920	4.56	0.77	17.98	8.88	-0.41	424.43
2/22/2014	402.96	120.37	0.37	48.473	23.72	0.073	159.999	67963	4.51	0.90	18.01	8.89	1.18	425.97
2/23/2014	390.07	117.36	0.36	48.260	23.96	0.073	160.274	69050	4.61	0.91	18.25	9.02	0.98	423.03
2/24/2014	369.97	110.10	0.34	47.912	23.53	0.073	160.344	68339	4.65	0.70	18.24	9.01	1.03	424.46
2/25/2014	390.52	118.83	0.36	45.821	22.92	0.069	160.206	69656	4.56	0.83	17.94	8.85	1.02	423.92
2/26/2014	397.49	119.04	0.37	46.667	23.17	0.071	160.941	69100	4.63	1.12	17.84	8.80	0.93	424.36
2/27/2014	395.47	119.58	0.37	45.409	22.60	0.069	160.758	69240	4.62	1.34	17.89	8.82	1.38	420.19
2/28/2014	388.25	115.84	0.37	47.428	23.42	0.073	160.861	68625	4.78	0.98	18.10	8.93	1.03	423.21

Pinetree Power - Monthly Data Summary - March2014

Averages: 382.62 114.06 0.36 47.944 23.56 0.074 159.740 68372 4.72 0.90 18.12 8.94 0.97 424.46
 Totals: 81985.75 16961.80

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/Nox	CATALYST BED TEMP
3/1/2014	394.19	119.65	0.37	47.436	23.75	0.073	160.692	69714	4.73	1.12	18.17	8.96	0.90	421.40
3/2/2014	385.70	115.05	0.36	47.945	23.64	0.073	160.586	68565	4.69	0.79	18.16	8.95	0.98	423.54
3/3/2014	373.47	112.73	0.35	47.795	23.78	0.074	160.443	69205	4.78	1.33	18.44	9.09	0.90	418.83
3/4/2014	379.12	113.28	0.36	47.618	23.43	0.074	160.465	68382	4.85	1.20	18.68	9.21	0.89	421.20
3/5/2014	352.26	104.66	0.33	46.706	22.99	0.072	160.071	68433	4.79	1.20	18.34	9.05	0.99	419.21
3/6/2014	368.28	109.71	0.35	47.426	23.29	0.073	160.583	68200	4.81	1.30	18.39	9.07	0.89	421.52
3/7/2014	372.56	113.11	0.36	62.637	31.68	0.101	160.858	69801	4.94	1.41	15.83	7.81	0.75	370.12
3/8/2014	351.87	103.70	0.33	48.655	23.69	0.075	160.155	67665	4.73	0.95	18.08	8.92	1.01	429.36
3/9/2014	385.83	115.98	0.36	47.637	23.66	0.073	160.040	69115	4.74	1.09	18.13	8.95	1.02	426.51
3/10/2014	361.50	106.39	0.34	50.171	24.39	0.077	160.329	67456	4.71	1.01	18.16	8.95	1.99	428.93
3/11/2014	378.07	112.18	0.36	48.091	23.49	0.073	159.653	67968	4.62	0.91	18.25	9.01	0.78	426.73
3/12/2014	388.70	114.63	0.36	47.035	22.91	0.071	160.184	67744	4.62	1.15	18.01	8.89	2.22	428.89
3/13/2014	410.62	123.50	0.38	47.149	23.37	0.072	159.952	68993	4.67	1.51	17.97	8.86	1.00	422.20
3/14/2014	388.63	116.68	0.36	47.990	23.76	0.073	160.537	68858	4.61	1.31	18.11	8.92	0.94	428.78
3/15/2014	373.84	111.74	0.34	47.747	23.45	0.072	160.182	68301	4.47	0.87	17.68	8.72	0.82	427.72
3/16/2014	385.18	115.58	0.36	47.513	23.45	0.073	160.394	68663	4.69	0.82	17.77	8.75	0.68	428.91
3/17/2014	388.20	118.85	0.36	46.560	23.41	0.071	160.451	70046	4.71	1.38	17.93	8.86	0.92	424.12
3/18/2014	378.27	113.36	0.35	47.089	23.13	0.072	159.900	68323	4.68	1.03	17.91	8.83	0.97	426.86
3/19/2014	363.70	98.97	0.34	47.421	20.82	0.072	160.673	62793	4.62	1.51	18.29	9.02	1.65	427.17
3/20/2014	385.13	113.69	0.35	49.203	23.98	0.074	160.479	67802	4.49	0.29	18.24	9.02	0.16	431.33
3/21/2014	371.77	111.60	0.35	48.788	24.09	0.075	160.148	68689	4.70	0.24	18.73	9.25	1.92	427.72
3/22/2014	391.53	116.42	0.36	48.625	23.79	0.074	160.104	68002	4.68	0.55	18.64	9.22	1.16	430.80
3/23/2014	392.75	117.88	0.37	48.040	23.89	0.074	159.433	69194	4.81	0.37	18.45	9.10	0.93	428.07
3/24/2014	380.90	113.87	0.36	47.391	23.29	0.072	159.046	68312	4.69	0.79	18.42	9.09	0.95	426.58
3/25/2014	385.61	114.49	0.35	48.112	23.68	0.072	160.430	68331	4.52	0.66	18.45	9.10	1.54	425.12
3/26/2014	441.62	129.69	0.41	45.819	22.07	0.070	159.120	66954	4.67	0.53	18.65	9.20	1.04	424.54
3/27/2014	384.97	116.72	0.37	47.653	23.86	0.074	159.616	69638	4.85	0.63	18.44	9.11	-0.63	425.26
3/28/2014	377.19	111.76	0.35	46.321	22.65	0.070	160.832	68020	4.49	0.43	18.18	8.98	1.23	433.10
3/29/2014	368.37	110.92	0.34	45.778	22.83	0.070	160.215	69406	4.60	0.14	17.81	8.80	-0.44	431.73
3/30/2014	413.30	122.65	0.40	45.475	22.38	0.072	154.913	68439	5.06	0.39	17.81	8.79	0.71	429.19
3/31/2014	387.99	116.30	0.38	44.430	21.89	0.071	151.462	68531	5.24	0.85	17.75	8.75	1.07	422.94

GSI Emission Chart 2014

BETHLEHEM

MSS 337

CT00218-07

2014	Operation Hours	Generation Gross MWh	Generation Net MWh	MMBTU	CO Tons	CO lbs.	CO lb/MWh	NOX Tons	NOX lbs.	NOX lb/MMbtu	NOX lbs/hr	Heat Input	SOX lb/MWh	SOX Tons	SOX lbs.	Particulate lb/MWh	Particulate Tons	Particulate lbs.
January	741.22	12360.96	11167	188498.6	42.99	85980	7.699	8.31	16620	0.069	22.41	324.783	0.0168	0.0637	207.54	0.0240	0.1482	296.49
February	672	11410.46	10335	188577.8	36.34	72680	7.032	7.6	15204.2	0.073	23.51	322.055	0.0165	0.0578	188.16	0.0236	0.1344	268.80
March	743	12,582.72	11356	213812.3	42.98	85960	7.570	8.05	16100	0.074	23.56	318.378	0.0165	0.0639	208.04	0.0236	0.1486	297.20
April	682	11467.00	10440	0.0	0	0.000	0	0	0	0	0	#DIV/0!	0.0167	0.0586	190.96	0.0238	0.1364	272.80
May					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
June					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
July					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
August					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
September					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
October					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
November					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
December					0	#DIV/0!	0	0	0	0	0	#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
Total	2838.22	47821.14	43298		122.31	244620	5.650	23.962	47924.2	0.072	23.16	#DIV/0!	#DIV/0!	0.2441	794.70	#DIV/0!	0.5676	1135.29