

AFFIDAVIT OF MARK DRISCOLL

Mark Driscoll, being duly sworn, deposes and says:

- (1) I am the plant manager and duly authorized representative of Pinetree Power, Inc. ("PPI") (MS337) for the purpose of certifying Class III RPS certificates in New Hampshire.
- (2) Attached to this affidavit are accurate copies of emissions data for Pinetree Power, Inc. facility for the months of July, August and September 2014.
- (3) The attached emissions data demonstrate that Pinetree Power, Inc.'s. Average NOx emission rate during the third quarter of 2014 was equal to or less than the 0.075 lbs/MMbtu threshold level required for Class III certificates.
- (4) Further, the affiant sayeth naught.


Date: 10/22/14



Mark Driscoll

STATE OF NEW HAMPSHIRE
COUNTY OF GRAFTON, SS.

Personally appeared the person signing the above affidavit, and swore that it is true to the best of his knowledge and belief.

Date: 10/22, 2014


Notary Public



Pinetree Power - Monthly Data Summary - July2014

Averages: 314.11 85.88 0.08 47.718 21.97 0.067 157.109 63095 4.70 -0.96 17.20 8.48 0.88 420.81
 Totals: 61602.23 15539.76

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/Nox	CATALYST BED TEMP
7/1/2014	342.73	95.50	0.32	71.667	33.48	0.111	160.947	63926	4.63	-0.68	14.97	7.38	0.65	366.43
7/2/2014	329.50	90.73	0.30	47.765	21.77	0.072	160.597	63262	4.43	-1.24	17.73	8.75	0.85	425.04
7/3/2014	327.65	90.65	0.30	46.425	21.21	0.070	160.904	63429	4.57	-1.18	17.64	8.70	0.84	428.67
7/4/2014	334.35	94.61	0.31	47.774	22.36	0.072	159.867	64874	4.49	-0.97	17.54	8.65	0.76	423.15
7/5/2014	304.09	84.10	0.28	48.456	22.11	0.073	158.825	63156	4.52	-1.13	17.56	8.66	0.92	423.50
7/6/2014	290.72	79.98	0.27	47.426	21.73	0.071	158.945	63481	4.47	-1.25	17.46	8.61	0.95	423.11
7/7/2014	305.20	83.67	0.28	47.229	21.35	0.071	159.386	62641	4.48	-0.98	17.62	8.69	0.76	424.76
7/8/2014	277.09	79.75	0.26	43.119	20.59	0.065	157.103	62699	4.15	-1.02	17.31	8.53	0.91	424.69
7/9/2014	433.45	68.40	-6.11	36.614	16.05	-0.092	93.205	43386	10.43	-0.56	9.99	4.93	0.40	359.86
7/10/2014	307.22	85.59	0.27	47.874	22.16	0.074	157.900	64240	4.74	-1.05	17.82	8.78	0.93	420.25
7/11/2014	284.98	79.18	0.26	47.298	21.56	0.072	158.094	63214	4.64	-0.97	17.70	8.73	0.62	423.97
7/12/2014	282.82	78.31	0.26	47.410	21.79	0.071	158.958	63783	4.44	-1.02	17.66	8.70	0.73	422.85
7/13/2014	280.65	76.98	0.26	48.984	22.16	0.073	159.798	62708	4.42	-1.01	17.97	8.86	0.75	425.26
7/14/2014	298.03	83.29	0.27	47.655	22.06	0.071	159.999	64210	4.37	-1.00	17.44	8.60	0.78	423.23
7/15/2014	295.49	81.81	0.27	47.300	21.70	0.070	160.041	63609	4.26	-1.03	17.45	8.58	0.71	428.46
7/16/2014	319.43	91.39	0.29	47.612	22.59	0.071	160.103	65858	4.35	-0.93	17.52	8.63	0.77	428.50
7/17/2014	307.21	86.33	0.28	48.446	22.51	0.073	159.099	64361	4.59	-1.00	18.32	9.04	0.73	428.59
7/18/2014	359.26	101.99	0.33	45.974	21.62	0.070	158.513	65232	4.67	-0.82	17.46	8.62	0.77	425.42
7/19/2014	375.63	104.28	0.35	46.220	21.27	0.070	158.602	63851	4.54	-0.99	16.92	8.35	1.15	426.38
7/20/2014	351.44	100.86	0.33	45.977	21.51	0.070	158.877	64934	4.63	-0.96	17.05	8.40	0.72	425.57
7/21/2014	410.98	113.21	0.38	46.330	21.20	0.071	159.004	63350	4.62	-1.05	16.78	8.27	0.75	426.62
7/22/2014	326.18	93.27	0.30	48.201	22.50	0.072	159.651	64791	4.50	-1.08	16.77	8.26	0.79	428.06
7/23/2014	310.61	85.54	0.28	48.552	22.19	0.073	160.178	63392	4.41	-1.08	17.30	8.54	0.77	427.58
7/24/2014	303.75	85.94	0.28	46.207	21.54	0.070	158.957	64729	4.63	-0.76	16.83	8.31	0.69	424.54
7/25/2014	283.32	77.83	0.26	48.126	21.85	0.073	158.862	62833	4.59	-0.93	17.53	8.63	0.63	424.77
7/26/2014	279.99	77.81	0.26	47.507	21.82	0.072	159.374	63653	4.51	-0.89	17.43	8.59	0.75	421.66
7/27/2014	279.60	75.43	0.26	46.843	20.84	0.070	159.380	61748	4.46	-0.85	17.74	8.75	2.48	421.97
7/28/2014	267.23	74.50	0.24	47.498	21.77	0.071	159.140	63476	4.32	-0.76	17.13	8.45	0.93	420.58
7/29/2014	283.50	78.39	0.26	48.140	22.10	0.073	158.247	63575	4.62	-0.94	18.11	8.93	2.41	422.99
7/30/2014	282.14	78.65	0.26	48.673	22.43	0.073	158.639	63890	4.52	-0.77	18.11	8.93	0.28	422.59
7/31/2014	303.06	84.31	0.28	45.955	21.13	0.069	159.192	63663	4.61	-0.86	18.38	9.05	1.07	426.13

Pinetree Power - Monthly Data Summary - August2014

Averages: 320.24 88.73 0.30 46.459 21.35 0.070 157.980 63025 4.51 -0.72 17.51 8.63 0.93 422.75
 Totals: 63992.29 15370.91

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/NOx	CATALYST BED TEMP
8/1/2014	298.91	84.44	0.28	46.296	21.42	0.070	158.949	64178	4.54	-0.87	17.60	8.68	0.46	423.95
8/2/2014	301.42	82.71	0.28	47.210	21.47	0.071	159.351	63002	4.54	-0.92	17.63	8.69	0.80	425.11
8/3/2014	303.75	84.68	0.28	47.652	22.00	0.072	159.511	63981	4.49	-0.89	17.65	8.70	2.18	422.92
8/4/2014	279.67	77.54	0.26	48.288	22.16	0.073	159.609	63529	4.47	-0.99	17.80	8.77	1.34	426.10
8/5/2014	334.19	90.85	0.30	47.644	21.68	0.072	159.482	63048	4.45	-0.94	16.96	8.37	0.42	421.97
8/6/2014	356.79	97.39	0.33	46.243	20.82	0.070	159.005	62366	4.48	-0.82	17.54	8.65	0.50	422.18
8/7/2014	351.47	97.21	0.32	46.007	21.06	0.069	158.439	63454	4.54	-0.59	17.24	8.51	0.85	419.30
8/8/2014	355.80	98.96	0.33	46.491	21.21	0.070	158.912	63202	4.46	-0.78	17.42	8.56	0.92	422.99
8/9/2014	353.62	100.32	0.33	45.973	21.49	0.070	159.009	64836	4.56	-0.74	17.37	8.57	0.97	423.12
8/10/2014	360.98	101.43	0.34	46.225	21.36	0.071	159.263	63930	4.72	-0.85	17.39	8.58	2.14	423.77
8/11/2014	358.76	99.60	0.33	44.268	20.34	0.067	159.472	63789	4.50	-0.88	17.03	8.40	0.85	423.82
8/12/2014	352.29	97.49	0.32	46.670	21.18	0.070	159.745	62880	4.48	-0.73	17.25	8.52	0.77	425.53
8/13/2014	318.12	88.49	0.29	45.848	21.18	0.069	159.663	64129	4.59	-0.57	17.70	8.69	1.30	421.64
8/14/2014	337.52	93.17	0.31	48.182	21.85	0.073	159.461	62846	4.52	-0.78	17.71	8.73	-0.48	423.41
8/15/2014	325.25	90.74	0.30	47.792	22.02	0.072	158.459	63830	4.53	-0.60	17.52	8.64	-1.21	421.41
8/16/2014	295.68	80.64	0.27	47.857	21.56	0.072	158.252	62512	4.45	-0.70	17.89	8.84	0.98	422.05
8/17/2014	300.83	82.68	0.28	47.225	21.51	0.071	158.248	63156	4.49	-0.76	17.70	8.71	0.69	418.71
8/18/2014	305.41	84.47	0.28	47.914	21.70	0.072	159.008	62730	4.58	-0.64	17.82	8.78	1.41	421.32
8/19/2014	305.32	85.27	0.28	47.699	21.97	0.071	158.561	63939	4.49	-0.65	17.82	8.77	0.62	422.97
8/20/2014	348.88	96.71	0.32	48.295	22.15	0.072	159.251	63595	4.34	-0.82	17.84	8.80	1.30	427.87
8/21/2014	330.27	92.37	0.30	47.998	22.30	0.072	158.839	64337	4.42	-0.68	17.65	8.71	1.10	424.17
8/22/2014	336.16	92.83	0.31	46.704	21.46	0.070	159.221	63686	4.45	-0.74	17.52	8.64	0.71	428.04
8/23/2014	340.52	96.79	0.31	46.734	21.84	0.070	159.044	64801	4.45	-0.68	17.67	8.69	0.75	424.68
8/24/2014	334.57	91.18	0.31	47.743	21.76	0.072	159.018	63056	4.46	-0.71	17.92	8.84	1.45	425.05
8/25/2014	293.74	87.96	0.46	29.228	17.38	0.054	126.031	54623	5.11	0.19	13.77	6.77	0.41	402.73
8/26/2014	286.56	77.07	0.26	46.109	20.57	0.069	159.153	61853	4.50	-0.78	17.74	8.74	1.01	425.37
8/27/2014	301.70	82.26	0.27	46.816	21.27	0.070	159.139	62996	4.39	-0.79	17.90	8.81	0.73	423.04
8/28/2014	294.80	79.57	0.27	47.799	21.20	0.072	158.746	61353	4.47	-0.68	17.98	8.87	2.99	422.17
8/29/2014	292.36	80.19	0.27	47.523	21.81	0.072	158.670	63594	4.54	-0.65	17.99	8.88	0.81	423.52
8/30/2014	287.48	78.49	0.26	46.561	20.80	0.070	158.546	61857	4.50	-0.61	18.00	8.88	1.14	424.38
8/31/2014	284.46	77.26	0.26	47.227	21.37	0.070	159.315	62700	4.32	-0.73	17.84	8.80	0.85	421.89

Pinetree Power - Monthly Data Summary - September2014

Averages: 342.88 91.05 0.31 47.354 20.95 0.073 153.542 60862 4.79 -0.54 17.00 8.38 0.89 412.52
Totals: 46197.97 10520.80

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/Nox	CATALYST BED TEMP
9/1/2014	293.25	78.15	0.27	50.844	22.44	0.075	159.697	61107	4.32	-0.87	18.30	9.03	0.87	426.41
9/2/2014	286.42	78.35	0.26	48.456	21.85	0.073	160.111	62546	4.46	-0.84	18.39	9.07	0.86	423.83
9/3/2014	319.77	86.39	0.29	51.457	23.10	0.078	158.741	62123	4.51	-0.87	18.07	8.90	0.65	423.81
9/4/2014	339.77	93.41	0.31	46.870	21.36	0.071	158.710	63197	4.49	-0.69	16.80	8.28	0.68	423.59
9/5/2014	359.24	96.23	0.32	54.238	24.10	0.080	160.127	61553	4.29	-0.72	17.45	8.62	0.68	426.72
9/6/2014	361.91	99.16	0.33	45.572	20.67	0.068	160.066	62910	4.30	-0.87	17.70	8.74	0.67	422.28
9/7/2014	331.74	89.59	0.31	48.427	21.58	0.074	158.301	61583	4.68	-0.82	18.04	8.92	1.29	421.40
9/8/2014	322.81	88.76	0.30	45.617	20.82	0.069	158.223	63327	4.62	-0.61	18.12	8.93	1.98	420.19
9/9/2014	313.89	85.42	0.29	46.319	20.72	0.070	157.730	61946	4.62	-0.57	18.27	8.98	1.02	422.82
9/10/2014	326.50	89.42	0.30	45.357	20.72	0.068	157.696	63287	4.47	-0.70	17.88	8.82	0.84	420.78
9/11/2014	350.46	93.43	0.32	48.009	21.43	0.072	158.785	61701	4.44	-0.61	18.28	9.01	0.83	423.79
9/12/2014	390.61	106.98	0.41	53.275	24.61	0.087	148.556	63808	5.53	-0.13	16.72	8.20	1.11	418.20
9/13/2014														
9/14/2014														
9/15/2014														
9/16/2014														
9/17/2014														
9/18/2014														
9/19/2014														
9/20/2014														
9/21/2014	454.58	106.91	0.35	42.570	16.22	0.102	80.571	45969	11.29	0.32	8.70	4.32	0.51	222.13
9/22/2014	279.67	71.87	0.25	50.693	21.56	0.076	156.262	59006	4.38	-0.60	18.51	9.14	1.13	415.85
9/23/2014	346.80	86.90	0.285	48.54	21.16	0.073	147.081	60261	5.00	-0.22	15.59	7.62	0.73	414.68
9/24/2014	348.47	92.74	0.32	47.262	20.70	0.071	156.839	60746	4.34	-0.32	17.46	8.61	0.88	428.53
9/25/2014	331.75	89.92	0.30	46.069	20.66	0.069	157.541	62211	4.31	-0.32	17.10	8.40	1.25	424.49
9/26/2014	347.85	91.28	0.31	43.042	18.77	0.064	156.687	60103	4.35	-0.36	16.76	8.25	0.60	424.48
9/27/2014	336.75	89.94	0.30	43.725	19.42	0.064	156.406	61443	4.23	-0.38	16.24	8.01	0.80	416.87
9/28/2014	346.28	89.32	0.31	44.036	18.92	0.065	156.338	59253	4.26	-0.57	16.47	8.14	0.81	418.35
9/29/2014	369.45	99.12	0.33	44.767	19.95	0.066	156.599	61596	4.28	-0.53	16.51	8.16	0.66	416.68
9/30/2014	385.46	99.77	0.35	46.642	20.05	0.069	156.856	59282	4.20	-0.52	16.73	8.25	0.79	419.58

GSI Emission Chart 2014

BETHLEHEM

MSS 337

CT00218-07

2014	Operation	Generation	Generation	MMBTU	CO	CO	CO	NOX	NOX	NOX	NOX	Heat Input	SOX	SOX	SOX	Particulate	Particulate	Particulate
	Hours	Gross MWh	Net MWh		Tons	lbs.	lb/MWh	Tons	lbs.	lb/MMbtu	lbs/hr		lb/MWh	Tons	lbs.	lb/MWh	Tons	lbs.
January	741.22	12360.96	11167	0.0	42.99	85980	7.699	8.31	16620	0.069	22.41	324.783	0.0168	0.0637	0.00	0.0240	0.0000	0.00
February	672	11410.46	10335	0.0	36.34	72680	7.032	7.6	15204.2	0.073	23.51	322.055	0.0165	0.0578	0.00	0.0236	0.0000	0.00
March	743	12,582.72	11356	0.0	42.98	85960	7.570	8.05	16100	0.074	23.56	318.378	0.0165	0.0639	0.00	0.0236	0.0000	0.00
April	682	11467.00	10440	0.0	32.81	65620	6.285	7.82	15640	0.073	22.04	301.918	0.0167	0.0586	0.00	0.0238	0.0000	0.00
May	730.56	12265.9	11205	0.0	33.7	67400	6.015	8.12	16240	0.071	22.25	313.380	0.0167	0.0628	0.00	0.0238	0.0000	0.00
June	720	12098	11004	0.0	30.32	60640	5.511	7.98	15960	0.072	22.17	307.917	0.0167	0.0619	0.00	0.0238	0.0000	0.00
July	733.75	12316	11217	0.0	31.51	63020	5.618	8.16	16320	0.073	22.25	304.795	0.0167	0.0631	0.00	0.0238	0.0000	0.00
August	739.75	12424.2	11325	0.0	32.81	65620	5.794	7.9	15800	0.070	21.35	305.000	0.0167	0.0636	0.00	0.0238	0.0000	0.00
September	514.99	8596.8	7864	0.0	23.45	46900	5.964	5.39	10780	0.073	20.95	286.986	0.0168	0.0443	0.00	0.0240	0.0000	0.00
October					0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
November					0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
December					0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
Total	6277.27	105522.04	95913	0.0	306.91	613820	6.400	69.332	138664.2	0.072	22.28	#DIV/0!	#DIV/0!	0.5398	0.00	#DIV/0!	0.0000	0.00