



The State of New Hampshire
Department of Environmental Services

Robert R. Scott, Commissioner



May 1, 2020

Debra A. Howland, Executive Director and Secretary
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

Re: 1st Quarter Emissions Verification Summary for Certified Renewable Energy Sources (DE 08-024, DE 08-044, DE 08-051, DE 09-104, DE 12-091, DE 13-265, DE 14-007, DE 14-182, DE 14-209, DE 14-296, REC 15-081, REC 16-546, RREC 16-1214, RREC 17-90015, RREC 17-90017, RREC 18-0351, RREC 18-0485, and RREC 19-0181)

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities meet average emission rates of 0.02 lb/MMBtu (or an alternative plan) and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Pinetree Power, Inc.

1241 Whitefield Rd
Bethlehem, NH 03574
GIS Unit ID #: MSS337

Pinetree Power-Tamworth, Inc.

469 Plains Rd
Tamworth, NH 03886
GIS Unit ID #: MSS592

Pinetree Power-Fitchburg, Inc.

2 Rowtier Drive
Westminster, MA 01473
GIS Unit ID #: MSS538

Granite Shore Power (GSP)

Schiller Station #5

400 Gosling Rd
Portsmouth, NH 03801
GIS Unit ID #: MSS557

Bridgewater Power Company

Route 3
Bridgewater, NH 03222
GIS Unit ID #: MSS357

Berlin Station, LLC

One Community Street
Berlin, NH 03570
GIS Unit ID #: MSS16653

Ryegate Power Station

247 Weesner Drive
East Ryegate, VT 05042
GIS Unit ID #: MSS2433

DG Whitefield LLC not operating

260 Airport Rd.
Whitefield, NH 03598
GIS Unit ID #: MSS618

Springfield Power LLC not operating

54 Fisher Corner Rd.
Springfield, NH 03284
GIS Unit ID #: MSS436

www.des.nh.gov

29 Hazen Drive • PO Box 95 • Concord, NH 03302-0095
(603) 271-3503 • Fax: 271-2867 TDD Access: Relay NH 1-800-735-2964

Based on the attached summary, DES recommends certification of the following wood-fired boilers as thermal renewable energy sources, because the facilities meet average emission rates of 0.10 lb/MMBtu for TSP and best management practices (BMP) for NOx, respectively:

Littleton Regional Healthcare (LRH)
600 Saint Johnsbury Road
Littleton, NH 03561

Androscoggin Valley Hospital (AVH)
59 Page Hill Road
Berlin, NH 03570

Warwick Mills
301 Turnpike Rd.
New Ipswich, NH

EMD Millipore
11 PRESCOTT RD
Jaffrey, NH

Memorial Hospital
3073 White Mountain Highway
North Conway, NH 03860

Holderness School
21 Mt. Prospect Road
Holderness, NH 03245

Froling Energy
590 Hancock Road
Peterborough, NH

Keene State College (three boilers)
229 Main St.
Keene, NH 03435

Merrimack County DoC
Boscawen, NH

Rockingham County Complex
Brentwood, NH


Sullivan County Complex
Unity, NH

Maplewood
Westmoreland, NH

DES communicated directly with PUC staff regarding eligibility for newly eligible small (<3 mmBtu/hr) thermal renewable energy sources.

If you have any questions regarding DES's recommendations, please contact me at joseph.fontaine@des.nh.gov or (603) 271-6794.

Sincerely,



Joseph T. Fontaine
Trading Programs Manager
Air Resources Division

cc: Jason Morse, NH PUC

1st Quarter 2020		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth 300019	0.070	14-Jun-19	0.002	
PT Bethlehem 900026	0.070	17-May-18 3-year test frequency approved by DES	0.004	
PT Fitchburg	0.062	May-19	0.006	
GSP SR5 1500012	0.066	May-17 3-year test frequency approved by DES	0.002	
Whitefield 700010	not operating	May-18	0.010	
Springfield Power 1900031	not operating	Jun-18	0.006	
Berlin 790137	0.060	16-Oct-19 3-year test frequency approved by DES	0.003	
Bridgewater Power 900021	0.070		n/a under Alternative Plan	
Ryegate	0.073	Jun-19	0.0014	
Thermal Sources		99% CE	maximum allowed	0.1 lb/mmbtu
Sullivan County Complex 1900026	99.97% annual tune-up & CE test	5-Dec-18 1-time test	0.049	
Conway Memorial 300006	99.999% 99.993% annual tune-up & CE test	9-Sep-15 10-Sep-15 1-time test	boiler #1 boiler #2 quarterly reporting of <90% capacity required	0.081 0.095
Grafton County Complex	annual tune-up & CE test	1-time test	pending	
Frothing Energy 500069	99.99% CE annual tune-up & CE test	1-time test 18-Apr-17	0.089	
Keene State College 500003	99.999% CE annual tune-up & CE test	1-time test 13-Dec-17 1-time test 13-Dec-17 1-time test 26-Apr-17	boiler #2 boiler #3 boiler #4	0.007 0.024 0.009
Maplewood 500010	99.99% CE annual tune-up & CE test	1-time test 11-Dec-19	0.038 eligible for Q1 2020	
Merrimack County 1300164	99.95% CE annual tune-up & CE test	1-time test 6-Dec-17	0.022	
Rockingham County 3301500014	99.99% annual tune-up & CE test	1-time test 11-Apr-18	0.0187	
Weeks Medical Center	annual tune-up & CE test	1-time test	pending	
Holderness School 900137	99.998% annual tune-up & CE test	1-time test 15-Dec-15	0.0075 quarterly reporting of <90% capacity required	
EMD Millipore 500056	99.95% CE annual tune-up & CE test	1-time test 13-Mar-15 8/21/2018	0.009 0.004	
Littleton Regional Healthcare 990284	99.99% CE annual tune-up & CE test	1-time test 17-Mar-14 18-Mar-14	boiler #1 boiler #2	0.056 0.032
Warwick Mills 110129	99.89% CE annual tune-up & CE test	1-time test 30-Sep-14 1-Oct-14	0.018	
AVH 7007	99.99% CE annual tune-up & CE test	4-Jun-14 1-time test	0.067	