


THE STATE OF NEW HAMPSHIRE



TDD Access: Relay NH  
1-800-735-2964

Tel. (603) 271-2431

FAX (603) 271-3878

Website:  
www.puc.nh.gov

CHAIRMAN  
Amy L. Ignatius

COMMISSIONERS  
Michael D. Harrington  
Robert R. Scott

EXECUTIVE DIRECTOR  
Debra A. Howland

**PUBLIC UTILITIES COMMISSION**  
21 S. Fruit Street, Suite 10  
Concord, N.H. 03301-2429

May 9, 2013

James Webb  
Registry Administrator  
APX Environmental Markets  
224 Airport Parkway, Suite 600  
San Jose, CA 95110

**Re: Quarterly Emissions Verification Summary for Certified Renewable Energy Sources**

DE 08-024	Pinetree - Bethlehem	DE 08-044	Shiller Station #5
DE 08-051	Pinetree Power - Tamworth	DE 09-008	Indeck
DE 09-104	Springfield Power (suspended)	DE 12-091	Berlin Station (under construction)

Dear Mr. Webb:

Pursuant to RSA 362-F:11, III, Renewable Portfolio Standard eligibility determinations of generation facilities that use biomass fuels are conditional. Within ten days of receiving the quarterly notice from the New Hampshire Department of Environmental Services (DES) that a facility has met DES emissions standards, the Commission must designate the facility as eligible to produce Renewable Energy Certificates.

Based on the DES recommendation, received May 02, 2013, the Commission hereby certifies the following wood-fired power plants as renewable energy sources for the fourth quarter of 2012, as the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Facility Name	Class	Address	GIS Unit ID #
Pinetree Power, Inc.	III	1241 Whitefield Rd Bethlehem, NH 03574	MSS337
Pinetree Power-Tamworth, Inc.	III	469 Plains Rd Tamworth, NH 03886	MSS592
Public Service Company of New Hampshire (PSNH) Schiller Station # 5	I	400 Gosling Rd Portsmouth, NH 03801	MSS557
Indeck	I	151 Smith River Road Alexandria, NH 03222	MSS14211

The following plant did not meet the test requirements for TSP as required by statute (RSA 362-F) and continues to be ineligible beginning with the fourth quarter of 2010:

Facility Name	Class	Address	GIS Unit ID #
Springfield Power, LLC	I/III	54 Fisher Corner Road Springfield, NH 03284	MSS436

The following plant applied for conditional approval to generate RECs, but has not yet begun operation:

Facility Name	Class	Address	GIS Unit ID #
Berlin Station, LLC	I	One Community Street Berlin, NH 03570	(not yet issued)

If you have any questions regarding DES's recommendations, please contact Joe Fontaine at [joseph.fontaine@des.nh.gov](mailto:joseph.fontaine@des.nh.gov) or 603-271-6794. Other questions should be directed to Barbara Bernstein at [barbara.bernstein@puc.nh.gov](mailto:barbara.bernstein@puc.nh.gov) or 603-271-6011.

Sincerely,



Debra A. Howland  
Executive Director

cc: Joe Fontaine, NHDES