

Public Service Company of New
Hampshire
Docket No. DE 11-215

Data Request STAFF-01

Dated: 10/28/2011

Q-STAFF-007

Page 1 of 2

ORIGINAL	
N.H.P.U.C. Case No.	DE 11-215
Exhibit No.	#4
Witness	
DO NOT REMOVE FROM FILE	

Witness: Frederick White
Request from: New Hampshire Public Utilities Commission Staff

Question:

Regarding September 23, 2011 Filing. Reference Attachment RAB-2, page 3. Please provide the annual and monthly capacity factors used for each of PSNH's owned fossil and hydro generating stations in the calculation of the preliminary ES rate.

Response:

Please see the attached file.

Unit Capacity Factors in the Preliminary 2012 ES Rate Calculation

<u>2012</u>	<u>Merrimack 1</u>	<u>Merrimack 2</u>	<u>Schiller 4</u>	<u>Schiller 5</u>	<u>Schiller 6</u>	<u>Newington</u>	<u>Hydros</u>	<u>ICUs</u>
Jan	90%	86%	77%	82%	79%	8%	72%	0%
Feb	90%	86%	77%	82%	79%	5%	65%	0%
Mar	82%	77%	66%	82%	67%	0%	81%	0%
Apr	0%	77%	0%	18%	0%	0%	95%	0%
May	0%	0%	0%	82%	0%	0%	85%	0%
Jun	0%	77%	0%	82%	0%	3%	67%	0%
Jul	83%	77%	58%	82%	60%	12%	51%	0%
Aug	83%	77%	43%	82%	44%	10%	45%	0%
Sep	0%	0%	0%	82%	0%	0%	38%	0%
Oct	0%	77%	0%	82%	0%	0%	54%	0%
Nov	82%	77%	46%	82%	20%	0%	78%	0%
Dec	90%	86%	66%	82%	75%	5%	73%	0%
Total	50%	66%	36%	77%	35%	4%	67%	0%