





Spanmaster ® Release 3.1 Sag / Tension Computations 09/01/11 Waveguide


Waveguide River and Rail Crossings


						E*A LOAD	MAX.
	X-SECT	EFF	NOMINAL	EFF.EXP.	CABLE	BEARING	RATED
	AREA	MODULUS	DIAM	COEFF.	WEIGHT	CAPACITY	LOAD
Selected Cables	(sq.in)	(psi)	(in)	(1/F)	(lb/ft)	(lbs)	(lbs)
1/4"6.6mEHS	0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	6650
ORF-O-288-LN	0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	651
Bundle			1.108		0.3170		

### **NESC RESULTS**

					Horz	Result			% Len	Sag @	Horz	Vert	
Loading		Ice	Ice	Wind	Wind	Load	Sag	Tension	Chg From	Point	Sag	Sag	Vector
Condition	Temp.	Load	Thick	Constant	Load	+ Const			Input	158	Comp	Comp	Angle
	(F)	lb/ft	in	lb/ft	lb/sq ft	lb/ft	ft	lb	Conditions	ft	ft .	ft	Deg
Rule 251 - Heavy	0.0	1.000	.50	.3	4.0	1.793	7.82	2854	0.14	7.84	3.68	6.90	28.1
232A1	120.0	0.000	00	0	0.0	0.317	3 66	1078	0.01	3 67	0.00	3 66	0.0

Span Length = 316.00 ft Span Sag = 3.16 ft (37.9 in)	Temp (F)	Midspan Sag (ft)	Tension (lb)	% Length Change	Clearance
Span Tension = 1,252 lb	-40.0	2.32	1,698	-0.01	N/A
Max Load = 6,650 lb	-30.0	2.38	1,655	-0.01	N/A
Usable load (60%) = 3,990 lb	-20.0	2.45	1,611	-0.01	N/A
Catenary Length = 316.084 ft	-10.0	2.52	1,568	-0.01	N/A
Stress Free Length @	.0	2.59	1,526	-0.01	N/A
Installed Temperature = 315.652 ft	10.0	2.66	1,484	-0.01	N/A
	20.0	2.73	1,443	-0.01	N/A
Unloaded Strand	30.0	2.81	1,403	-0.01	N/A
Sag = 1.43 ft (17.1 in) 0.45 %	40.0	2.89	1,363	0.00	N/A
Tension = 1,058 lb	50.0	2.98	1,324	0.00	N/A
	60.0	3.07	1,287	0.00	N/A
	70.0	3.16	1,249	0.00	N/A
	80.0	3.25	1,213	0.00	N/A
	90.0	3.35	1,178	0.00	N/A
	100.0	3.45	1,144	0.01	N/A
	110.0	3.56	1,110	0.01	N/A
	120.0	3.66	1,078	0.01	N/A
	130.0	3.77	1,047	0.01	N/A
	140.0	3.89	1,017	0.01	N/A






pole (PSNH/Fairpoint) in

existing Right-of-Way)

E - 30/48 - T - 17/48

NHOS proposes to install a ¼ inch metal supporting strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each note using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole



pole (PSNH/Fairpoint) in

existing Right-of-Way)

White Mtn Rd., Gorham NH Nearest cross street- White Birch Ln.

Project # TID-157 - Primary 10

New Hampshire Optical Systems, Inc.

Proposed **River Crossing** Gorham, NH

The heights of structures shown hereon are

based on field measurements taken with a Nikon 362 total station during a site survey on

The horizontal distance between the nearest bridge edge and the existing overhead wires ranges from 24' to 25'.

The smallest vertical distance from the top of

sail boating and per NESC Table 232-1 a vertical clearance of 14' must be maintained

between the lowest conductor and 10 year

difference between the river bed and the 10%

Vertical distances are representative of attachment heights after utility make ready

existing bridge deck to the lowest existing

4. The vertical distance between the top of water and bridge deck is approximately 23'. The waterway is classified as not suitable for

6. Based on the FEMA Flood Profile for the Peabody River (Page 122P) and the Flood Insurance Rate Map for the Town of Gorham, Coos County, (Community Panel Number 330032 0015 C) dated May 2, 1994 the

Chance Flood Event is 8'.

moves are completed.

overhead wires is 12'.


99 Pine Hill Rd. Nashua, NH 03063 (603-821-6467)


Notes:

Date: 11/28/11

Proposed River Crossing Gorham, NH

Sheet 2 of 2







Spanmaster ® Release 3.1 Sag / Tension Computations

Salastad Cables		EFF MODULUS	NOMINAL DIAM	EFF.EXP. COEFF.	CABLE WEIGHT	E*A LOAD BEARING CAPACITY	MAX. RATED LOAD
Selected Cables	(sq.in)	(psi)	(in)	(1/F)	(lb/ft)	(lbs)	(lbs)
1/4"6.6mEHS	0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	6650
ORF-O-288-LN	0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	651
Bundle			1.108		0.3170		


Waveguide

River and Rail Crossings

# **NESC RESULTS**

Loading Condition	Temp.	Ice Load lb/ft	Ice Thick	Wind Constant lb/ft	Wind Load lb/sq ft	Load + Const	Sag	Tension	76 Len Chg From Input Conditions	Point 150	Sag Comp	Sag	Vector Angle Deg
	(F)	ID/IL	***	ID/IL	ib/sq it	ID/IL	11.	10	Conditions	10	11	11.	Deg
Rule 251 - Heavy	0.0	1.000	.50	.3	4.0	1.793	7.32	2749	0.13	7.34	3.44	6.45	28.1
232A1	120.0	0.000	.00	.0	0.0	0.317	3.50	1018	0.01	3.50	0.00	3.50	0.0

	_				01
	Temp	Midspan	Tension		Clearance
Span Length = 300.00 ft	(F)	Sag (ft)	(lb)	Change	
Span Sag = 3.00 ft (36.0 in)					
Span Tension = 1,189 lb	-40.0	2.18	1,632	-0.01	N/A
Max Load = 6,650 lb	-30.0	2.24	1,589	-0.01	N/A
Usable load (60%) = 3,990 lb	-20.0	2.30	1,545	-0.01	N/A
Catenary Length = 300.080 ft	-10.0	2.37	1,503	-0.01	N/A
Stress Free Length @	.0	2.43	1,461	-0.01	N/A
Installed Temperature = 299.691 ft	10.0	2.51	1,419	-0.01	N/A
	20.0	2.58	1.378	-0.01	N/A
Unloaded Strand	30.0	2.66	1,338	-0.01	N/A
Sag = 1.37 ft (16.4 in) 0.46 %	40.0	2.74	1,299	0.00	N/A
Tension = 995 lb	50.0	2.82	1,261	0.00	N/A
	60.0	2.91	1,223	0.00	N/A
	70.0	3.00	1,186	0.00	N/A
	80.0	3.09	1,151	0.00	N/A
	90.0	3.19	1,116	0.00	N/A
	100.0	3.29	1,082	0.01	N/A
	110.0	3.39	1,050	0.01	N/A
	120.0	3.50	1,018	0.01	N/A
	130.0	3.60	988	0.01	N/A
	140.0	3.71	959	0.01	N/A



**Construction Notes:** 

(Existing joint owned utility

pole (NHEC/Fairpoint) in

existing Right-of-Way)

E-8/466 - T-3/41

NHOS proposes to install a ¼ inch metal supporting strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole



New Hampshire Optical Systems, Inc. 99 Pine Hill Rd. Nashua, NH 03063 (603-821-6467)

# Proposed **River Crossing** Bartlett, NH

## Notes:

- The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on
- The horizontal distance between the nearest bridge edge and the existing overhead wires ranges from 41' to 77'.
- The smallest vertical distance from the top of existing bridge deck to the lowest existing overhead wires is 12'.
- The vertical distance between the top of water and bridge deck is approximately 28'.
- The waterway is classified as not suitable for sail boating and per NESC Table 232-1 a vertical clearance of 14' must be maintained between the lowest conductor and 10 year
- 6. Based on the FEMA Flood Insurance Rate Map for the Town of Bartlett, Carroll County, (Community Panel Number 330010 0010 C) dated March 1, 1984 there is no 10% chance
- Assuming the exising bridge deck was built above the 10% flood event we can safely wire is at least 12' above the 10 year flood
- Vertical distances are representative of attachment heights after utility make ready moves are completed.

Project # TID-162 - Primary 10

Proposed **River Crossing** Bartlett, NH

<u>Location:</u> Pinkham Notch Rd., Bartlett NH Nearest cross street- Goodrich Falls Rd.


Sheet 2 of 2



(Existing joint owned utility

pole (NHEC/Fairpoint) in

existing Right-of-Way)







Spanmaster ® Release 3.1 Sag / Tension Computations

Selected Cables	X-SECT AREA (sq.in)	EFF MODULUS (psi)	NOMINAL DIAM (in)	EFF.EXP. COEFF. (1/F)	CABLE WEIGHT (lb/ft)	E*A LOAD BEARING CAPACITY (lbs)	MAX. RATED LOAD (lbs)
	,	(I)	. ,	( )	(y	Ç/	. ,
1/4"6.6mEHS	0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	665
ORF-O-288-LN	0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	65
Bundle			1.108		0.3170		


Waveguide

River and Rail Crossings

NESC I	RESII	LTS

Loading Condition	Temp.	Ice Load	Ice Thick	Wind Constant	Horz Wind Load	Result Load + Const	Sag	Tension	% Len Chg From Input	Sag @ Point 91	Horz Sag Comp	Vert Sag Comp	Vector Angle
Containon	(F)	lb/ft	in	lb/ft	lb/sq ft	lb/ft	ft	lb	Conditions	ft	ft	ft	Deg
Rule 251 - Heavy	0.0	1.000	.50	.3	4.0	1.793	3.85	1925	0.09	3.86	1.81	3.40	28.1
232A1	120.0	0.000	.00	.0	0.0	0.317	2.23	588	0.01	2.23	0.00	2.23	0.0

	Temp	Midspan	Tension	% Length	Clearand
Span Length = 182.00 ft	(F)	Sag (ft)	(lb)	Change	
Span Sag = 1.82 ft (21.8 in)	. ,	• . ,	. ,		
Span Tension = 721 lb	-40.0	1.15	1,137	-0.02	N/A
Max Load = 6.650 lb	-30.0	1.20	1.093	-0.02	N/A
Usable load (60%) = 3,990 lb	-20.0	1.25	1,051	-0.01	N/A
Catenary Length = 182.049 ft	-10.0	1.30	1,010	-0.01	N/A
Stress Free Length @	.0	1.35	969	-0.01	N/A
Installed Temperature = 181.905 ft	10.0	1.41	930	-0.01	N/A
motalica fomporatare fortione it					
Unloaded Strand	20.0	1.47	891	-0.01	N/A
Sag = .93 ft (11.1 in) 0.51 %	30.0	1.53	854	-0.01	N/A
Tension = 540 lb	40.0	1.60	819	-0.01	N/A
Tension – 540 lb	50.0	1.67	784	0.00	N/A
	60.0	1.74	752	0.00	N/A
	70.0	1.82	720	0.00	N/A
	80.0	1.90	691	0.00	N/A
	90.0	1.98	663	0.00	N/A
	100.0	2.06	636	0.01	N/A
	110.0	2.15	611	0.01	N/A
	120.0	2.23	588	0.01	N/A
	130.0	2.32	566	0.01	N/A
			545		
	140.0	2.41	040	0.02	N/A



strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above).
The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole owners.



pole (NHEC/Fairpoint) in

existing Right-of-Way)

E-520/156 - T-2/135

New Hampshire Optical Systems, Inc. 99 Pine Hill Rd. Nashua, NH 03063 (603-821-6467)

> Proposed **River Crossing** Bartlett, NH

# Notes:


- The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on
- The horizontal distance between the nearest bridge edge and the existing overhead wires ranges from 14' to 17'.
- The smallest vertical distance from the top of existing bridge deck to the lowest existing overhead wires is 14'.
- The vertical distance between the top of water and bridge deck is approximately 17'.
- The waterway is classified as not suitable for sail boating and per NESC Table 232-1 a vertical clearance of 14' must be maintained between the lowest conductor and 10 year
- Based on the FEMA\_Flood Insurance Rate Map for Carroll County (Community Panel Number 330010 0010 C) dated March 1, 1984 there is no 10% chance flood event information available for this area.
- Assuming the exising bridge deck was built above the 10% flood event we can safely assume that the lowest existing overhead wire is 14' above the 10 year flood plain.
- Vertical distances are representative of attachment heights after utility make ready moves are completed.

Project # TID-163 - Primary 10

Proposed **River Crossing** Bartlett, NH

<u>Location:</u> White Mtn. Rd., Bartlett NH Nearest cross street- Town Hall Rd.


Sheet 2 of 2




pole (NHEC/Fairpoint) in

existing Right-of-Way)

E-520/157 - T-2/136








Spanmaster ® Release 3.1 Sag / Tension Computations
09/01/11 Wavequide

Waveguide River and Rail Crossings

### **NESC RESULTS**

Loading Condition	Temp.	Ice Load	Ice Thick	Wind Constant	Horz Wind Load	Result Load + Const	Sag	Tension	% Len Chg From Input	Sag @ Point 164.5	Horz Sag Comp	Vert Sag Comp	Vector Angle
Oditation	(F)	lb/ft	in	lb/ft	lb/sq ft	lb/ft	ft	lb	Conditions	ft	ft	ft	Deg
Rule 251 - Heavy	0.0	0.927	.50	.3	4.0	1.671	8.20	2749	0.14	8.23	3.97	7.18	28.9
232A1	120.0	0.000	.00	.0	0.0	0.273	3.86	956	0.01	3.86	0.00	3.86	0.0

Span Length = 329.00 ft Span Sag = 3.29 ft (39.5 in)	Temp (F)	Midspan Sag (ft)	Tension (lb)	% Length Change	Clearance
Span Tension = 1,123 lb	-40.0	2.36	1,563	-0.01	N/A
Max Load = 6,650 lb	-30.0	2.42	1,520	-0.01	N/A
Usable load (60%) = 3,990 lb	-20.0	2.49	1,476	-0.01	N/A
Catenary Length = 329.088 ft	-10.0	2.57	1,434	-0.01	N/A
Stress Free Length @	.0	2.65	1,392	-0.01	N/A
Installed Temperature = 328.684 ft	10.0	2.73	1,351	-0.01	N/A
Halandad Olmad	20.0	2.81	1,310	-0.01	N/A
Unloaded Strand	30.0	2.90	1,271	-0.01	N/A
Sag = 1.73 ft (20.8 in) 0.53 % Tension = 946 lb	40.0	2.99	1,232	0.00	N/A
161151011 - 940 ID	50.0	3.09	1,194	0.00	N/A
	60.0	3.19	1,157	0.00	N/A
	70.0	3.29	1,121	0.00	N/A
	80.0	3.40	1,086	0.00	N/A
	90.0	3.51	1,052	0.00	N/A
	100.0	3.62	1,019	0.01	N/A
	110.0	3.74	987	0.01	N/A
	120.0	3.86	956	0.01	N/A
	130.0	3.98	927	0.01	N/A
	140.0	4.11	899	0.01	N/A





E-333/486 - T-NT/NT

# Construction Notes:

NHOS proposes to install a ¼ inch metal supporting strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole



New Hampshire Optical Systems

New Hampshire Optical Systems, Inc. 99 Pine Hill Rd. Nashua, NH 03063 (603-821-6467)

# Proposed Crossing Saco River Conway, NH

## Notes:

- The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on 11/9/11.
- The waterway is classified as not suitable for sail boating and per NESC Table 232-1 a vertical clearance of 14' must be maintained between the lowest conductor and 10 year floodplain.
- 3. Based on the FEMA Flood Profile for the Saco River (Page 59P) and the Flood Insurance Rate Map for Carroll County (County Map Number 3300110040C) dated 6/3/02 a conservative 10 year flood elevation was calculated by adding the delta between the river bed and the 10 year flood elevation to the surveyed water level and then the 14' buffer (for non-navigable streams) was added to that.
- Vertical distances are representative of attachment heights after utility make ready moves are completed.


Project # TID-166-PRI-10 Drawing # AC-CONW-RIV-


Date: 11/30/2011

Proposed Crossing Saco River Conway, NH

<u>Location:</u> Heath Rd, Conway, NH Nearest cross street: Main St

Sheet 2 of 2







Spanmaster ® Release 3.1 Sag / Tension Computations 09/01/11 Waveguide

						E*A LOAD	MAX.
	X-SECT	EFF	NOMINAL	EFF.EXP.	CABLE	<b>BEARING</b>	RATED
	AREA	MODULUS	DIAM	COEFF.	WEIGHT	CAPACITY	LOAD
Selected Cables	(sq.in)	(psi)	(in)	(1/F)	(lb/ft)	(lbs)	(lbs)
1/4"6.6mEHS	0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	6650
ORF-O-288-LN	0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	651
Dundlo			1 100		0.2170		


Waveguide

River and Rail Crossings

# **NESC RESULTS**

Loading Condition	Temp.	Ice Load	Ice Thick	Wind Constant	Horz Wind Load	Result Load + Const	Sag	Tension	% Len Chg From	Sag @ Point 136	Horz Sag	Vert Sag	Vector Angle
Condition	(F)	lb/ft	in	lb/ft	lb/sq ft	+ Const lb/ft	ft	lb	Input Conditions	ft	Comp ft	Comp ft	Deg
Rule 251 - Heavy 232A1		1.000 0.000	.50 .00	.3 .0	4.0 0.0	1.793 0.317	6.45 3.20	2562 914	0.12 0.01	6.47 3.21		5.69 3.20	

232A I	120.0 0.000	.00	.0	0.0	0.317 3.20	914	0.01	5.21 0.0	3.20 0.0
	th = 272.00 ft = 2.72 ft (32.6 ir				Temp (F)	Midspan Sag (ft)	Tension (lb)	% Length Change	Clearance
Span Tensi Max I Us Catenary L	on = 1,078 lb Load = 6,650 lb able load (60%) ength = 272.073	= 3,990	lb		-40.0 -30.0 -20.0 -10.0 .0	1.93 1.99 2.05 2.11 2.17	1,516 1,473 1,429 1,387 1,345	-0.01 -0.01 -0.01 -0.01 -0.01	N/A N/A N/A N/A N/A
Unloaded S Sag = 1	Installed Temperature coaded Strand Sag = 1.26 ft (15.2 in) Tension = 886 lb			10.0 20.0 30.0 40.0 50.0	2.24 2.31 2.39 2.47 2.55	1,304 1,264 1,224 1,186 1,148	-0.01 -0.01 -0.01 0.00 0.00	N/A N/A N/A N/A	
					60.0 70.0 80.0 90.0 100.0	2.63 2.72 2.81 2.90 3.00	1,112 1,076 1,041 1,008 975	0.00 0.00 0.00 0.00 0.01	N/A N/A N/A N/A N/A
					110.0 120.0 130.0 140.0	3.10 3.20 3.31 3.41	944 914 886 858	0.01 0.01 0.01 0.02	N/A N/A N/A N/A



pole (Fairpoint/PSNH) in existing Right-of-Way)

pole (Fairpoint/PSNH) in existing Right-of-Way)



New Hampshire Optical Systems, Inc. 99 Pine Hill Rd. Nashua, NH 03063 (603-821-6467)

# Proposed **River Crossing** Conway, NH

## Notes:

- 1. The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on
- The horizontal distance between the nearest bridge edge and the existing overhead wires ranges from 12' to 13'.
- The smallest vertical distance from the top of existing bridge deck to the lowest existing
- The vertical distance between the top of water and bridge deck is approximately 24'.
- The waterway is classified as not suitable for sail boating and per NESC Table 232-1 a vertical clearance of 14' must be maintained between the lowest conductor and 10 year
- Based on the FEMA Flood Profile for the Saco River (Page 60P) the difference between the stream bottom and the 10% flood elevation is 15'. This 15' was added to the existing stream bed and then the 14' buffer (for non-navigable streams) was added to that.
- Vertical distances are representative of attachment heights after utility make ready moves are completed.

Project # TID-168 - Lateral 6

Date: 12/06/11

Proposed River Crossing Conway, NH

<u>Location:</u> East Side Rd., Conway, NH Nearest cross street- West Side St.

Sheet 2 of 2

# Construction Notes:

NHOS proposes to install a ¼ inch metal supporting strand between the existing utility poles shown above that will traverse the stream. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each note using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole



E -31/2 - T- 6/2

K:  $\Projects\USNH\dwgs\Conway\river\_xing\TID-168\TID-168.dwg$