

NHPUC 17OCT'13PM12:10

October 11, 2013

Ms. Debra Howland
Executive Director and Secretary
State of New Hampshire Public Utilities Commission
21 S. Fruit Street Suite 10
Concord, NH 03301-2429

Ms. Howland,

Solar Farm Bank LLC (SFB) New Hampshire Certification Code NH-II-13-O10 requests the New Hampshire Public Utilities Commission (Commission) grant its approval and certification of our account for Class II REC for the photovoltaic array of:

Bennett Way Limited Partnership
C/O Harvey Gertel / Scott Foster
600 Bennett Way Building 7
Newmarket, NH 03857
Telephone # 603-659-5665
Email: hgertel@aol.com

In Support of the request for Class II eligibility for the Bennett Way Limited Partnership, SFB submits an original and two copies of the completed application, required documentation and supplemental supporting information.

Thank you for your consideration of SFB's request. If you have any questions or need additional information, please contact me directly.

Stephen Hirsh,

President

Solar Farm Bank LLC. 508-259-2419
Mailing address: P O Box 24 Medway, MA 02053
Office address: 205 Shaw Farm Rd Holliston, MA 01746
Solarfarmbank@gmail.com



State of New Hampshire Public Utilities Commission



21 S. Fruit Street, Suite 10, Concord, NH 03301-2429

DRAFT APPLICATION FORM FOR RENEWABLE ENERGY SOURCE ELIGIBILITY FOR CLASS I AND CLASS II SOURCES WITH A CAPACITY OF 100 KILOWATTS OR LESS

Pursuant to New Hampshire Administrative Code [Puc 2500](#) Rules including Puc 2505.08, Certification of Certain Customer-Sited Sources

- Please submit one (1) original and two (2) paper copies of the completed application and cover letter* to:

Debra A. Howland
Executive Director

New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

- Send an electronic version of the completed application and the cover letter electronically to executive.director@puc.nh.gov.

* The cover letter must include complete contact information and identify the renewable energy class for which the applicant seeks eligibility. Pursuant to Puc 2505.01, the Commission is required to render a decision on an application within 45 days of receiving a completed application.

If you have any questions please contact Barbara Bernstein at (603) 271-6011 or Barbara.Bernstein@puc.nh.gov.

Check the applicable class:

Eligibility Requested for Class I Class II

Applicant Name: Bennett Way Limited Partnership

Mailing Address: 600 Bennett Way

Town/City: Newmarket State: NH Zip Code: 03857

Primary Contact: Harvey Gertel / Scott Foster

Telephone: 603-659-5665 Cell: _____

Email address: hgertel@aol.com

The facility name and contact information (if different than applicant contact information).

Facility Name: Building 7
Mailing Address: 7 Bennett Way
Town/City: Newmarket State: NH Zip Code: 03857
Primary Contact: Harvey Gertel / Scott Foster
Telephone: 603-659-5665 Cell: _____
Email address: hgertel@aol.com

Provide a complete list of the equipment used at the facility, including the meter, and, if applicable, the inverter:

quantity		quantity	
37	Solar World SW265 265W Modules	3	Schlumberger Centron CL200 240V 3W Type C1S
37	Enphase M215 MicroInverter	3	Enphase Envoy Monitoring
3	Racking - IronRidge		

What is the nameplate capacity of your facility? 9.805 kW DC

What was the initial date of operation? 8/19/2013

*This is typically included in the interconnection agreement. Provide this documentation as **Attachment A**.*

Provide the name, license number and contact information of the installer, or indicate that the equipment was installed directly by the customer.

Installer Name: Harmony Energy Works Incorporated

Installer Address: 10 Gale Rd

License #: NABCEP PV Installer #032611-147

Town/City: Hampton State: NH Zip Code: 03842

Telephone: 603-926-3366 Cell: 603-512-3377

Email address: george.horrocks@harmonyenergyworks.com

If the equipment was installed directly by the customer, please check here:

Provide the name and contact information of the equipment vendor:

Check here if the installer and the equipment vendor were one and the same.

Business Name: _____

Vendor's Name: _____

Business Address: _____

Town/City: _____ State: _____ Zip Code: _____

Telephone: _____ Cell: _____

Email address: _____

If an independent electrician was used, please provide the following information:

Electrician's Name: Paul Miner

Business Name: Miner Electric

Business Address: 9 Tansy Lane

Town/City: Stratham State: NH Zip Code: 03885

License # 3941M

Provide the name and contact information of the independent monitor for this facility.

(A [list](#) of independent monitors is available at:

http://www.puc.nh.gov/Sustainable%20Energy/Renewable_Energy_Source_Eligibility.htm.)

Independent Monitor's Name: Paul Button

Town/City: Manchester State: NH Zip Code: 03104

Telephone: 603-617-2469 Cell: 603-836-4402

Email address: pbutton@energy-audits-unltd.com

Provide documentation of the applicable distribution utility's approval of the installation (This is usually included in the interconnection agreement.) If this documentation is separate from the interconnection document, please provide this as **Attachment B**.

Is the facility certified under another state's renewable portfolio standard? yes _____ no X

If "yes", then provide proof of the certification as **Attachment C**.

In order to qualify your facility's electrical production for Renewable Energy Certificates (RECs), you must register with the NEPOOL – GIS. Contact information for the GIS administrator follows:

James Webb
Registry Administrator, APX Environmental Markets
224 Airport Parkway, Suite 600, San Jose, CA 95110
Office: 408.517.2174
jwebb@apx.com

Mr. Webb will assist you in obtaining a GIS facility code and, if applicable, an ISO-New England asset ID number.

GIS Facility Code # NON-35889 Asset ID # Not Needed

Complete an attestation by the applicant that the project is installed and operating in conformance with any applicable state/local building codes. Use either the following attestation or provide a separate document as **Attachment D**.

AFFIDAVIT

The Undersigned applicant declares under penalty of perjury that the project is installed and operating in conformance with all applicable building codes.

Applicant's Signature Not needed if above supplied Date _____

Applicant's Printed Name _____

Subscribed and sworn before me this _____ Day of _____ (month) in the year

County of _____ State of _____

Notary Public/Justice of the Peace

My Commission Expires _____

CHECK LIST: The following has been included to complete the application:	YES
• All contact information requested in the application.	X
• A copy of the interconnection agreement, nameplate capacity and date of operation <i>(Attachment A.)</i>	x
• Documentation of the distribution utility's approval of the installation.* <i>(Attachment B.)</i>	X
• If the facility is participating in another state's renewable portfolio standard (RPS) program, documentation of certification in other state's RPS. <i>(Attachment C).</i>	
• A signed and notarized attestation or <i>Attachment D.</i>	
• A GIS number has been obtained.	
• The distribution utility's approval of the installation.*	
• The document has been printed and notarized.	
• The original and 2 copies are included in the packet mailed to Debra Howland, Executive Director of the PUC.	
• An electronic version of the completed application has been sent to executive.director@puc.nh.gov .	
<i>*Usually included in the interconnection agreement. If the interconnection agreement contains this information, attachment B is not necessary.</i>	

PREPARER'S INFORMATION


Preparer's Name: Solar Farm Bank LLC / Stephen Hirsh

Mailing Address: 205 Shaw Farm RD

Town/City: Holliston State: MA Zip Code: 01746

Telephone: 508-893-8993 Fax 508-893-8991 Cell: 508-259-2419

Email address: Solarfarmbank@gmail.com or solarfarmbank@verizon.net

Preparer's Signature:  SFBS eec

N2720

ATTACHMENT A, pg. 1

RECEIVED
JUN 19 2013
SESD

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE INTERCONNECTION STANDARDS FOR INVERTERS SIZED UP TO 100 KVA (Continued)

Simplified Process Interconnection Application and Service Agreement

Contact Information: Date Prepared: 6/17/2013
 Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)
 Customer or Company Name (print): Bennett Way Limited Partnership
 Contact Person, if Company: Harvey Gertel / Scott Foster
 Mailing Address: 600 Bennett Way
 City: Newmarket State: NH Zip Code: 03857
 Telephone (Daytime): 603-659-5665 (Evening): _____
 Facsimile Number: _____ E-Mail Address: hgertel@aol.com / scott@scgmgmnt.com

Alternative Contact Information (e.g., system installation contractor or coordinating company, if appropriate):
 Name: George Horrocks / Harmony Energy Works Incorporated
 Mailing Address: 10 Gale Road
 City: Hampton State: New Hampshire Zip Code: 03842
 Telephone (Daytime): 603-926-3366 (Evening): 603-512-3377
 Facsimile Number: _____ E-Mail Address: george.horrocks@harmonyenergyworks.com

Electrical Contractor Contact Information (if appropriate):
 Name: Paul Miner / Miner Electric Telephone: 603-772-6807
 Mailing Address: 9 Tansy Lane
 City: Stratham State: New Hampshire Zip Code: 03885

Facility Information:
 ✓ Address of Facility: 7 Bennett Way
 ✓ City: Newmarket State: NH Zip Code: 03857
 Electric Service Company: PSNH Account Number: 56523141018 ✓ Meter Number: 72758597
 Inverter Manufacturer: Enphase Model Name and Number: M215 Quantity: 12
 Nameplate Rating: .215*12 (kW) _____ (kVA) _____ (AC Volts) Single or Three _____ Phase
 System Design Capacity: .215*12 (kVA) _____ (kVA)
 Net Metering: If Renewably Fueled, will the account be Net Metered? Yes No _____
 Prime Mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other _____
 Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other _____
 ✓ UL 1741.1 (IEEE 1547.1) Listed? Yes No _____
 Estimated Install Date: 7/1/2013 Estimated In-Service Date: 8/31/2013

2.58kW

Interconnecting Customer Signature
 I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the Terms and Conditions on the following page.
 Customer Signature: [Signature] Title: Manager Date: 6/17/13
 Please attach any documentation provided by the inverter manufacturer describing the inverter's UL 1741 listing.

Approval to Install Facility (For Company use only)
 Installation of the Facility is approved contingent upon the terms and conditions of this Agreement, and agreement to any system modifications, if required. (Are system modifications required? Yes No To be Determined _____)
 Company Signature: [Signature] Title: SE ENGINEER Date: 6-24-13
 Company waives inspection / Witness Test? Yes No _____

METER V612S GR. 520 120/120

N2721

RECEIVED
JUN 19 2013
SESD

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA (Continued)

Simplified Process Interconnection Application and Service Agreement

Contact Information: Date Prepared: 6/17/2013
Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)
Customer or Company Name (print): Bennett Way Limited Partnership
Contact Person, if Company: Harvey Gertel / Scott Foster
Mailing Address: 600 Bennett Way
City: Newmarket State: NH Zip Code: 03857
Telephone (Daytime): 603-659-5665 (Evening):
Facsimile Number: E-Mail Address: hgertel@aol.com / scott@scgmgmnt.com

Alternative Contact Information (e.g., system installation contractor or coordinating company, if appropriate):
Name: George Horrocks / Harmony Energy Works Incorporated
Mailing Address: 10 Gale Road
City: Hampton State: New Hampshire Zip Code: 03842
Telephone (Daytime): 603-926-3366 (Evening): 603-512-3377
Facsimile Number: E-Mail Address: george.horrocks@harmonyenergyworks.com

Electrical Contractor Contact Information (if appropriate):
Name: Paul Miner / Miner Electric Telephone: 603-772-6807
Mailing Address: 9 Tansy Lane
City: Stratham State: New Hampshire Zip Code: 03885

Facility Information:
Address of Facility: 7 Bennett Way
City: Newmarket State: NH Zip Code: 03857
Electric Service Company: PSNH Account Number: 56135525012 Meter Number: 72756429
Inverter Manufacturer: Enphase Model Name and Number: M215 Quantity: 17
Nameplate Rating: 215*17 (kW) (kVA) (AC Volts) Single or Three Phase
System Design Capacity: 215*17 (kVA) (kVA)
Net Metering: If Renewably Fueled, will the account be Net Metered? Yes No
Prime Mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other
Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other
UL 1741.1 (IEEE 1547.1) Listed? Yes No
Estimated Install Date: 7/1/2013 Estimated In-Service Date: 8/31/2013

3.66 kW

Interconnecting Customer Signature
I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the Terms and Conditions on the following page.
Customer Signature: Harvey Gertel Title: Manager Date: 6/17/13
Please attach any documentation provided by the inverter manufacturer describing the inverter's UL 1741 listing.

Approval to Install Facility (For Company use only)
Installation of the Facility is approved contingent upon the terms and conditions of this Agreement, and agreement to any system modifications, if required (Are system modifications required? Yes No To be Determined)
Company Signature: Michael White Title: Sr. Engineer Date: 6-24-13
Company waives inspection / Witness Test? Yes No

VL125 GR 520 120/120

N2722

ATTACHMENT A, pg. 3

RECEIVED
JUN 19 2013
SESD

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE INTERCONNECTION STANDARDS FOR INVERTERS SIZED UP TO 100 KVA (Continued)

Simplified Process Interconnection Application and Service Agreement

Contact Information: Date Prepared: 6/17/2013
 Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)
 Customer or Company Name (print): Bennett Way Limited Partnership ✓
 Contact Person, if Company: Harvey Gertel / Scott Foster
 Mailing Address: 600 Bennett Way
 City: Newmarket State: NH Zip Code: 03857
 Telephone (Daytime): 603-659-5665 (Evening): _____
 Facsimile Number: _____ E-Mail Address: hgertel@aol.com / scott@scgmgmnt.com

Alternative Contact Information (e.g., system installation contractor or coordinating company, if appropriate):
 Name: George Horrocks / Harmony Energy Works Incorporated
 Mailing Address: 10 Gale Road
 City: Hampton State: New Hampshire Zip Code: 03842
 Telephone (Daytime): 603-926-3366 (Evening): 603-512-3377
 Facsimile Number: _____ E-Mail Address: george.horrocks@harmonyenergyworks.com

Electrical Contractor Contact Information (if appropriate):
 Name: Paul Miner / Miner Electric Telephone: 603-772-6807
 Mailing Address: 9 Tansy Lane
 City: Stratham State: New Hampshire Zip Code: 03885

Facility Information:
 ✓ Address of Facility: 7 Bennett Way
 ✓ City: Newmarket State: NH Zip Code: 03857
 Electric Service Company: PSNH Account Number: 56265525055 ✓ Meter Number: 72755958 ✓
 Inverter Manufacturer: Enphase Model Name and Number: M215 Quantity: 8
 Nameplate Rating: .215*8 (kW) _____ (kVA) _____ (AC Volts) Single or Three _____ Phase
 System Design Capacity: .215*8 (kVA) _____ (kVA)
 Net Metering: If Renewably Fueled, will the account be Net Metered? Yes _____ No _____
 Prime Mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other _____
 Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other _____
 ✓ UL 1741.1 (IEEE 1547.1) Listed? Yes No _____
 Estimated Install Date: 7/1/2013 Estimated In-Service Date: 8/31/2013

1.72 kW

Interconnecting Customer Signature
 I hereby certify that to the best of my knowledge, all of the information provided in this application is true and I agree to the Terms and Conditions on the following page:
 Customer Signature: Harvey Gertel Title: Manager Date: 6/17/13
 Please attach any documentation provided by the inverter manufacturer describing the inverter's UL 1741 listing.

Approval to Install Facility (For Company use only)
 Installation of the Facility is approved contingent upon the terms and conditions of this Agreement, and agreement to any system modifications, if required (Are system modifications required? Yes _____ No To be Determined _____)
 Company Signature: Muhammad Motta Title: Sr. Engineer Date: 6-24-13
 Company waives inspection / Witness Test? Yes No _____

EPPING 3191 X 1 B MAP C P. 57/BA X FMR 3-50 (150KVA)
 OCEAN ROAD - PTF PHASE / PHASE CONN.
 METER

RECEIVED
AUG 20 2013
SESD

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA (Continued)

Exhibit B - Certificate of Completion for Simplified Process Interconnections

Installation Information:

Check if owner-installed

Customer or Company Name (print): Bennett Way Limited Partnership
Contact Person, if Company: Harvey Gertel / Scott Foster
Mailing Address: 600 Bennett Way
City: Newmarket State: NH Zip Code: 03857
Telephone (Daytime): 603-659-5665 (Evening): _____
Facsimile Number: _____ E-Mail Address: hgertel@aol.com / scott@scgmgmnt.com

Address of Facility (if different from above): 7 Bennett Way
City: Newmarket State: NH Zip Code: 03857
Generation Vendor: Harmony Energy Works Incorporated Contact Person: George Horrocks

I herby certify that the system hardware is in compliance with Puc 900.

Vendor Signature:  Date: 8/19/13

Electrical Contractor's Name (if appropriate): Paul Miner / Miner Electric
Mailing Address: 9 Tansy Lane
City: Stratham State: New Hampshire Zip Code: 03885
Telephone (Daytime): 603-772-6807 (Evening): 603-772-6807
Facsimile Number: _____ E-Mail Address: minerelectric@comcast.net
License number: 3948M

Date of approval to install Facility granted by the Company: 6/17/2013 Installation Date: 8/19/2013

Application ID number: N2720

Inspection:

The system has been installed and inspected in compliance with the local Building/Electrical Code of
Newmarket, NH
(City/County)


Signed (Local Electrical Wiring Inspector, or attach signed electrical inspection): 

Name (printed): Michael Hoffman

Date: 8/19/2013

Customer Certification:

I hereby certify that, to the best of my knowledge, all the information contained in this Interconnection Notice is true and correct. This system has been installed and shall be operated in compliance with applicable electrical standards. Also, the initial start up test required by Puc 905.04 has been successfully completed.

Customer Signature:  Date: 8/19/13

RECEIVED
AUG 20 2013
SESD

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA (Continued)

Exhibit B - Certificate of Completion for Simplified Process Interconnections

Installation Information:

Check if owner-installed

Customer or Company Name (print): Bennett Way Limited Partnership
Contact Person, if Company: Harvey Gertel / Scott Foster
Mailing Address: 600 Bennett Way
City: Newmarket State: NH Zip Code: 03857
Telephone (Daytime): 603-659-5665 (Evening): _____
Facsimile Number: _____ E-Mail Address: hgertel@aol.com / scott@scgmgmnt.com

Address of Facility (if different from above): 7 Bennett Way
City: Newmarket State: NH Zip Code: 03857
Generation Vendor: Harmony Energy Works Incorporated Contact Person: George Horrocks

I herby certify that the system hardware is in compliance with Puc 900.


Vendor Signature:  Date: 8/19/13

Electrical Contractor's Name (if appropriate): Paul Miner / Miner Electric
Mailing Address: 9 Tansy Lane
City: Stratham State: New Hampshire Zip Code: 03885
Telephone (Daytime): 603-772-6807 (Evening): 603-772-6807
Facsimile Number: _____ E-Mail Address: minerelectric@comcast.net
License number: 3948 M

Date of approval to install Facility granted by the Company: 6/17/2013 Installation Date: 8/19/2013
Application ID number: N2722


Inspection:

The system has been installed and inspected in compliance with the local Building/Electrical Code of
Newmarket, NH
(City/County)

Signed (Local Electrical Wiring Inspector, or attach signed electrical inspection): 
Name (printed): Michael Hoffman
Date: 8/19/2013

Customer Certification:

I hereby certify that, to the best of my knowledge, all the information contained in this Interconnection Notice is true and correct. This system has been installed and shall be operated in compliance with applicable electrical standards. Also, the initial start up test required by Puc 905.04 has been successfully completed.

Customer Signature:  Date: 8/19/13

RECEIVED
AUG 20 2013
SESD

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA (Continued)

Exhibit B - Certificate of Completion for Simplified Process Interconnections

Installation Information:


Check if owner-installed

Customer or Company Name (print): Bennett Way Limited Partnership
Contact Person, if Company: Harvey Gertel / Scott Foster
Mailing Address: 600 Bennett Way
City: Newmarket State: NH Zip Code: 03857
Telephone (Daytime): 603-659-5665 (Evening): _____
Facsimile Number: _____ E-Mail Address: hgertel@aol.com / scott@scgmgmnt.com

Address of Facility (if different from above): 7 Bennett Way
City: Newmarket State: NH Zip Code: 03857

Generation Vendor: Harmony Energy Works Incorporated Contact Person: George Horrocks

I hereby certify that the system hardware is in compliance with Puc 900.

Vendor Signature:  Date: 8/19/13

Electrical Contractor's Name (if appropriate): Paul Miner / Miner Electric
Mailing Address: 9 Tansy Lane
City: Stratham State: New Hampshire Zip Code: 03885
Telephone (Daytime): 603-772-6807 (Evening): 603-772-6807
Facsimile Number: _____ E-Mail Address: minerelectric@comcast.net
License number: 3948 m

Date of approval to install Facility granted by the Company: 6/17/2013 Installation Date: 8/19/2013

Application ID number: N2721

Inspection:

The system has been installed and inspected in compliance with the local Building/Electrical Code of

Newmarket, NH
(City/County)


Signed (Local Electrical Wiring Inspector, or attach signed electrical inspection): 

Name (printed): M. J. ...

Date: 8/19/2013

Customer Certification:

I hereby certify that, to the best of my knowledge, all the information contained in this Interconnection Notice is true and correct. This system has been installed and shall be operated in compliance with applicable electrical standards. Also, the initial start up test required by Puc 905.04 has been successfully completed.

Customer Signature:  Date: 8/19/13

ATTACHMENT B, pg. 4



George Horrocks <george.horrocks@harmonyenergyworks.com>

#N2720, #N2721 & #N2722 Bennett Way PV (1-3) (Newmarket) - Certificates of Completion Processed

2 messages

katherine.roberge@nu.com <katherine.roberge@nu.com>

Tue, Aug 27, 2013 at 1:02 PM

To: hgartel@aol.com, scott@scgmgmt.com

Cc: michael.motta@nu.com, richard.labrecque@nu.com, george.horrocks@harmonyenergyworks.com

Dear Mr. Gertel:

We have processed the Exhibit B - Certificates of Completion for projects #N2720, #N2721 & #N2722 Bennett Way PV (1-3) (Newmarket) located at 7 Bennett Way, Newmarket, NH.

The Certificate of Completion has been reviewed and processed. Enrollment into the Net Metering program is complete and you may interconnect your project to the PSNH electrical distribution system in accordance with the *New Hampshire Code of Administrative Rules Chapter Puc 900 Net Metering For Customer-Owned Renewable Energy Generation Resources of 1000 Kilowatts or Less*, and the *Terms and Conditions for Simplified Process Interconnections*. Attached for your records is a copy of the "Certificate of Completion" and the "Simplified Process Interconnection Application and Service Agreement."

Please contact Michael D. Motta, Supplemental Energy Sources, at Michael.Motta@nu.com or by calling (603) 634-2920 should you have any questions or require additional information.

 This e-mail, including any files or attachments transmitted with it, is confidential and/or proprietary and is intended for a specific purpose and for use only by the individual or entity to whom it is addressed. Any disclosure, copying or distribution of this e-mail or the taking of any action based on its contents, other than for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Any views or opinions expressed in this e-mail are not necessarily those of Northeast Utilities, its subsidiaries and affiliates (NU). E-mail transmission cannot be guaranteed to be error-free or secure or free from viruses, and NU disclaims all liability for any resulting damage, errors, or omissions. *****

6 attachments

N2720 Bennett Way - Certificate of Completion.pdf
65K

N2720 Bennett Way - Processed Application.pdf
160K

N2721 Bennett Way PV - Certificate of Completion.pdf
63K

N2721 Bennett Way PV - Processed Application.pdf


ATTACHMENT D

DE 13-302



Harmony ENERGY WORKS

10 Gale Rd
Hampton, NH 03842
603-926-3366



**BENNETT WAY LIMITED PARTNERSHIP –
COMMISSIONING REPORT & CERTIFICATION OF SYSTEM OPERATION**

I am pleased to present this Letter of Certification in regards to the 9.805 kW - DC (STC) solar photovoltaic (PV) system installed at 7 Bennett Way, Newmarket, NH. In my role and capacity as PV Project Manager for the above installation, I do hereby certify that the 9.805 kW PV system has been inspected, commissioned, and interconnected with the grid and was officially placed in service on August 19, 2013. The project was installed and is operating in conformance with any applicable state/local building codes. The 9.805 kW PV system consists of 37 - 265W Solar World solar modules, 37 Enphase M215 Microinverters, 3 revenue-grade solar production meters and AC disconnects. All solar PV panels, inverters, and balance of system equipment are operating properly and as designed. The power output of the solar PV system is being fed into the PSNH grid as per the terms and conditions of the PSNH Standard Interconnection Agreement and *CHAPTER PUC 900 Net Metering For Customer-Owned Renewable Energy Generation Resources Of 1000 Kilowatts Or Less* of the NH Public Utility Commission (NHPUC).

Installer's Signature Date 10/29/13

Installer's Printed Name George Horrocks

Subscribed and sworn before me this 29 Day of October (month) in the year 2013

County of Rockingham State of New Hampshire

Notary Public/Justice of the Peace

My Commission Expires OCT. 3, 2017

**RYAN S. NICKERSON
NOTARY PUBLIC
STATE OF NEW HAMPSHIRE
MY COMMISSION EXP OCT.3, 2017**