



DE 13-332

Knollwood Energy of MA LLC  
P.O. Box 30  
Chester, New Jersey 07930

April 17, 2015

Debra A. Howland  
Executive Director  
New Hampshire Public Utilities Commission  
21 South Fruit Street, Suite 10  
Concord, NH 03301-2429

NHPUC 27 APR '15 PM 12:42

Dear Ms Howland,

Enclosed please find an additional (expansion) Interconnection Application for the David Tofts system to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.

*Note: The original Knollwood Energy Application was emailed on 4/7, postal mailed on 4/8. This system is a TRANSFER from NHEC effective 4/1/15. Please reference DE 13-332 for original application information as all paperwork required is not available in this packet. Also enclosed please find a letter from NHEC requesting monitoring withdrawal effective 3/31/15.*

Customer and Facility Information

DE 13-332  
David Tofts  
272 Meredith Neck Road  
Meredith, NH 03253  
302.235.0945  
dtofts@gmail.com

The Nepool GIS ID # for this facility is: NON47599.


Please do not hesitate to contact me if you have any questions regarding this application. An electronic copy of this paperwork was sent on 4/15.

Thank you for your consideration,

Linda Modica  
New England REC Operations Manager  
**Knollwood Energy of MA LLC**  
973.879.7826  
[linda@knollwoodenergy.com](mailto:linda@knollwoodenergy.com)

Enclosures (3)

*Knollwood Energy - Your best resource for selling and buying solar renewable energy credits*



**NEW HAMPSHIRE ELECTRIC CO-OP  
INTERCONNECTION APPLICATION-RENEWABLE GENERATION UP TO 1000 KW**

PURSUANT TO NEW HAMPSHIRE ADMINISTRATIVE RULE PUC 900, APPLICANT HEREBY GIVES NOTICE OF INTENT TO INSTALL AND OPERATE A GENERATING FACILITY.

**Section 1. Applicant Information**

Name: David Tofts  
Mail Address: 272 Meredith Neck Rd.  
City: Meredith State: NH Zip Code: 03253  
Facility Location (if different from above): \_\_\_\_\_  
Daytime Phone #: 603-677-7616 or call 302-235-0945  
Distribution Utility: New Hampshire Electric Cooperative, Inc. Account #: \_\_\_\_\_  
Electricity Supplier (ES) \_\_\_\_\_ Account #: \_\_\_\_\_

**Section 2. Generating Facility Information**

Generator Type (check one): Solar  Wind \_\_\_\_\_ Hydro \_\_\_\_\_  
Generator Manufacturer, Model Name & Number: (10) SunPower 327W - SPR E20 - 327  
(18) SunPower 335W - SPR-X 21-335  
Number of Phases of Unit: Single, Three or Other: Single  
Generation output rating in Kilowatts: 9.3 kW Note: Added to existing 8,829 kW array that was finished on 10/28/13  
Inverter Manufacturer, Model Name & Number: (3) SMA 3000TLUS-22 Inverters  
Battery backup?  Yes  No  
Will a generator Disconnect Switch accessible to the utility be installed?  Yes  No  
Proposed location of Disconnect Switch, if applicable: by Net + REC Meter

**Section 3. Installation Information & Certification**

Check if owner-installed  
Installation Date: 12/2/13  
Installing Electrician: Frase Electric LLC  
State of NH License #: 4446  
Mail Address: 789 Whittier Hwy  
City: So. Tamworth  
State: NH Zip Code: 03883  
Daytime Phone #: 603-284-6618

1. The system hardware is listed to Underwriters Laboratories standards to be in compliance with UL 1741 and IEEE 929-2000:

Signed (Vendor/Supplier): [Signature]

Name (printed): Kim Frase Date: 12/11/13

Company: Frase Electric LLC

Company Address: 781 Whittier Hwy, So. Tamworth, NH 03883

2. The system has been installed in compliance with the local Building/Electrical Code of

see attached letter (City/County)

Signed (Electrician or Town Inspector): [Signature]

Print Name: Kim Frase Date: 12/14/13

*In lieu of signature by inspector, a copy of final inspection certificate may be attached.*

3. The initial start-up test required by PUC 905.04 has been successfully completed.

Completed on 12/2/13 Witnessed By [Signature]

4. Utility signature to signify only receipt of this form, in compliance with the Commission's net metering rules PUC 908.

Signed (NHEC): [Signature]

Print Name: Scott McNeil Date: 12-2-13

Signed (Electricity Supplier Representative): \_\_\_\_\_

Date: \_\_\_\_\_

5. Interconnection Date: 12.2.13

Applicant agrees to install and operate the system in accordance with PUC 900.

I hereby certify that, to the best of my knowledge, all of the information provided in this Application is true and correct.

Signature of Applicant: [Signature] Date: 12-6-13

THE ELIGIBLE CUSTOMER-GENERATOR SHALL PROVIDE NEW HAMPSHIRE ELECTRIC CO-OP WITH A WRITTEN UPDATE OF THE INFORMATION ON THIS FORM AS ANY CHANGES OCCUR.