

NORTHERN UTILITIES, INC.

**DIRECT TESTIMONY OF
RICK AHLIN**

New Hampshire Public Utilities Commission

Docket No. DG 15-121

Table of Contents

I. INTRODUCTION..... 1

II. JUNE 25, 2014 INSPECTION OF NEW HAMPSHIRE AVENUE
REGULATOR STATION 2

III. REGULATOR STATION MAINTENANCE AND ADJUSTMENT OF
REGULATOR SET POINTS 7

Table of Attachments

- A: Barberry Lane station pressure recording (June 25, 2014)
- B: Marcy Street station pressure recording (June 25, 2014)

1 **I. INTRODUCTION**

2 **Q. Please state your name and business address.**

3 **A.** My name is Rick Ahlin. My business address is 325 West Road, Portsmouth, New
4 Hampshire.

5
6 **Q. What is your position and what are your responsibilities?**

7 **A.** I am the System Operations Supervisor for the New Hampshire Division of Northern
8 Utilities, Inc. (“Northern” or the “Company”). My primary responsibilities are the
9 supervision of the operation and maintenance of Northern’s gas pressure regulating
10 facilities in New Hampshire.

11
12 **Q. Please describe your professional background and qualifications.**

13 **A.** I possess more than 22 years of experience in the natural gas industry, focused primarily
14 on distribution and pressure control. I joined the Company in 1992 as Streetman
15 Apprentice. Since then, I have been promoted through jobs of increasing responsibility
16 and was most recently promoted to my current position in 2008. I have attended
17 numerous educational programs pertinent to pressure regulation, including the Emerson
18 Controls Regulator Maintenance and Troubleshooting Courses, the Gas Technology
19 Institute’s Regulator Station Design Course, the Northeast Gas Association’s Operations
20 Course, and the Appalachian Gas Measurement Short Course. I also serve as member of
21 the General Committee for the Appalachian Gas Measurement Short Course.

22

1 I am currently Operator Qualified in 49 Covered Tasks, including those that relate
2 directly to pressure regulation and the operation and maintenance of regulator facilities.

3

4 **Q. What is the purpose of your testimony?**

5 **A.** The purpose of my testimony is to describe the events that occurred at the New
6 Hampshire Avenue regulator station during an inspection performed by the New
7 Hampshire Commission's Safety Staff on June 25, 2014. I will also provide background
8 on the procedures typically used by the Company to adjust the set points for monitor and
9 worker regulators for the Company's regulator stations.

10

11 **II. JUNE 25, 2014 INSPECTION OF NEW HAMPSHIRE AVENUE**

12 **REGULATOR STATION**

13

14 **Q. Were you present during the New Hampshire Commission Staff's inspection of the**
15 **New Hampshire Avenue regulator station on June 25, 2014?**

16 **A.** Yes, I was. Commission Staff was performing an inspection of the Company on that day.
17 Dave Burnell of the Commission's Staff was performing the inspection and he was
18 accompanied by Glynn Blanton, who was representing the Pipeline and Hazardous
19 Materials Safety Administration ("PHMSA"). It was my understanding from Mr. Burnell
20 that Mr. Blanton was present to perform an evaluation of Mr. Burnell's performance with
21 regard to the inspection.

22

1 The inspection lasted most of the day on June 25. During the morning, Mr. Burnell
2 performed document review at the Company's engineering and operations facility on
3 West Road in Portsmouth. Before the lunch break, Mr. Burnell explained to me that he
4 wanted to perform an inspection of the New Hampshire Avenue regulator station after
5 lunch. We made arrangements to meet there at approximately 1:00 PM.

6

7 **Q. How did the inspection of the regulator station start?**

8 **A.** The inspection started out with me providing a general overview of the regulator station
9 and its various components. Among other things, I pointed out where gas enters the
10 station from the Granite State Gas Pipeline system, the two regulator runs in the regulator
11 station, the worker and monitor regulators in each run, and I explained the inlet pressure
12 and outlet pressure of the station. The station is described in greater detail in the Direct
13 Testimony of Chris LeBlanc and Jon Pfister.

14

15 **Q. What happened after you provided an overview of the station?**

16 **A.** As confirmed in the Staff's discovery responses, Mr. Burnell told me that he wanted to
17 test the overpressure protection for the station and he directed the technician on site to
18 fail the worker regulator on Run A.

19

20 The Unitil technician increased the set point on the worker regulator in Run A of the
21 station to simulate its failure as directed. Before that adjustment was made, the set point
22 of the worker in Run A was set at 52 psig, and the digital pressure gauge at the outlet of
23 the station read 52 psig. As the technician increased the set point pressure on the Run A

1 worker regulator, I explained to Mr. Burnell that the pressure reading on the digital gauge
2 would rise until the monitor regulator assumed control of pressure at the station. We
3 watched the pressure increase on the gauge, and it exceeded the MAOP of 56 psig. Mr.
4 Burnell saw this, and he stated that MAOP had been exceeded and he halted the first test.
5 The technician then decreased the set point on the worker regulator until the pressure
6 gauge at the outlet of the regulator station was brought back to 52 psig.

7

8 **Q. Were you concerned that the distribution system was in an unsafe condition when**
9 **the pressure on the digital gauge rose above MAOP during the simulation?**

10 A. No. I understood that this buildup pressure was normal and I'm also aware that the steel
11 piping in the regulator station is designed to handle pressures that far exceed the 56 psig
12 MAOP rating of the distribution system.

13

14 **Q. What happened after the station was brought back to 52 psig.?**

15 A. I explained to Mr. Burnell that the monitor regulator is set at 55 psig, but there is a
16 buildup pressure that occurs as an operational function when the monitor regulator takes
17 control over system pressure and that buildup pressure was reflected in the pressure
18 gauge at the regulator station. I explained that the monitor regulator would have
19 eventually taken control over system pressure and brought the pressure back down to the
20 monitor regulator's set point of 55 psig.

21

22 **Q. Did Mr. Burnell seem satisfied with that explanation?**

23 A. Yes, he did.

1 **Q. What happened after you explained the buildup pressure to Mr. Burnell?**

2 A. Mr. Burnell instructed us to perform the same simulated failure of the worker regulator,
3 but this time on Run B.

4

5 **Q. Prior to the start of the simulation on Run B, did Mr. Burnell express any concern**
6 **about performing a simulation similar to that which was performed on Run A?**

7 A. No, he did not.

8

9 **Q. Please describe the simulation on Run B.**

10 A. We moved over to Run B. Run B is configured similar to Run A with both a worker and
11 monitor regulator. The Run B worker regulator is set at 50 psig and the monitor is set at
12 55 psig. Because Run A was controlling system pressure, Run B was in standby and
13 there was no gas flowing through Run B. As with Run A, I directed the technician to
14 increase the set point on the Run B worker regulator. The reading on the pressure gauge
15 at the outlet of the station increased to around 57 psig. After a minute or so, the reading
16 on the pressure gauge began to decrease as the monitor regulator assumed control from
17 the worker regulator and the buildup pressure was relieved. The reading on the pressure
18 gauge continued to decrease until it settled at 55 psig, which is the set point of the
19 monitor regulator.

20

21 **Q. You testified previously that a representative from PHMSA was present during Mr.**
22 **Burnell's inspection of the regulator station. Did the PHMSA representative raise**

1 **any concerns during these simulations with regard to the pressure gauge readings at**
2 **the regulator station?**

3 A. No, the PHMSA representative did not.

4

5 **Q. Although you observed the pressure gauge at the regulator station rise to**
6 **approximately 57 psig during the simulations on Run B, are you aware of what the**
7 **pressure was on other parts of the distribution system while the simulations were**
8 **being performed?**

9 A. Yes. The Portsmouth IP distribution system has pressure sensing devices that will trigger
10 a “high” pressure alarm condition at Gas Control if pressure on the distribution system
11 exceeds 55 psig. A “high-high” pressure alarm condition is triggered if system pressure
12 exceeds 56 psig. I contacted the gas controller on duty in the Control Room after the
13 simulations and was told that no alarms were triggered during the simulations on the
14 Portsmouth IP system.

15

16 There two points on the Portsmouth IP system that are pressure monitored: the outlet of
17 the Barberry Lane regulator station and at the inlet to the Marcy Street regulator station.
18 Attachments A and B to my testimony show the pressures recorded on June 25, 2014 at
19 these monitor points at the Barberry Lane and Marcy Street stations, respectively. The
20 pressures recorded during that afternoon at the outlet of the Barberry Lane station
21 fluctuated around 52-53 psig while at the inlet to Marcy Street station the pressure was
22 around 51-53 psig. The recorded pressures were at all times well below the 56 psig
23 MAOP for the Portsmouth IP system.

1 **Q. How is it possible that the pressure gauge at the New Hampshire Avenue Station**
2 **registered pressure that was above 56 psig during the simulations you have**
3 **described, while the pressure records in Attachments A and B are in the 51-53 psig**
4 **range?**

5 **A.** The Portsmouth IP system was supplying gas to our customers who are served by that
6 system, as well as customers on the low pressure system that are fed by the Portsmouth
7 IP system. Each of those loads accounts for a pressure drop on the Portsmouth IP system,
8 and there are also pressure drops due to friction as the gas moves through the distribution
9 system. So, while the digital pressure gauge in the Portsmouth Avenue regulator station
10 briefly read in excess of 56 psig during the two simulations, due to the normal operation
11 of the system the downstream pressures recorded at the Barberry Lane and Marcy Street
12 stations were well below 56 psig.

13

14 **III. REGULATOR STATION MAINTENANCE AND ADJUSTMENT**
15 **OF REGULATOR SET POINTS.**

16 **Q. In part II of your testimony, you described simulated failures of the worker**
17 **regulators on Run A and Run B at the New Hampshire Avenue Station. Is the**
18 **simulated failure of the worker regulator a procedure that Until uses when**
19 **performing maintenance or testing of its pressure regulating stations?**

20 **A.** No, it is not. The simulated failure is not how we maintain or test overpressure protection
21 of our pressure regulating stations. The Company has an Operations and Maintenance
22 Procedure 2-L, which it follows when performing periodic maintenance and testing of

1 pressure regulating stations. A copy of this procedure is Attachment J to the testimony of
2 Messrs. LeBlanc and Pfister.

3

4 **Q. How does the Company ensure that regulators are adjusted to the proper set point?**

5 **A.** The procedure we use to set regulator set points in a worker-monitor configuration such
6 as at the New Hampshire Avenue Station is as follows:

7 (1) The run is removed from service by closing both the inlet and outlet valves for the
8 run; the run is then blown down to 0 psig.

9 (2) The pilot adjustment screw on the worker regulator is backed off completely
10 while the monitor regulator pilot adjustment screw is turned in completely to
11 allow the flow of gas to pass through the monitor regulator but not the worker.

12 (3) The inlet valve to the run is then opened to allow gas to flow to the worker
13 regulator to be able to establish a bubble tight lock up. Bubble tight lock up is the
14 term used to describe the regulator's ability to stop the flow of gas completely.

15 (4) The monitor regulator pilot adjustment screw is then turned out completely. The
16 worker regulator pilot adjustment screw is then turned in allowing the gas to be
17 evacuated between the worker and monitor regulators and allows the monitor
18 regulator to be able to be checked for a bubble tight lockup.

19 (5) If no gas is passing through the monitor, then the outlet valve for the run is
20 opened.

21 (6) The pilot adjustment screw on the monitor regulator is then turned in until the
22 desired set point for the monitor regulator is reached.

1 (7) The pilot adjustment screw on the worker regulator is then turned out until the
2 desired set point for the worker regulator is reached.

3 By following this procedure, the Company is able to confirm both the proper operation
4 and set points for the monitor and worker regulators without exceeding MAOP.

5

6 **Q. Does this conclude your testimony?**

7 **A. Yes, it does.**