

1 A. It shows that the requirements for relief devices (the primary alternative to a monitor  
2 regulator) can be traced back to the same “consistent with the pressure limits of  
3 §192.201(a)” standard that applies to monitor regulators.

4  
5 **Q. Has PHMSA issued interpretations regarding the pressure allowances for  
6 overpressure protection?**

7 A. Yes. The first interpretation I will discuss was issued by PHMSA in 1982, and later  
8 amended when PHMSA concluded that its interpretation used imprecise language.  
9 The 1982 interpretation is Interpretation 192.201 14, dated September 16, 1982 (see  
10 Attachment F), which states:

11 “The plain language of paragraphs (a), (b), and (c) makes it clear that the  
12 purpose of §192.743 is to assure that relief devices at pressure limiting and  
13 regulating stations have sufficient capacity to limit downstream pressure to  
14 the “desired maximum pressure.” It follows that the term “required capacity”  
15 in paragraph (b) refers to the capacity of relief devices that is needed to  
16 achieve this purpose, and not to a capacity required by §192.201(a). ...

17  
18 PHMSA further stated:

19 Section 192.201(a) prescribes capacities that apply to the design of pressure  
20 relief and limiting stations. The purpose of this rule is to assure that stations  
21 are installed with sufficient capacity to prevent accidental overpressure in  
22 connected facilities, based on specified safe pressure limits known at the time  
23 of design. As operating conditions change, these limits may exceed the  
24 “desired maximum pressure” of the facilities so that additional capacity would  
25 be required to meet §192.743. Therefore, the capacity requirements of  
26 §192.201(a) should not be used to determine the capacity of relief devices  
27 needed to meet §192.743.”  
28

William Hewitt 8/13/2015 12:50 PM

Deleted: 13

William Hewitt 8/13/2015 12:51 PM

Deleted: February 1

CORRECTED

1 It should be noted that the requirements for the desired maximum pressure allowed by  
2 a monitor regulator would be no different than the desired maximum pressure for a  
3 relief device.

4 **Q. Does that indicate that your interpretation is incorrect?**

5 A. It might, except that the following year PHMSA was asked to reconsider that  
6 interpretation, and it do so in Interpretation 192.201 15 dated March 31, 1983 (see  
7 Attachment G):

8 Upon reconsideration, we confirm the *merits of the interpretation* as it relates  
9 to *applying §192.201 to judging the capacities required by §192.743*.  
10 However, we believe that the stated relationship between "desired maximum  
11 pressures" and MAOP could be misconstrued and result in a conflict with  
12 §192.201 and an unjustified burden for operators of existing relief valves.

13  
14 We believe the problem you have identified with Interpretation 82-9 [a/k/a  
15 Interpretation 102.201 14] would be resolved if the "*desired maximum*  
16 *pressure" under §192.743* were interpreted to *include a safe amount of*  
17 *pressure build-up above the MAOP. For valves subject to §192.201, the safe*  
18 *amount would be that set forth in §192.201*, and the *capacities required by*  
19 *§§192.201 and 192.743 would be the same* until allowable operating pressure  
20 limits change. For pre-existing relief valves that do not conform with the  
21 criteria of §192.201, the safe amount would be that which a prudent operator  
22 would have established when the valve was installed.

23  
24 Accordingly, a *footnote has been added to Interpretation 82-9* to correct the  
25 problem, and the interpretation is reissued. A copy of the reissued  
26 interpretation is enclosed.

27  
28 The footnote that PHMSA added to Interpretation 82-9 states:

29 1/ for purposes of *pressure relief capacity, operating pressure limits* may be  
30 exceeded by a safe amount. *Section 192.201 specifies the amounts for relief*  
31 *devices subject to that section*. The allowable amount for other relief devices  
32 installed before Section 192.201 became effective would be that which a  
33 prudent operator would have established under similar circumstances.  
34  
35

William Hewitt 8/13/2015 12:52 PM  
Deleted: 13

William Hewitt 8/13/2015 12:52 PM  
Deleted: 13

1 | Q. Does PHMSA's amended version of Interpretation 192.201 <sup>14</sup> support your  
2 analysis concerning Section 192.201?

3 A. Yes, it does.  
4

5 Q. Are there any more recent PHMSA interpretations that address the issues in  
6 Staff's NOV?

7 A. Yes. By letter dated September 5, 2014, Northern requested an interpretation from  
8 PHMSA addressing the specific overpressure protection settings for the New  
9 Hampshire Avenue Gate Station. By reply dated April 21, 2015 (see Attachment N to  
10 LeBlanc/Pfister testimony), PHMSA confirmed that system pressure is allowed to  
11 rise to 62 psig for a 56 psig MAOP system during a failure of the worker regulator.  
12 Unutil's question, and PHMSA's answer are provided below:

13 Q. (2) During a system emergency, such as a failed worker regulator, on a  
14 high pressure distribution system with a properly established MAOP  
15 of 56 psig, does the operator violate 49 C.F.R. § 192.201(a) if the  
16 system pressure does not exceed 62 psig?

17 A. No, *the operator does not violate § 192.201(a)* as long as the MAOP  
18 limits are met during a system emergency and the pipeline meets the  
19 Subpart D - Design of Pipeline Components requirements. In this  
20 case, *the emergency operating limit is 62 psi (56 + 6 psi)*. Emergency  
21 operating overpressure conditions are only allowed for the time  
22 required to activate the overpressure protection device and are not  
23 meant for long term or frequently occurring normal operating or  
24 periodic maintenance conditions and, therefore, require immediate  
25 response by the operator either to shut down or reduce the operating  
26 pressure to the normal operating conditions.  
27

28 There is no dispute that the pressure at the New Hampshire Avenue Gate Station  
29 peaked at 57.2 psig during the simulated failure of the worker regulator, which is less

1 than the 62 psig allowed by Section 192.201(a)(2)(ii). PHMSA confirmed that there  
2 was no Code violation, notwithstanding that pressure within the station exceeded  
3 MAOP.

4  
5 **Q. Were there any issues raised by PHMSA regarding the testing of the**  
6 **overpressure protection that occurred on June 25, 2014, when Commission Staff**  
7 **directed that a failure of the worker regulator be simulated to assess the**  
8 **operation of Northern's over pressure protection?**

9 A. Yes. PHMSA seems to disapprove of the practice of testing overpressure protection  
10 through a simulation of a failure of the worker regulator while those components are  
11 actively controlling system pressure: “[a] simulated test on a pressure limiting or  
12 regulator station that is not isolated from the system does not constitute a system  
13 emergency. It is a normal operation subject to the limitations described above. The  
14 pressure limiting or regulator station should be isolated from the system prior to any  
15 testing of buildup and set points.”

16  
17 Although I cannot whole-heartedly support that position (especially with properly  
18 trained pressure mechanics on site to ensure the safety of the system), if such a  
19 simulation does constitute a violation of Section 192.619, it was a violation that  
20 resulted from Northern’s compliance with the directives of Commission Staff.

1 A. It shows that the requirements for relief devices (the primary alternative to a monitor  
2 regulator) can be traced back to the same “consistent with the pressure limits of  
3 §192.201(a)” standard that applies to monitor regulators.

4

5 **Q. Has PHMSA issued interpretations regarding the pressure allowances for**  
6 **overpressure protection?**

7 A. Yes. The first interpretation I will discuss was issued by PHMSA in 1982, and later  
8 amended when PHMSA concluded that its interpretation used imprecise language.

9 The 1982 interpretation is Interpretation 192.201 14, dated September 16, 1982 (see  
10 Attachment F), which states:

11 “The plain language of paragraphs (a), (b), and (c) makes it clear that the  
12 ***purpose of §192.743 is to assure that relief devices at pressure limiting and***  
13 ***regulating stations have sufficient capacity*** to limit downstream pressure to  
14 the ***“desired maximum pressure.”*** It follows that the term “required capacity”  
15 in paragraph (b) refers to the capacity of relief devices that is needed to  
16 achieve this purpose, and not to a capacity required by §192.201(a). ...

17

18 PHMSA further stated:

19 Section 192.201(a) prescribes capacities that apply to the design of pressure  
20 relief and limiting stations. The purpose of this rule is to assure that stations  
21 are installed with sufficient capacity to prevent accidental overpressure in  
22 connected facilities, based on specified safe pressure limits known at the time  
23 of design. As operating conditions change, these limits may exceed the  
24 “desired maximum pressure” of the facilities so that additional capacity would  
25 be required to meet §192.743. Therefore, the capacity requirements of  
26 §192.201(a) should not be used to determine the capacity of relief devices  
27 needed to meet §192.743.”

28

1 It should be noted that the requirements for the desired maximum pressure allowed by  
2 a monitor regulator would be no different than the desired maximum pressure for a  
3 relief device.

4 **Q. Does that indicate that your interpretation is incorrect?**

5 A. It might, except that the following year PHMSA was asked to reconsider that  
6 interpretation, and it do so in Interpretation 192.201 15 dated March 31, 1983 (see  
7 Attachment G):

8 Upon reconsideration, we confirm the *merits of the interpretation* as it relates  
9 to *applying §192.201 to judging the capacities required by §192.743*.  
10 However, we believe that the stated relationship between "desired maximum  
11 pressures" and MAOP could be misconstrued and result in a conflict with  
12 §192.201 and an unjustified burden for operators of existing relief valves.

13  
14 We believe the problem you have identified with Interpretation 82-9 [a/k/a  
15 Interpretation 102.201 14] would be resolved if the "*desired maximum*  
16 *pressure" under §192.743* were interpreted to *include a safe amount of*  
17 *pressure build-up above the MAOP. For valves subject to §192.201, the safe*  
18 *amount would be that set forth in §192.201, and the capacities required by*  
19 *§§192.201 and 192.743 would be the same* until allowable operating pressure  
20 limits change. For pre-existing relief valves that do not conform with the  
21 criteria of §192.201, the safe amount would be that which a prudent operator  
22 would have established when the valve was installed.

23  
24 Accordingly, a *footnote has been added to Interpretation 82-9* to correct the  
25 problem, and the interpretation is reissued. A copy of the reissued  
26 interpretation is enclosed.

27  
28 The footnote that PHMSA added to Interpretation 82-9 states:

29 1/ for purposes of *pressure relief capacity, operating pressure limits* may be  
30 exceeded by a safe amount. *Section 192.201 specifies the amounts for relief*  
31 *devices subject to that section*. The allowable amount for other relief devices  
32 installed before Section 192.201 became effective would be that which a  
33 prudent operator would have established under similar circumstances.

34  
35

1    **Q.    Does PHMSA’s amended version of Interpretation 192.201 14 support your**  
2           **analysis concerning Section 192.201?**

3    A.    Yes, it does.

4

5    **Q.    Are there any more recent PHMSA interpretations that address the issues in**  
6           **Staff’s NOV?**

7    A.    Yes. By letter dated September 5, 2014, Northern requested an interpretation from  
8           PHMSA addressing the specific overpressure protection settings for the New  
9           Hampshire Avenue Gate Station. By reply dated April 21, 2015 (see Attachment N to  
10          LeBlanc/Pfister testimony), PHMSA confirmed that system pressure is allowed to  
11          rise to 62 psig for a 56 psig MAOP system during a failure of the worker regulator.

12         Unitil’s question, and PHMSA’s answer are provided below:

13                 Q.    (2) During a system emergency, such as a failed worker regulator, on a  
14                         high pressure distribution system with a properly established MAOP  
15                         of 56 psig, does the operator violate 49 C.F.R. § 192.201(a) if the  
16                         system pressure does not exceed 62 psig?

17                 A.    No, ***the operator does not violate § 192.201(a)*** as long as the MAOP  
18                         limits are met during a system emergency and the pipeline meets the  
19                         Subpart D - Design of Pipeline Components requirements. In this  
20                         case, ***the emergency operating limit is 62 psi (56 + 6 psi)***. Emergency  
21                         operating overpressure conditions are only allowed for the time  
22                         required to activate the overpressure protection device and are not  
23                         meant for long term or frequently occurring normal operating or  
24                         periodic maintenance conditions and, therefore, require immediate  
25                         response by the operator either to shut down or reduce the operating  
26                         pressure to the normal operating conditions.

27

28                 There is no dispute that the pressure at the New Hampshire Avenue Gate Station  
29                 peaked at 57.2 psig during the simulated failure of the worker regulator, which is less

1 than the 62 psig allowed by Section 192.201(a)(2)(ii). PHMSA confirmed that there  
2 was no Code violation, notwithstanding that pressure within the station exceeded  
3 MAOP.

4

5 **Q. Were there any issues raised by PHMSA regarding the testing of the**  
6 **overpressure protection that occurred on June 25, 2014, when Commission Staff**  
7 **directed that a failure of the worker regulator be simulated to assess the**  
8 **operation of Northern's over pressure protection?**

9 A. Yes. PHMSA seems to disapprove of the practice of testing overpressure protection  
10 through a simulation of a failure of the worker regulator while those components are  
11 actively controlling system pressure: “[a] simulated test on a pressure limiting or  
12 regulator station that is not isolated from the system does not constitute a system  
13 emergency. It is a normal operation subject to the limitations described above. The  
14 pressure limiting or regulator station should be isolated from the system prior to any  
15 testing of buildup and set points.”

16

17 Although I cannot whole-heartedly support that position (especially with properly  
18 trained pressure mechanics on site to ensure the safety of the system), if such a  
19 simulation does constitute a violation of Section 192.619, it was a violation that  
20 resulted from Northern’s compliance with the directives of Commission Staff.

21