

## **APPENDIX A**

### **F107 & 380 Lines OYSTER RIVER DURHAM, NH**

1. The design and proposed construction of this crossing is shown on the attached PSNH Transmission Business Drawing entitled “DOUBLE CKT F107 & 380 BETWEEN STR. 28 & 29 OYSTER RIVER, DURHAM, NEW HAMPSHIRE” (Drawing No. F10740901) marked as Exhibit 1.
2. The location of the double circuit F107 and 380 crossing is shown on the attached Location Plan marked as Exhibit 2.
3. Line F107 and 380 will cross the Oyster River on a 1-pole, direct embed, 110 foot pole (16.5 feet embedded), steel tangent suspension structure (northern side) and on a 1-pole, 100 foot, steel deadend strain structure on concrete foundation (southern side). Details of these structures are shown on Exhibit 1. As shown on Exhibit 1, for Structure 28 the 115kV phase wires have an approximate separation at the structure of 7 - 15 feet vertically and 0-13 feet horizontally in a delta configuration. The static wire is carried on the structure by a support bracket approximately nine inches down from the top of the structure. The 34.5kV phase wires are arranged horizontally approximately 15 feet below the lowest 115kV conductor and have an approximate separation at the structure of 0-5 feet vertically and 3-6 feet horizontally. The neutral wire is carried on the structure by a support bracket approximately seven feet down below the 34.5kV phase wires. As shown on Exhibit 1, for Structure 29 the 115kV phase wires have an approximate separation at the structure of 7 -15 feet vertically and 3-20 feet horizontally in a delta configuration. The static wire is carried on the structure by a support bracket approximately six inches down from the top of the structure. The 34.5kV phase wires are arranged horizontally approximately 16 feet below the lowest 115kV conductor and have an approximate separation at the structure of zero feet vertically and five feet horizontally. The neutral wire is carried on the structure by a support bracket approximately seven feet down below the 34.5kV phase wires. All NESC clearances at the structure, as described in paragraph 11 of the petition, have been met by exceeding the horizontal and/or vertical clearances required. Land along the shoreline between the structures of this crossing and the river is not traversable by vehicles. However, minimum distances to ground per the NESC have been met. A clearance of 24 feet between the neutral and the closest ground point has been provided. This exceeds the NESC required clearance of 15.5 feet by 8.5 feet. As all other phase wires are above this elevation they will always exceed the NESC required clearance.
4. Flood water elevations for the Oyster River were based on information contained in flood insurance rate maps provided by FEMA. Flood elevations are based on FEMA FIRM Map 33017C0314D Panel 314 or 405 dated May 17, 2005 and FEMA FIS Study 33015CV001A Dated May 17, 2005. The 10-year flood elevation for this portion

of the river is approximately 33.3 feet. The area of the crossing, as required by the NESC (Section 232), is approximately 38.1 acres (314 feet x5280 feet/43560sf/acre). As stated in paragraph 10 of the petition, the minimum required 115 kV conductor clearance for water surface areas between 20-200 acres is 30.1 feet for 115 kV, and 28.5 feet for 34.5 kV.

5. The sags and clearances to the water surface during a 10-year flood event for this crossing are as follows;

- PSNH has investigated a multitude of weather and loading conditions for its design. PSNH used these design conditions and combinations thereof to determine the minimum clearance of all conductors to the water and land surfaces, between the phase conductors and OPGW cable and neutral conductors. PSNH has determined that the weather cases and combinations listed below result in the minimum clearance and control over all other weather conditions and combinations.
- Shield wires – Due to the fact that the OPGW wire is located above the phase wires, its clearance to the water surface will always exceed the minimum required NESC distance.
- F107 (115 kV): 285 degrees F – Max operating temperature (Phase wires) based on PSNH transmission standards - The maximum conductor sag for this weather case will be 22 feet with a clearance to the water surface of 57.1 feet. This condition produces the greatest sag in the phase wires and therefore the minimum clearance to the water surface. This design will exceed the minimum clearance requirement of 30.1 feet by 27 feet under temporary emergency conditions during a 10-yr storm event.
- F107 (115 kV): Minimum phase to shield wire(s) clearance – The weather case that would produce the minimum clearance between the phase wires and the shield wires would be a combination of winter weather factors. First, the phase wires would have to be at 30 deg. F just after an ice storm and would have just dropped their ice. The shield wires would be at 32 deg. F and would still be iced with 1/2” of radial ice. Under these conditions the clearance would be 12 feet vertically and 6 feet horizontally from the shield wires to the closest phase wire. As described in Paragraph 11 of the petition, 64.7 inches (5.4 feet) of horizontal and/or 32.3 inches (2.7 feet) of vertical clearance is required between 115kV and 0kV conductors. The line would exceed both clearance requirements.
- F107 and 380 (115kV and 34.5kV): Minimum 115kV phase conductor to 34.5kV phase conductor clearance – The weather case that would produce the minimum clearance between the 115kV phase

wires and the 34.5 kV phase wires would occur when the 34.5kV conductor is at 30 deg. F with no ice and the 115kV phase wires are at their maximum operating temperatures of 285 degrees F. Under these conditions the clearance would be 8.7 feet vertically and 1 foot horizontally from the shield wires to the closest phase wire. As described in Paragraph 11 of the petition, 70.7 inches (5.9 feet) of horizontal and/or 40.7 inches (3.4 feet) of vertical clearance is required between 115kV and 34.5kV conductors. The line design will meet these requirements as the conductors will exceed the vertical requirement by 5.8 feet under worst case conditions.

- 380 (34.5 kV): 212 degrees F – Max operating temperature (Phase wires) based on PSNH distribution standards - The maximum conductor sag for this weather case will be 24 feet with a clearance to the water surface of 36.7feet. This condition produces the greatest sag in the phase wires and therefore the minimum clearance to the water surface. This design will exceed the minimum clearance requirement of 28.5 feet by 8 feet under temporary emergency conditions during a 10-yr storm event.
- 380 (Neutral): 120 degrees F – Max operating temperature (Phase wires) based on PSNH distribution standards - The maximum conductor sag for this weather case will be 21 feet with a clearance to the water surface of 30.3 feet. This condition produces the greatest sag in the phase wires and therefore the minimum clearance to the water surface. This design will exceed the minimum clearance requirement of 25.5 feet by 4.8 feet under temporary emergency conditions during a 10-yr storm event.
- 380 (Neutral): Minimum phase to neutral clearance – Due to the fact that the 115kV phase conductors are located above the 34.5kV phase wires, its clearance to the neutral conductor will always exceed the minimum required NESC distance. The weather case that would produce the minimum clearance between the 34.5kV phase wires and the neutral wire would be a condition where the neutral conductor is at 80 deg. F and the 34.5kV conductors are at their maximum operating temperatures of 212 degrees F. Under these conditions the clearance of the closest 34.5kV line would be 1.5 feet vertically and 0 feet horizontally from the neutral wire to the closest phase wire. As described in Paragraph 11 of the petition, 59.8 inches (4.15 feet) of horizontal and/or 15.7 inches (1.3 feet) of vertical clearance is required between 34.5kV and 0kV conductors. The line design will meet these requirements as the conductors will exceed the vertical requirement by 0.2 feet under worst case conditions.

## **APPENDIX B**

### **F107 & 3850 Lines PICKERING BROOK NEWINGTON, NH**

1. The design and proposed construction of these crossings is shown on the attached PSNH Transmission Business Drawings entitled “SINGLE CKT F107 BETWEEN STR. 119 & 120 PICKERING BROOK, NEWINGTON, NEW HAMPSHIRE” (Drawing No. F10740903) marked as Exhibit 3 and “SINGLE CKT 3850 BETWEEN STR. 5 & 6 PICKERING BROOK, NEWINGTON, NEW HAMPSHIRE” (Drawing No. 385040901) marked as Exhibit 5.

2. The location of the single circuit F107 crossing is shown on the attached Location Plan marked as Exhibit 4. The location of the single circuit 3850 crossing is shown on the attached Location Plan marked as Exhibit 6.

3. Line F107 will cross the Pickering Brook on a 1-pole, direct embed, 100 foot pole (16 feet embedded), steel tangent suspension structure (eastern side) and on a 1-pole, 75 foot, steel deadend strain structure on concrete foundation (western side). Details of these structures are shown on Exhibit 3. As shown on Exhibit 3, for Structure 120 the 115kV phase wires have an approximate separation at the structure of 8 -15 feet vertically and 0-13 feet horizontally (6.5 foot post insulators) in a delta configuration. The static wire is carried on the structure by a support bracket approximately nine inches down from the top of the structure. As shown on Exhibit 3, for Structure 119 the 115kV phase wires have an approximate separation at the structure of 7 -15 feet vertically and 2.5-20 feet horizontally in a delta configuration. The static wire is carried on the structure by a support bracket approximately six inches down from the top of the structure. Land along the shoreline between the structures of this crossing and the river is not traversable by vehicles. However, minimum distances to ground per the NESC have been met. A clearance of 26.2 feet between the phase wire and the closest ground point has been provided. This exceeds the NESC required clearance of 20.1 feet by 6.1 feet. As all other phase wires are above this elevation they will always exceed the NESC required clearance.

4. Line 3850 will cross the Pickering Brook on a 1-pole, direct embed, 60 foot pole (eight feet embedded), wood deadend structure (western side) and on a 1-pole, direct embed 60 foot (eight feet embedded), wood tangent structure (eastern side). As shown on Exhibit 5, for Structure 5 the 34.5kV phase wires have an approximate separation at the structure of five feet vertically and 0-9 feet horizontally in a horizontal configuration. The neutral wire is carried on the structure by a support bracket approximately five feet down below the 34.5kV phase wires. As shown on Exhibit 5, for Structure 6 the 34.5kV phase wires have an approximate separation at the structure of four feet eight inches horizontally in a horizontal configuration. The neutral wire is carried on the structure by a support bracket approximately five feet down below the

34.5kV phase wires. All NESC clearances at the structure as described in paragraph 11 of the petition have been met by exceeding the horizontal and/or vertical clearances required. Land along the shoreline between the structures of this crossing and the river is not traversable by vehicles. However, minimum distances to ground per the NESC have been met. A clearance of 21 feet between the neutral and the closest ground point has been provided. This exceeds the NESC required clearance of 15.5 feet by 5.5 feet. As all other phase wires are above this elevation they will always exceed the NESC required clearance.

5. Flood water elevations for the Pickering Brook were based on information contained in flood insurance rate maps provided by FEMA. There was no flood elevation provided on the FEMA Maps as this portion of Pickering Brook is in the Zone X section of Map 33015C0255E, dated May 17, 2005. Zone X locations indicate that under a 100 year flood event the flood depth would be less than 1 foot. For conservative design it was assumed that the water level would not exceed the top of bank during a 10 year flood. The 10-year flood elevation for this portion of the river was designed at approximately 27.7 feet. This far exceeds the 1 foot depth prescribed on the FEMA flood map. The area of the crossing, as required by the NESC (Section 232), is approximately 9.9 acres (82 feet x 5280 feet/43560sf/acre). As stated in paragraph 10 of the petition, the minimum required 115 kV conductor clearance for water surface areas between under 20 acres is 22.1 feet for 115 kV and 20.5 feet for 34.5 kV.

6. The sags and clearances to the water surface during a 10-year flood event for this crossing are as follows;

- PSNH has investigated a multitude of weather and loading conditions for its design. PSNH used these design conditions and combinations thereof to determine the minimum clearance of all conductors to the water and land surfaces, between the phase conductors and OPGW cable and neutral conductors. PSNH has determined that the weather cases and combinations listed below results in the minimum clearance and control over all other weather conditions and combinations.
- Shield wires – Due to the fact that the OPGW wire is located above the phase wires, its clearance to the water surface will always exceed the minimum required NESC distance.
- F107 (115 kV): 285 degrees F – Max operating temperature (Phase wires) based on PSNH transmission standards - The maximum conductor sag for this weather case will be 18.4 feet with a clearance to the water surface of 34.1 feet. This condition produces the greatest sag in the phase wires and therefore the minimum clearance to the water surface. This design will exceed the minimum clearance requirement of 22.1 feet by 12 feet under temporary emergency conditions during a 10-yr storm event.

- F107 (115 kV): Minimum phase to shield wire(s) clearance – The weather case that would produce the minimum clearance between the phase wires and the shield wires would be a combination of winter weather factors. First, the phase wires would have to be at 30 deg. F just after an ice storm and would have just dropped their ice. The shield wires would be at 32 deg. F and would still be iced with 1/2” of radial ice. Under these conditions the clearance would be 13.5 feet vertically and 6 feet horizontally from the shield wires to the closest phase wire. As described in Paragraph 11 of the petition 64.7 inches (5.4 feet) of horizontal and/or 32.3 inches (2.7 feet) of vertical clearance is required between 115kV and 0kV conductors. The line would exceed both clearance requirements.
- 380 (34.5 kV): 212 degrees F – Max operating temperature (Phase wires) based on PSNH distribution standards - The maximum conductor sag for this weather case will be 22.1 feet with a clearance to the water surface of 31.9 feet. This condition produces the greatest sag in the phase wires and therefore the minimum clearance to the water surface. This design will exceed the minimum clearance requirement of 20.5 feet by 11.4 feet under temporary emergency conditions during a 10-yr storm event.
- 380 (Neutral): 120 degrees F – Max operating temperature (Phase wires) based on PSNH distribution standards - The maximum conductor sag for this weather case will be 19 feet with a clearance to the water surface of 23.5 feet. This condition produces the greatest sag in the phase wires and therefore the minimum clearance to the water surface. This design will exceed the minimum clearance requirement of 17.5 feet by 6 feet under temporary emergency conditions during a 10-yr storm event.
- 380 (Neutral): Minimum phase to neutral clearance – The weather case that would produce the minimum clearance between the 34.5kV phase wires and the neutral wire would be a condition where the neutral conductor is at 80 deg. F and the 34.5kV conductors are at their maximum operating temperatures of 212 degrees F. Under these conditions the clearance of the closest 34.5kV line would be 2.4 feet vertically and 0 feet horizontally from the neutral wire to the closest phase wire. As described in Paragraph 11 of the petition, 49.8 inches (4.15 feet) of horizontal and/or 15.7 inches (1.3 feet) of vertical clearance is required between 34.5kV and 0kV conductors. The line design will meet these requirements as the conductors will exceed the vertical requirement by 1.1 feet under worst case conditions.

## APPENDIX C

### **F107 Line Little Bay Durham, NH and Newington, NH**

1. The design and proposed construction of this crossing is shown on the attached PSNH Transmission Business Drawing entitled “F107 LINE CROSSING, LITTLE BAY DURHAM AND NEWINGTON, NEW HAMPSHIRE” (Drawing No. F10740905) marked as Exhibit 7.
2. The location of the F107 crossing of Little Bay is also shown on Exhibit 7.
3. Line F107 will cross Little Bay using three underground submarine cables. The three cables will be buried using a water jet plow, driver hand jetting or mechanical trenching. The submarine cable will begin at F107 Structure 101 on the West shore of Little Bay. This structure will be a single pole, 80 foot, steel deadend strain structure on concrete foundation. The cable will then run underwater to an underground manhole on the East shore of Little Bay. Details of Structure 101 are provided with the petition on Exhibit 7. As shown on Exhibit 7, for Structure 101 the overhead 115kV phase wires have an approximate separation at the structure of 6 to 12 feet vertically and 0 to 20 feet horizontally in a delta configuration. The static wire is carried on the structure by a support bracket approximately 9 inches down from the top of the structure on the left and right poles. The submarine cable will run down the pole at Structure 101 and be buried to a depth of 42 inches heading east for approximately 367 feet by open trenching or diver burial, one phase per pole, from the overhead conductor elevation. The cables will then proceed 1835 feet at 42 inch burial using a water jet plow. At that point the depth will be increased to 8 feet depth in the main channel for approximately 2431 feet. Continuing the Eastern path, the depth will decrease to 42 inches for the last 770 feet where the cable will come on shore and enter an underground splice vault. From that point the submarine cable will be spliced to a land based underground cable to connect to the above ground portion of the line at Structure 102. Details of the splice vault have been included on Exhibit 7. As shown on Exhibit 7 the cables will be installed 42 inches below finished grade and will be spaced a minimum of 18 inches apart vertically attached to the side of the manhole. All NESC clearances at the structure, as described in paragraph 11 of the petition, have been met by exceeding the horizontal and/or vertical clearances required. This crossing will be entirely underground or underwater so all overhead clearances described will not be applicable to this crossing.
4. The underwater crossing will consist of three 115kV rated, 1400 mm<sup>2</sup> XLPE submarine cables. The cable will have a copper wire core surrounded by extruded XLPE insulation. A layer of copper armoring will be installed on the outside of the cable to provide mechanical protection. The overall cable diameter will be approximately 140.2 mm. The cables will be installed with a separation of approximately 30 feet in the main channel of Little Bay. As they approach land they will converge to within 5 feet separation. Two ADSS fiber optic cables will be strapped to two separate cable (one

ADSS cable per conductor cable) to continue the fiber optic path for the F107 line. These cables will follow the same route as the 115kV conductors. There are four existing cables in the corridor that have been abandoned. Some of these cables may be raised to the surface, cut, capped and reset on the bottom to move them out of the way of the new cable installation.


5. The submarine cable will be buried between 42 inches and 96 inches depending on the location within the Little Bay. This will meet or exceed the NESC clearance of 42 inches based on Table 352-1 of the NESC for underground direct bury cable over 50kV. Section 351.C.5 of the NESC also states that “Submarine crossings should be routed, installed, or both, so they will be protected from erosion by tidal action or currents. They should not be located where ships normally anchor.” All three cables will be located in an existing cable crossing location as shown on the NOAA Navigational Chart for Little Bay and Great Bay attached to this petition as Exhibit 8. Per the NOAA Nautical Chart User’s Manual dated 1997 this designation includes restrictions on anchoring in the cable area. This satisfies the requirement of the NESC. The cables will also be buried to protect them from tidal action as well as any inadvertent boat anchors.

6. The underground vault will comply with all requirements of the NESC. As described in NESC Section 323.A, the underground vault will be designed for an HS-20 vehicle loading. Per NESC Section 323.B, the underground vault will have a vertical dimension not less than 6 feet and a minimum of 3 feet of working space and shall be accessible by two manholes with a minimum diameter of 26 inches.


08/2012

11/16/2015 3:04 PM - SFISHER - F10740901.DWG - F10740901


THIS PLAN FOR REFERENCE ONLY.  
NO REPRESENTATION OR WARRANTY IS  
MADE AS TO LOCATION OF  
BOUNDARIES OR OTHER POINTS OF  
REFERENCE. RIGHT OF WAY LOCATION  
HAS BEEN SURVEYED AND PROVIDED  
BY DOUCET SURVEY INC.




**PROFILE**  
SCALE: 1"=200' HORIZ.  
20' VERT.




**STRUCTURE 28**  
SINGLE POLE  
TYPE WT-1-UB



**STRUCTURE 29**  
SINGLE POLE  
TYPE SPDE-DAUB




D U R H A M, N. H.



PROPOSED 380/F107  
DOUBLE CIRCUIT 34.5kV/115kV

**PLAN VIEW**  
SCALE: 1"=200'



GRAPHIC SCALE  
1" = 200'

24 FIBER OPGW INSTALLED @ 4,500 LBS. NESC HVY. INITIAL  
1590 ACSR 45/7 INSTALLED @ 11,400 LBS. NESC HVY. INITIAL  
477 ACSR 18/1 INSTALLED @ 3,500 LBS. NESC HVY. INITIAL  
4/0 ACSR 6/1 INSTALLED @ 2,500 LBS. NESC HVY. INITIAL


NO.	REVISION	DATE	DRWN	CHKD	APPR
3	UPDATED F107 STRUCTURE NUMBERS	11/15	SCF	APJ	-
2	UPDATED ALIGNMENT HEIGHTS	8/15	SCF	APJ	-

 Public Service of New Hampshire A Northeast Utilities Company	TRANSMISSION BUSINESS		3	
			T	
DRAWN SCF	<b>DOUBLE CKT F107 &amp; 380</b> <b>BETWEEN STR. 28 &amp; 29</b> OYSTER RIVER, DURHAM, NEW HAMPSHIRE			
ENGINEER KMS				
CHECKED APJ				
APPROVED	SCALE AS NOTED	DATE 12/8/14	SHEET 1 OF 1	DRAWING NO. F10740901




THIS PLAN FOR REFERENCE ONLY.  
NO REPRESENTATION OR WARRANTY IS  
MADE AS TO LOCATION OF  
BOUNDARIES OR OTHER POINTS OF  
REFERENCE. RIGHT OF WAY LOCATION  
HAS BEEN SURVEYED AND PROVIDED  
BY DOUCET SURVEY INC.


NEWINGTON, N. H.





**PROFILE**  
SCALE: 1"=200' HORIZ.  
20' VERT.



STRUCTURE 119  
SINGLE POLE  
TYPE SPDE



STRUCTURE 120  
SINGLE POLE  
TYPE WT-2-SB



**PLAN VIEW**  
SCALE: 1"=200'

GRAPHIC SCALE  
1" = 200'

24 FIBER OPGW INSTALLED @ 4,500 LBS. NESC HVY. INITIAL  
1590 ACSR 45/7 INSTALLED @ 11,400 LBS. NESC HVY. INITIAL

NO.	REVISION	DATE	DRWN	CHKD	APPR
4	UPDATED F107 STRUCTURE NUMBERS	12/15	SCF	APJ	-
3	UPDATED 3850 & F107 STRUCTURE NUMBERS	11/15	SCF	APJ	-



<p><b>Public Service of New Hampshire</b> A Northeast Utilities Company</p>	TRANSMISSION BUSINESS		4
	SINGLE CKT F107 BETWEEN STR. 119 & 120		T
DRAWN SCF		PICKERING BROOK, NEWINGTON, NEW HAMPSHIRE	
ENGINEER KMS			
CHECKED APJ			
APPROVED -	SCALE AS NOTED	DATE 3/17/15	SHEET 1 OF 1
		DRAWING NO. F10740903	





				DRAWN		Public Service of New Hampshire		System Projects	
				SCF					
				DESIGNED		<b>LOCATION PLAN</b> <b>SINGLE CIRCUIT F107 LINE CROSSING</b> <b>PICKERING BROOK</b> <b>NEWINGTON, NEW HAMPSHIRE</b>			
				KMS					
				CHECKED					
				APJ					
				APPROVED		SCALE		DATE	
						1" = 1500'		3/17/15	
						SHEET		DRAWING NO.	
						1 of 1		F10740904	
1	UPDATED ALIGNMENT	8/7/15	SCF	APJ					
0	ISSUED FOR PERMITTING	4/10/15	SCF	APJ					
NO.	REVISION	DATE	DRWN	CHK	APPR				

THIS PLAN FOR REFERENCE ONLY. NO REPRESENTATION OR WARRANTY IS MADE AS TO LOCATION OF BOUNDARIES OR OTHER POINTS OF REFERENCE. RIGHT OF WAY LOCATION HAS BEEN SURVEYED AND PROVIDED BY DOUCET SURVEY INC.

NEWINGTON, N. H.




PROFILE  
SCALE: 1"=200' HORIZ.  
20' VERT.



477 ACSR 18/1 INSTALLED @ 3,500 LBS. NESC HVY. INITIAL  
4/0 ACSR 6/1 INSTALLED @ 2,500 LBS. NESC HVY. INITIAL

NO.	REVISION	DATE	DRWN	CHKD	APPR
2	UPDATED F107 STRUCTURE NUMBERS	12/15	SCF	APJ	-
1	UPDATED 3850 & F107 STRUCTURE NUMBERS	11/15	SCF	APJ	-



 Public Service of New Hampshire A Northeast Utilities Company	TRANSMISSION BUSINESS		2	
			T	
DRAWN SCF	SINGLE CKT 3850 BETWEEN STR. 5 & 6 PICKERING BROOK, NEWINGTON, NEW HAMPSHIRE			
ENGINEER KMS				
CHECKED APJ				
APPROVED	SCALE AS NOTED	DATE 8/4/15	SHEET 1 OF 1	DRAWING NO. 385040901




**PICKERING BROOK  
CROSSING**

				DRAWN <i>SCF</i>	Public Service of New Hampshire	System Projects			
				DESIGNED <i>KMS</i>	<b>LOCATION PLAN</b> <b>SINGLE CIRCUIT 3850 LINE CROSSING</b> <b>PICKERING BROOK</b> <b>NEWINGTON, NEW HAMPSHIRE</b>				
				CHECKED <i>APJ</i>					
				APPROVED					
0	ISSUED FOR PERMITTING	8/7/15	SCF	APJ	SCALE	DATE	SHEET	DRAWING NO.	
NO.	REVISION	DATE	DRWN	CHK	APPR	1" = 1500'	8/4/15	1 of 1	385040902


08/2012

1/8/2016 8:45 AM - ROLSEN - PSNH REV8ISSUE01-F10/40905 1-8-16.DWG - 11x17

# PLAN VIEW





THIS PLAN FOR REFERENCE ONLY. NO REPRESENTATION OR WARRANTY IS MADE AS TO LOCATION OF BOUNDARIES OR OTHER POINTS OF REFERENCE. RIGHT OF WAY LOCATION HAS BEEN SURVEYED AND PROVIDED BY DOUCET SURVEY INC.



Coordinate System  
State Plane, NAD 83  
2800 - New Hampshire, U.S. Feet  
Vertical Datum: MLLW





# PROFILE VIEW



General Notes

PROPOSED RE-ROUTE

- Magnetometer Hit
- Route Centerline:
- Trench Burial:
- Diver Burial:
- 8' Jet Plow Burial:
- 3' Jet Plow Burial:
- OOS Cable:
- OOS Cable To Be Removed:
- Cable Area:
- Easement Area:
- Mean High Water:




**Caldwell**  
Marine International, LLC.  
1433 Highway 34 South  
Building B  
Farmingdale, NJ 07727  
732.557.6100



 <b>Public Service of New Hampshire</b> A Northeast Utilities Company	TRANSMISSION BUSINESS		8
	F107 LINE CROSSING LITTLE BAY		
	DURHAM AND NEWINGTON, NEW HAMPSHIRE		
DRAWN	ENGINEER	CHECKED	APPROVED
SCALE AS NOTED	DATE 4/15/15	SHEET 1 OF 1	DRAWING NO. F10740905

NO.	REVISION	DATE	DRWN	CHKD	APPR
8	Rev. 08/Issue 01	1/16	-	-	-
7	Rev. 07/Issue 02	5/15	-	-	-



LOCATION OF CHARTED CABLE AREA. APPROXIMATELY 1000 FEET WIDE

EXHIBIT 8

PORTSMOUTH TO DOVER AND EXETER



UNITED STATES - EAST COAST MAINE - NEW HAMPSHIRE

Meridian Projection Scale 1:50,000 at Lat 43°00' North American Datum of 1983 (NAD 83) Soundings in Feet at Mean Lower Low Water

Table with columns for Tide, Mean High Water, Mean Lower Low Water, and Lowest Low Water.

Table with columns for Tide, Mean High Water, Mean Lower Low Water, and Lowest Low Water.

Table with columns for Tide, Mean High Water, Mean Lower Low Water, and Lowest Low Water.

Table with columns for Tide, Mean High Water, Mean Lower Low Water, and Lowest Low Water.

Table with columns for Tide, Mean High Water, Mean Lower Low Water, and Lowest Low Water.

Table with columns for Tide, Mean High Water, Mean Lower Low Water, and Lowest Low Water.