

**ENGINEERING DESIGN & OPERATIONAL SUMMARY**  
**DOCKHAM SHORES WATER IMPROVEMENTS**  
**PWS # 0882190**  
**GILFORD, NEW HAMPSHIRE**  
***April 2018***

The Dockham Shores PWS #0882190 is located on the northeasterly side of Route 11B in Gilford, NH. Dockham Shores is owned by Lakes Region Water Company of Moultonborough. The existing water facilities are being upgraded to current standards through the addition of a new water storage / pump house facility that will be located proximate to the existing two bedrock wells that provide water to this system.

This document describes the engineering and operation of water improvements at this PWS. The new Pump House facilities include a reinforced concrete 15,000-gallon water storage tank, Pump House building, booster pumps, automatic controls and related equipment. There is provision for water treatment, and for a standby generator.

The design of the improvements will operate automatically, with Wells operation based on tank levels. Booster pumps will be VFD controlled. There are two pre-charged pressure tanks that allow boosters to shut off during low flow conditions. Water use, based on NHPUC records shows average use within this 63 home community to be 6,900+/- gallons per day. A peak day calculated at 2.0 times = 13,800 gallons. The reported well pumping capacity from 2 onsite wells is 50 gpm and 60 gpm respectively. Wells 1 & 2 are located proximate to the new Pump House. Atmospheric Tank level will be used to start and stop the respective well pumps. A submersible level transducer will provide water level readings.

**New Pump House** - The water improvement project will include the construction of a new water pump house building on the site. A pre-cast reinforced concrete water storage tank will act as the building's foundation. The building is 11'4" W x 27'4" L x 8'0" H ceiling height. This is an insulated wood framed structure that uses manufactured roof trusses (80 psf snow load and 20 psf ceiling load), a painted plywood interior, Zip exterior sheathing with vinyl siding, and an insulated metal

access door. A Zip Roofing System, 25-year fiberglass / asphalt shingles will also be used. A Bilco, or equal, roof access hatch will allow access to the line-shaft turbine booster pumps. The reinforced concrete water storage tank has 8' floor to ceiling height, with an outside screened vent / overflow, and two access hatches located inside the Pump House. The tank acts at the frost wall foundation and floor slab. A floor drain will be located inside the station. The floor drain will have a rodent screen. A flood alarm will be part of the station.

**System Connection and Water Supplies** - The pump house will be connected into the existing 3" diameter water distribution system.

The water supply wells will each have individual 1" meters, check valves, pressure relief valves, sampling taps, 2.5" - 100 psi liquid filled pressure gauges and flushing valves to daylight. Provision has been made for future water treatment, if needed. An existing UV unit may be transferred from the existing pump house to be used in the new pump house.

**Master Water Meter and Controls** - The Pump House uses a 2" Badger M2000 master water meter measuring in gallons, a submersible tank level pressure transducer to supply water level data to start and stop well pumps. Smart Drives will be used to operate the 5 h.p. VFD water booster pumps, using input from a 0-100 psi WIKA discharge pressure transducer and the 2" master water meter. There will be 4.5" liquid filled pressure gauge (0 – 100 psi), twin 119-gallon pre-charged pressure tanks, sampling taps, and provision for emergency chlorination. There is also a high-level alarm, a low water warning and an emergency low water shut off for the booster pumps that will be connected into the GS-400 automatic monitoring / alarm system.

**Electrical Service, VFD Booster Pumps, Heat, Lights, Ventilation** - The station will use a new single phase 200 A/240-120 VAC, 1- phase electrical service. The Smart Drives area VFD's that create 3 phase power for the Booster Pumps. Well pumps will remain across the line start. Heat is provided from 2 – 3 KW electric heaters. There are 3 – 48" long, water resistant fluorescent lights, an automatic

ventilation fan, with motor operated air inlet vent that operates based on temperature rise.

Additional details are found on the Plan Set, and Data Sheets are included within the balance of this document.

**Pump House Automatic Operation** - The standard operation will be as follows, starting from the atmospheric tank being full, and the Pump House at 70-psi full system discharge pressure, with booster pumps "off":

1. As water is used in the system, the first water is supplied from the pre-charged pressure tanks. As pressure drops to 55 psi, the "lead" VFD booster pump starts and runs. As demand is met and pressure is restored with flow below 3 gpm for more than 60 seconds, this pump shuts off. The "lag" booster pump will start and run as "lead" during the next cycle. If water flow from the lead pump exceeds 60 gpm, the lag booster will start and run. If flow exceeds 80 gpm for 1 minute, a high flow alarm is sent. If the discharge pressure with one booster running drops to 50 psi, the lag booster will start and run until pressure is restored. If pressure drops to 35 psi, or is above 75 psi, either condition will activate an alarm. Alarm and booster starting and stopping pressures are operator adjustable on the Smart Drive. The boosters will have 2 minute minimum run times programmed. Pump speed will vary to maintain the set discharge pressure which will be 65+/- psi, with a 5 psi bump-up just before shutting off. The booster pumps are line-shaft submersible turbine pumps mounted inside the pump house. A roof hatch allows easy removal for maintenance.
2. As water is used in the system and the atmospheric tank drops from Full at 92" to 86", a well pump will start and run until the Full level is reached. If the level goes to 94" a highwater alarm will be activated. If the water level continues to drop to 80" the lag well pump will start and run until the tank is refilled. If the tank drops to 55" there will be a low water warning alarm activated. If the water continues to drop to 40", there is a second alarm and the booster pumps

will be automatically shut down to prevent pump damage. Alarm levels, and well starting and stopping level, are operator adjustable.

3. A GS-400, cell phone based, automated monitoring and alarm system will be included in the station. This system may be accessed through a secure web portal and will send alarm and status signals to responsible party's smart phone.

Following construction, commissioning, and start- up with NH-DWGB approval, as-Built Drawings and an IOM manual will be provided.

## Capital Improvements - Actual Costs &amp; Step Increase

## Preliminary Calculation of Revenue Requirement

Plant Additions/Retirements:

Plant Additions

	<u>Source / Pumping</u>	
302	Franchises	\$ 18,335
304.02	Structures & Improvements	173,677
307	Wells	4,905
310	Power Generation Equipment	26,170
311	Pumping Equipment	9,682
339	Miscellaneous Equipment	
	<u>Transimission and Distribution</u>	
330	Storage Tank	29,975
334	Meters	<u>7,002</u>
	Total Improvements	300,599

Plant Retirements	<u>87,614</u>
-------------------	---------------

Net Additions/Retirements	\$212,985
---------------------------	-----------

Add: Accum Depr on Retired Plant	87,614
Less: Accum Depr on New Plant	<u>(6,728)</u>

Net Plant	<u>\$293,871</u>
-----------	------------------

Plus: Working Capital	<u>0</u>
-----------------------	----------

Total Additional Rate Base	\$293,871
----------------------------	-----------

Rate of Return	<u>8.91%</u>
----------------	--------------

Additional Net Operating Income Required	<u>\$26,188</u>
--	-----------------

Increase in Depreciation Expense	13,456
----------------------------------	--------

Increase in Taxes other than Income - State	1,801
---	-------

Increase in Taxes other than Income - Town	4,370
--	-------

Increase in Federal Income and			
State Business Taxes	293,871	2.75%	<u>8,079</u>

Total Increase in Operating Expenses			<u>\$ 27,705</u>
--------------------------------------	--	--	------------------

Total Additional Revenue Required	\$53,894
-----------------------------------	----------

Revenue from Current Rates for the period 7/1/17 - 6/30/18	<u>38,035</u>
--	---------------

Total Revenue Required	<u>\$91,928</u>
------------------------	-----------------

Percentage Increase Required	<u>141.70%</u>
------------------------------	----------------

SPSt. Cyr  
12/3/2018

# Lakes Region Water Co., Inc. / Dockham Shores

SPS 2

## Capital Improvements - Actual Costs & Step Increase

### Cost Rate for Step Adjustment on Dockham Shores improvements

<u>Debt Holder</u>	<u>Amount</u>		<u>Interest Rate</u>		<u>Interest Expense</u>	<u>Amortization of Fin Costs</u>	<u>Total Interest</u>	<u>Cost Rate</u>	<u>Wght Avg Cost Rate</u>
CoBank	\$ 75,000	23.52%	5.45%	\$	4,088	\$ 917	\$ 5,004	6.67%	1.57%
LRWC	<u>243,934</u>	<u>76.48%</u>						9.60%	<u>7.34%</u>
Total Cost of Capital	<u>\$ 318,934</u>	<u>100.00%</u>							<u>8.91%</u>

Income Tax on Equity Component:	(1) <u>Weighted Cost</u>		(2) <u>Tax Multiplier</u>		(3) <u>Pre-Tax Cost</u>	(4) <u>Tax Gross-up ((3) - (1))</u>
Debt	1.57%	x	1	=	1.57%	0.00%
Equity	<u>7.34%</u>	x	1.3744	=	10.09%	<u>2.75%</u>
Total	<u>8.91%</u>					<u>2.75%</u>

SPSt. Cyr  
12/3/2018

**Capital Improvements - Actual Costs & Step Increase**

## EFFECTIVE TAX FACTOR

Taxable Income	100.00%
Less: NH Business Profits Tax	<u>-7.90%</u>
Federal Taxable Income	92.10%
Federal Income Tax Rate	x <u>21.00%</u>
Effective Federal Income Tax Rate	19.34%
Add: NH Business Profits Tax	<u>7.90%</u>
Effective Tax Rate	<u>27.24%</u>
Percent of Income Available if No Tax	<u>100.00%</u>
Less: Effective Tax Rate	<u>27.24%</u>
Percent Used as a Divisor in Determining Revenue Requirement	<u>72.76%</u>
Tax Multiplier (Effective Tax Rate ÷ Percent Used as a Divisor)	<u>0.3744</u>

SPSt. Cyr  
12/3/2018

## Capital Improvements - Actual Costs &amp; Step Increase

## Plant / Depreciation Expense / Accumulated Depreciation

<u>PUC</u> <u>Acct. No.</u>	<u>Description</u>	<u>Cost</u>	<u>Depr.</u> <u>Rate</u>	<u>Annual</u> <u>Cost</u>	<u>Accum</u> <u>Depr.</u>
	<u>Source / Pumping</u>				
302	Franchises	\$ 18,335	5.00%	\$ 917	\$ 458
304.02	Structures & Improvements	173,677	2.50%	4,342	2,171
307	Wells	4,905	3.30%	162	81
310	Power Generation Equipment	26,170	10.00%	2,617	1,309
311	Pumping Equipment	30,853	10.00%	3,085	1,543
339	Miscellaneous Equipment	9,682	14.29%	1,383	692
	<u>Transmission and Distribution</u>				
330	Storage Tank	29,975	2.00%	600	300
334	Meters	<u>7,002</u>	5.00%	<u>350</u>	<u>175</u>
	Total Improvements	<u>\$ 300,599</u>		<u>\$ 13,456</u>	<u>\$ 6,728</u>

SPSt. Cyr  
12/3/2018



## Capital Improvements - Actual Costs &amp; Step Increase

## Taxes

Total  
Projected  
CostsState Property Taxes on Wells and Pump Station Improvements

Total Project Costs	\$ 300,599
Accumulated Depreciation	(6,728)
Net Plant	\$ 293,871
Percent of Assessed Value to Net Plant	92.87%
Net Plant subject to State utility property taxes	\$ 272,931
Thousand Dollars of Assessed Value	\$ 273
Property Tax Rate	6.60
State Property Taxes	\$ 1,801

Town of Gilford Property Taxes

Total Project Costs	\$ 300,599
Accumulated Depreciation	(6,728)
Net Plant	\$ 293,871
Net Plant subject to Town of Gilford property taxes	100.00%
Thousand Dollars of Assessed Value	\$ 293,871
Thousand Dollars of Assessed Value	\$ 294
Property Tax Rate	14.87
Local Property Taxes	\$ 4,370

State Utility Property Taxes Percent	
12/31/16 Net Plant	\$ 3,864,253
Assessed value as of April 1, 2017	3,588,900
Percent of Assessed Value to Net Plant	92.87%

Town of Gilford Property Taxes Percent	
12/31/17 Net Plant	\$ 79,277
Assessed value as of ...	82,600
Percent of Assessed Value to Net Plant	104.19%

**Capital Improvements - Actual Costs & Step Increase**

Total Costs of Projects	\$ 318,934
-------------------------	------------

**Source of Funds:**

CoBank	\$ 75,000
LRWC	<u>243,934</u>
Total Source of Funds	\$ 318,934

**Use of Funds:**

Franchises	\$ 18,335
Financing/Step Adjustment	18,335
Pump Station & T&D Improvements	<u>\$ 282,264</u>
Total Use of Funds	\$ 318,934

SPSt. Cyr  
12/3/2018

**Capital Improvements - Actual Costs & Step Increase****Actual Franchise and Financing/Step Adjustment Costs**

Belknap County Registry of Deeds	\$ 75
CoBank *	3,000
Stephen P. St. Cyr & Associates *	3,257
Upton & Hatfield *	<u>30,338</u>
Total Franchises and Financing/Step Adjustment Costs	<u>\$ 36,670</u>

**Allocation of Franchises and Financing/Step Adjustment Costs:**

Franchises (50%)	\$ 18,335
Financing/Step Adjustment Costs	<u>18,335</u>
Total	<u>\$ 36,670</u>

Annual Amortization of Franchises	\$ 917
Annual Amortization of Financing/Step Increase	<u>917</u>
Total	<u>\$ 1,834</u>

SPSt. Cyr  
12/3/2018

# Lakes Region Water Co., Inc. / Dockham Shores

SPS-8

## Capital Improvements - Actual Costs & Step Increase

### Rates

#### Current Rates

	<u># of Customers</u>	<u>Base Rate</u>	<u>Revenue from Base Rate</u>
Base Rates	<u>61</u>	<u>\$ 165.08</u>	<u>\$ 10,070</u>
	<u>7/1/17 - 6/30/2018 Usage</u>	<u>Consumption Rate per 100 gallons</u>	<u>Revenue from Cons Rate</u>
Consumption Rate	<u>2,663,060</u>	<u>\$ 1.0501</u>	<u>\$ 27,965</u>
Total Revenue for 7/1/17 - 6/30/18			<u>\$ 38,035</u>

#### Proposed Rates

	<u># of Customers</u>	<u>Base Rate</u>	<u>Revenue from Base Rate</u>
Base Rates	<u>61</u>	<u>\$ 399.00</u>	<u>\$ 24,339</u>
	<u>7/1/17 - 6/30/2018 Usage</u>	<u>Consumption Rate per 100 gallons</u>	<u>Revenue from Cons Rate</u>
Consumption Rate	<u>2,663,060</u>	<u>\$ 2.5380</u>	<u>\$ 67,590</u>
Total Revenue for 7/1/17 - 6/30/18			<u>\$ 91,928</u>

Total Revenue Required	<u>\$ 91,928</u>
Less Proposed Revenue from Base Rate	<u>(24,339)</u>
Proposed Revenue from Consumption Rate	<u>\$ 67,590</u>
7/1/17 - 6/30/18 Usage	<u>2,663,060</u>
Proposed Consumption Rate per 100 gallons	<u>\$ 2.5380</u>

SPSt. Cyr  
12/3/2018