

ATTACHMENT WHS - 1

LIST OF UNIT OUTAGES AND SCHEDULED OUTAGE PERIODS

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
MERRIMACK 1 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
3/22	1621	3/26	0518	3.5	Planned Maintenance
6/22	1723	6/25	0334	2.4	Planned Maintenance
9/20	1619	9/24	0145	3.4	Planned Maintenance
TOTAL OUTAGE DOWN TIME				9.4	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
MERRIMACK 2 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
2/9	0740	2/13	0004	3.7	Superheater Tube Leak
4/17	1401	5/22	0017	34.4	Scheduled Maintenance Outage
5/22	1542	5/23	0032	0.4	Generator Voltage Swing / Phase Imbalance
5/23	1443	5/25	0622	1.7	Boiler Feed Pump
5/29	1707	6/1	1922	3.1	Economizer Tube Leak
6/2	0703	6/3	0604	1.0	ISO Transmission Constraint
9/24	1620	10/4	2153	10.2	Planned Maintenance / Feedwater Flow Nozzle
TOTAL OUTAGE DOWN TIME				54.4	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
MERRIMACK CT1 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
1/3	0815	1/3	1202	0.2	Other Fuel System Problems
1/9	1450	1/10	1430	1.0	Other Jet Engine Problems
2/10	0855	2/10	0902	0.0	Other Jet Engine Problems
3/6	0702	3/6	0733	0.0	Other Fuel System Problems
4/1	0400	4/11	1642	10.5	Other Fuel System Problems
5/11	0500	5/11	1800	0.5	Switchyard Transformers & Assoc. Cooling Sys.
6/7	1000	6/7	1210	0.1	Switchyard Protection Devices
7/29	0500	7/29	0729	0.1	Other Switchyard or High Voltage Sys Problems
10/20	0700	10/20	1726	0.4	Lube Oil System - General
11/10	0700	11/10	1415	0.3	Generator Bearings and Lube Oil System
TOTAL OUTAGE DOWN TIME				13.2	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
MERRIMACK CT2 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
1/3	0815	1/3	1202	0.2	Other Fuel System Problems
1/20	1745	1/20	1917	0.1	Other Gas Turbine Problems
4/1	0400	4/11	1519	10.5	Other Fuel System Problems
4/11	1520	4/14	1452	3.0	Miscellaneous Electrical Failures
5/11	0500	5/11	1800	0.5	Switchyard Transformers & Assoc. Cooling Sys.
6/7	1000	6/7	1210	0.1	Switchyard Protection Devices
TOTAL OUTAGE DOWN TIME				14.3	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
 NEWINGTON 1 - UNIT OUTAGE LIST
 JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
3/7	0000	3/7	0150	0.1	Boiler - Low Pressure Fuel Oil Trip Valve
3/31	0000	4/14	0645	14.3	Scheduled Maintenance Outage
8/1	1042	8/1	1433	0.2	Boiler - Low Drum Level
10/3	1730	10/4	0915	0.7	Burner Management System (BMS)
12/10	0701	12/10	0839	0.1	BMS - Auxiliary Air Damper Relay
TOTAL OUTAGE DOWN TIME				15.2	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
SCHILLER 4 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
1/20	0641	1/20	1930	0.5	Induced Fan Motor Leads
3/17	2308	3/18	0105	0.1	Burner Management System (BMS)
3/26	1014	3/30	1904	4.4	Superheater Tube Leak
4/25	0630	4/25	1405	0.3	Transformer Interruption
5/7	1011	5/7	1550	0.2	BMS - Faulty Draft Pressure Switch
7/10	0400	7/10	0425	0.0	Coal Pulverizer Pluggage
8/31	1055	8/31	1210	0.1	BMS - Boiler Feed Pump - Oil Pump
10/2	0320	10/5	1855	3.6	Generation Tube Leak
TOTAL OUTAGE DOWN TIME				9.3	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
SCHILLER 5 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
1/2	0442	1/13	0830	11.2	Boiler - Cyclone Vortex Finders
1/18	1125	1/19	1541	1.2	Throttle Valve Flange Leak
1/31	0206	1/31	0800	0.2	Loss of Fuel - Wood Supply
2/4	0610	2/4	0755	0.1	Wood Fuel Feeder Pluggage
2/9	1640	2/16	1250	6.8	Boiler - Bed Pluggage
2/18	1825	2/18	2125	0.1	Loss of Fuel - Wood Supply
2/18	2135	2/19	0058	0.1	Boiler - Low Steam Pressure
3/11	1045	3/11	1705	0.3	Wood Fuel Feeder Pluggage
3/12	0705	3/12	1125	0.2	High Cyclone Temperatures
3/18	2230	3/19	0250	0.2	Wood Feeder Chain Failure
4/11	1846	4/11	2105	0.1	Vibration - Forced Draft Fan
4/15	0435	4/22	2235	7.8	Scheduled Maintenance Outage
4/24	1111	4/24	1212	0.0	Boiler - Furnace Pressure
4/25	0630	4/26	0705	1.0	Transformer Interruption
4/26	1032	4/26	1710	0.3	480V Circuit Breaker Failure
5/22	0410	5/23	0650	1.1	Forced Draft Fan Silencer
6/22	2117	6/29	1335	6.7	Planned Maintenance
7/23	2050	7/27	1310	3.7	Boiler - Bed Material
9/3	1251	9/8	1015	4.9	Boiler - Bed Material
10/20	0737	11/5	2320	16.7	Scheduled Maintenance Outage
TOTAL OUTAGE DOWN TIME				62.6	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
SCHILLER 6 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
1/12	1043	1/16	0044	3.6	Generation Tube Leak
2/19	2141	2/22	0001	2.1	Generation Tube Leak
3/6	2155	4/12	1215	36.6	Scheduled Maintenance Outage
4/25	0630	4/25	2240	0.7	Transformer Interruption
4/29	1410	5/7	0130	7.5	Generation Tube Leak
5/8	1346	5/8	1435	0.0	Boiler Management System - Loss of Flame
6/6	1145	6/10	0855	3.9	Miscellaneous Tube Leaks
6/18	1123	6/20	1745	2.3	Superheater Tube Leak
9/3	0522	9/7	0253	3.9	Generation Tube Leak
TOTAL OUTAGE DOWN TIME				60.5	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
SCHILLER CT1 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
3/6	0733	3/6	1050	0.1	Loss of Gas Supply
4/2	1100	4/2	1714	0.3	Faulty Vibration Probe
4/9	0001	4/12	1447	3.6	Annual Inspection
6/14	0700	6/14	1300	0.3	Planned Maintenance
8/3	1358	8/3	1427	0.0	Miscellaneous Electrical Failures
9/7	1428	9/7	1534	0.0	Low Lube Oil Level
12/1	1639	12/3	0832	1.7	Speed Controller
12/13	1800	12/14	1005	0.7	Starting Sequence Difficulty
TOTAL OUTAGE DOWN TIME				6.7	

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
WYMAN 4 - UNIT OUTAGE LIST
JANUARY TO DECEMBER 2007

<u>OUTAGE</u> <u>DATE</u>	<u>START</u> <u>TIME</u>	<u>OUTAGE</u> <u>DATE</u>	<u>STOP</u> <u>TIME</u>	<u>DAYS</u>	<u>REASON</u>
1/17	2337	1/18	0000	0.0	Boiler Feed Pump Control
1/22	1652	1/22	1921	0.1	Boiler Feed Pump Control
1/28	0900	1/28	0925	0.0	Turbine Hydraulic Control
2/13	0500	2/13	0700	0.1	Fuel Oil Trip Valve Position Indication Relay
9/20	0437	9/20	0652	0.1	Boiler - Low Furnace Pressure Setpoint
11/5	0656	11/5	0830	0.1	Burner Valve Position Limit Switch
11/5	1534	11/5	1550	0.0	Loss of Power to Draft Fan Control
12/2	1026	12/2	1159	0.1	Loss of Flow Input to Fuel Oil Control System
12/18	1735	12/18	1800	0.0	Improper Feedwater Heater Operation
TOTAL OUTAGE DOWN TIME				0.5	

PSNH Hydro, White Lake and Lost Nation 2007 Outages

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Amoskeag	1	1/29/07 7:43	1/29/07 13:09	5.43	0.23	N	S	Annual Inspection
Amoskeag	1	2/23/07 9:23	2/23/07 13:17	3.90	0.16	N	S	Oil Change
Amoskeag	1	4/9/07 13:26	4/9/07 14:35	1.15	0.05	Y	S	UPS Installation
Amoskeag	1	4/11/07 6:00	4/11/07 6:33	0.55	0.02	Y	F	Line Fault
Amoskeag	1	7/23/07 7:00	7/27/07 12:53	101.88	4.25	N	S	Annual Inspection
Amoskeag	1	8/20/07 17:49	8/20/07 20:00	2.18	0.09	N	F	Relay failure
Amoskeag	1	9/29/07 5:00	9/30/07 21:26	40.43	1.68	N	S	S/S Maintenance
Amoskeag	2	1/30/07 13:02	2/2/07 12:43	71.68	2.99	N	S	Annual Inspection
Amoskeag	2	4/9/07 9:56	4/9/07 10:56	1.00	0.04	Y	S	UPS Installation
Amoskeag	2	4/11/07 6:00	4/11/07 6:33	0.55	0.02	Y	F	Line Fault
Amoskeag	2	6/11/07 13:24	6/11/07 13:34	0.17	0.01	Y	F	Pond Control Testing
Amoskeag	2	7/10/07 6:17	7/10/07 6:58	0.68	0.03	N	F	Low Oil Level
Amoskeag	2	7/15/07 14:17	7/15/07 14:45	0.47	0.02	N	F	Low Oil Level
Amoskeag	2	9/29/07 5:00	9/30/07 21:26	40.43	1.68	N	S	S/S Maintenance

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Amoskeag	3	2/5/07 9:09	2/8/07 13:12	76.05	3.17	N	S	Annual Inspection
Amoskeag	3	3/18/07 13:41	3/18/07 17:24	3.72	0.15	Y	F	Relay failure
Amoskeag	3	4/11/07 6:00	4/11/07 6:33	0.55	0.02	Y	F	Line Fault
Amoskeag	3	6/11/07 13:26	6/11/07 13:34	0.13	0.01	Y	F	Pond Control Testing
Amoskeag	3	6/21/07 14:10	6/21/07 14:18	0.13	0.01	Y	F	Pond Control Testing
Amoskeag	3	7/10/07 6:23	7/10/07 7:25	1.03	0.04	N	F	Relay failure
Amoskeag	3	9/29/07 5:00	9/30/07 21:26	40.43	1.68	Y	S	S/S Maintenance
Ayers	1	3/31/07 17:28	3/31/07 18:04	0.60	0.03	Y	F	Line Fault
Ayers	1	5/22/07 9:00	5/22/07 10:16	1.27	0.05	Y	F	Relay failure
Ayers	1	6/25/07 6:30	6/27/07 14:00	55.50	2.31	N	S	Annual Inspection
Ayers	1	10/1/07 7:00	10/5/07 21:00	110.00	4.58	N	S	S/S Maintenance
Ayers	1	10/7/07 12:38	10/7/07 14:00	1.37	0.06	N	F	High Oil Level
Ayers	2	3/31/07 17:28	3/31/07 17:47	0.32	0.01	Y	F	Line Fault
Ayers	2	5/23/07 18:46	5/23/07 19:51	1.08	0.05	Y	F	High bearing temp
Ayers	2	6/18/07 8:00	6/21/07 14:02	78.03	3.25	N	S	Annual Inspection
Ayers	2	10/1/07 7:00	10/5/07 21:00	110.00	4.58	N	S	S/S Maintenance

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Ayers	3	3/31/07 17:28	3/31/07 17:51	0.38	0.02	Y	F	Line Fault
Ayers	3	5/8/07 5:39	5/8/07 15:13	9.57	0.40	Y	F	Control System
Ayers	3	5/14/07 3:45	5/18/07 16:25	108.67	4.53	Y	S	Annual Inspection
Ayers	3	5/29/07 13:05	5/29/07 13:25	0.33	0.01	N	F	Incomplete start
Ayers	3	10/1/07 7:00	10/5/07 21:00	110.00	4.58	Y	S	S/S Maintenance
Ayers	3	10/27/07 17:02	10/27/07 18:17	1.25	0.05	Y	F	Incomplete start
Canaan	1	1/6/07 15:52	1/6/07 18:18	2.43	0.10	Y	F	Line Fault
Canaan	1	3/23/07 0:19	3/23/07 4:09	3.83	0.16	Y	F	Line Fault
Canaan	1	4/16/07 10:01	4/16/07 12:02	2.02	0.08	Y	F	Line Fault
Canaan	1	4/16/07 13:30	4/17/07 9:02	19.53	0.81	Y	F	Line Fault
Canaan	1	4/21/07 17:54	4/21/07 20:45	2.85	0.12	Y	F	Line Fault
Canaan	1	5/10/07 18:31	5/10/07 20:30	1.98	0.08	Y	F	Line Fault
Canaan	1	6/18/07 8:18	7/13/07 13:40	605.37	25.22	Y	S	Annual Inspection
Canaan	1	8/6/07 13:05	8/6/07 13:18	0.22	0.01	Y	F	Line Fault
Canaan	1	8/25/07 10:26	8/25/07 14:19	3.88	0.16	Y	F	Line Fault
Canaan	1	8/25/07 10:26	8/27/07 8:49	46.38	1.93	Y	F	Line Fault

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Canaan	1	9/27/07 15:42	9/27/07 16:58	1.27	0.05	Y	F	Line Fault
Eastman	1	1/6/07 2:56	1/6/07 7:18	4.37	0.18	Y	F	Unit tripped after phasing
Eastman	1	1/17/07 0:08	1/17/07 1:35	1.45	0.06	Y	F	Incomplete start
Eastman	1	2/7/07 15:36	2/7/07 15:42	0.10	0.00	Y	F	Low bearing cooling water flow
Eastman	1	2/21/07 20:08	2/21/07 21:00	0.87	0.04	N	F	High Sump Alarm
Eastman	1	5/14/07 9:43	5/14/07 14:50	5.12	0.21	Y	F	Incomplete start
Eastman	1	5/25/07 17:38	5/25/07 19:33	1.92	0.08	N	F	Overspeed
Eastman	1	7/23/07 8:20	8/13/07 10:37	506.28	21.10	N	S	Annual Inspection
Eastman	1	9/16/07 5:00	9/16/07 6:00	1.00	0.04	N	F	Incomplete start
Eastman	2	2/7/07 9:26	2/7/07 16:24	6.97	0.29	N	S	Oil Change
Eastman	2	2/19/07 23:07	2/20/07 11:05	11.97	0.50	N	F	High Oil Level
Eastman	2	2/28/07 10:28	3/1/07 15:00	28.53	1.19	N	S	Control System
Eastman	2	3/15/07 6:17	3/15/07 7:40	1.38	0.06	Y	F	Incomplete start
Eastman	2	3/16/07 11:47	3/16/07 13:26	1.65	0.07	Y	F	Control System
Eastman	2	3/17/07 16:07	3/17/07 17:40	1.55	0.06	Y	F	Control System
Eastman	2	3/17/07 20:50	3/17/07 21:30	0.67	0.03	Y	F	Control System

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Eastman	2	4/3/07 12:15	4/3/07 14:35	2.33	0.10	Y	S	Oil Change
Eastman	2	4/5/07 2:00	4/5/07 5:26	3.43	0.14	Y	F	Low Oil Pressure
Eastman	2	4/10/07 11:07	4/10/07 12:20	1.22	0.05	N	F	Control System
Eastman	2	5/31/07 20:26	5/31/07 22:13	1.78	0.07	N	F	Line Fault
Eastman	2	6/5/07 13:17	6/5/07 17:01	3.73	0.16	Y	F	Line Fault
Eastman	2	7/15/07 14:39	7/15/07 16:00	1.35	0.06	N	F	Line Fault
Eastman	2	8/7/07 20:16	8/7/07 22:29	2.22	0.09	N	F	Incomplete start
Eastman	2	9/17/07 7:00	9/25/07 11:30	196.50	8.19	N	S	Annual Inspection
Eastman	2	11/26/07 12:43	11/26/07 15:43	3.00	0.13	Y	F	High Oil Level
Garvins	1	1/1/07 0:00	1/16/07 14:14	374.23	15.59	Y	S	Carryover from 06
Garvins	1	1/16/07 14:15	1/16/07 17:11	2.93	0.12	Y	F	Oil Leak
Garvins	1	1/19/07 9:25	1/19/07 9:34	0.15	0.01	Y	F	Low Oil Pressure
Garvins	1	4/16/07 7:48	4/16/07 8:20	0.53	0.02	Y	F	Line Fault
Garvins	1	5/21/07 15:18	5/21/07 16:58	1.67	0.07	Y	F	Low Oil Pressure
Garvins	1	5/22/07 8:47	5/22/07 9:37	0.83	0.03	Y	F	Low Oil Pressure
Garvins	1	10/13/07 23:00	10/14/07 0:40	1.67	0.07	N	F	Incomplete start

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Garvins	1	10/20/07 7:19	10/21/07 17:50	34.52	1.44	Y	S	S/S Maintenance
Garvins	2	1/6/07 10:23	1/6/07 12:04	1.68	0.07	Y	S	Annual Inspection
Garvins	2	1/16/07 12:43	1/16/07 14:25	1.70	0.07	Y	S	Annual Inspection
Garvins	2	3/13/07 7:52	3/13/07 14:24	6.53	0.27	N	S	Inspection
Garvins	2	10/20/07 7:19	10/21/07 17:37	34.30	1.43	Y	S	S/S Maintenance
Garvins	2	12/24/07 10:45	12/24/07 11:25	0.67	0.03	N	F	Incomplete start
Garvins	3	6/11/07 0:00	6/15/07 12:42	108.70	4.53	N	S	Annual Inspection
Garvins	3	6/17/07 10:59	6/17/07 12:45	1.77	0.07	N	F	High bearing temp
Garvins	3	6/27/07 18:43	6/27/07 20:23	1.67	0.07	N	F	High bearing temp
Garvins	3	7/13/07 23:03	7/14/07 8:14	9.18	0.38	N	F	Control System
Garvins	3	10/20/07 7:19	10/21/07 17:20	34.02	1.42	Y	S	S/S Maintenance
Garvins	4	2/22/07 9:00	2/22/07 11:00	2.00	0.08	N	S	High Oil Level
Garvins	4	2/28/07 12:13	2/28/07 14:30	2.28	0.10	Y	F	Line Fault
Garvins	4	3/5/07 7:13	3/5/07 17:52	10.65	0.44	Y	S	Line Fault
Garvins	4	7/16/07 8:00	7/20/07 11:34	99.57	4.15	N	S	Annual Inspection
Garvins	4	10/20/07 7:19	10/21/07 17:23	34.07	1.42	Y	S	S/S Maintenance

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Gorham	1	1/27/07 3:50	1/28/07 6:39	26.82	1.12	N	F	Low flow
Gorham	1	10/15/07 7:59	10/19/07 13:33	101.57	4.23	N	S	Annual Inspection
Gorham	1	10/22/07 7:53	10/26/07 17:09	105.27	4.39	Y	S	S/S Maintenance
Gorham	1	11/20/07 9:47	11/20/07 13:53	4.10	0.17	Y	S	S/S Maintenance
Gorham	2	10/15/07 7:59	10/19/07 13:34	101.58	4.23	Y	S	Annual Inspection
Gorham	2	10/22/07 7:53	10/26/07 17:09	105.27	4.39	Y	S	S/S Maintenance
Gorham	2	11/20/07 9:47	11/20/07 13:58	4.18	0.17	Y	S	S/S Maintenance
Gorham	3	1/8/07 7:30	1/8/07 10:15	2.75	0.11	Y	F	Control System
Gorham	3	7/23/07 7:00	8/9/07 11:57	412.95	17.21	N	S	Annual Inspection
Gorham	3	10/22/07 7:53	10/26/07 17:10	105.28	4.39	Y	S	S/S Maintenance
Gorham	3	11/20/07 9:48	11/20/07 14:00	4.20	0.18	Y	S	S/S Maintenance
Gorham	4	8/27/07 7:46	8/29/07 14:15	54.48	2.27	N	S	Annual Inspection
Gorham	4	10/22/07 7:53	10/26/07 17:10	105.28	4.39	Y	S	S/S Maintenance
Gorham	4	11/20/07 9:47	11/20/07 14:08	4.35	0.18	Y	S	S/S Maintenance
Hooksett	1	2/28/07 12:13	2/28/07 12:56	0.72	0.03	Y	F	Line Fault
Hooksett	1	4/5/07 3:12	4/5/07 4:12	1.00	0.04	Y	F	Line Fault

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Hooksett	1	7/15/07 16:46	7/15/07 18:18	1.53	0.06	Y	F	Line Fault
Hooksett	1	8/6/07 7:00	12/7/07 15:00	2960.00	123.33	I	S	Major Overhaul
Hooksett	1	12/13/07 13:13	12/13/07 13:42	0.48	0.02	Y	F	Testing
Jackman	1	4/5/07 0:44	4/5/07 1:47	1.05	0.04	Y	F	Line Fault
Jackman	1	4/5/07 2:40	4/5/07 2:45	0.08	0.00	Y	F	Line Fault
Jackman	1	4/5/07 3:12	4/5/07 4:12	1.00	0.04	Y	F	Line Fault
Jackman	1	4/5/07 5:30	4/5/07 5:35	0.08	0.00	Y	F	Line Fault
Jackman	1	4/5/07 5:50	4/5/07 5:55	0.08	0.00	Y	F	Line Fault
Jackman	1	4/5/07 6:32	4/5/07 7:20	0.80	0.03	Y	F	Line Fault
Jackman	1	4/5/07 8:50	4/5/07 8:59	0.15	0.01	Y	F	Line Fault
Jackman	1	6/2/07 17:11	6/2/07 18:37	1.43	0.06	Y	F	Line Fault
Jackman	1	6/11/07 17:20	6/11/07 18:42	1.37	0.06	Y	F	Line Fault
Jackman	1	8/20/07 7:00	10/31/07 16:00	1737.00	72.38	N	S	Annual Inspection
Jackman	1	11/2/07 11:50	11/2/07 11:54	0.07	0.00	Y	F	High bearing temp
Jackman	1	11/8/07 9:44	11/19/07 15:49	270.08	11.25	Y	F	High bearing temp
Jackman	1	11/29/07 14:52	11/29/07 16:15	1.38	0.06	Y	S	Testing

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
Jackman	1	11/30/07 9:14	11/30/07 11:20	2.10	0.09	Y	F	Relay operation
Jackman	1	12/20/07 13:30	12/29/07 8:00	210.50	8.77	N	F	High bearing temp
Lost Nation	1	1/18/07 7:19	1/18/07 8:43	1.40	0.06	N/A	F	Control System
Lost Nation	1	1/20/07 17:06	1/29/07 13:19	212.22	8.84	N/A	F	Low fuel oil pressure
Lost Nation	1	3/6/07 7:01	3/6/07 8:01	1.00	0.04	N/A	F	Incomplete start
Lost Nation	1	5/7/07 8:00	5/11/07 23:59	111.98	4.67	N/A	S	Annual Inspection
Lost Nation	1	5/12/07 0:00	5/21/07 13:04	229.07	9.54	N/A	F	Annual Inspection
Smith	1	1/8/07 8:45	1/8/07 20:17	11.53	0.48	Y	S	Testing
Smith	1	1/9/07 9:44	1/9/07 10:41	0.95	0.04	Y	S	Testing
Smith	1	1/10/07 10:23	1/10/07 14:00	3.62	0.15	Y	S	Testing
Smith	1	1/12/07 8:27	1/12/07 12:48	4.35	0.18	Y	S	Testing
Smith	1	4/11/07 11:21	4/11/07 11:40	0.32	0.01	Y	S	Testing
Smith	1	9/22/07 7:07	9/29/07 11:12	172.08	7.17	Y	S	S/S Maintenance
Smith	1	10/17/07 6:10	10/18/07 15:06	32.93	1.37	Y	S	S/S Maintenance
White Lake	1	1/25/07 10:00	1/25/07 18:30	8.50	0.35	N/A	F	Incomplete start
White Lake	1	2/20/07 8:00	2/22/07 16:15	56.25	2.34	N/A	S	Annual Inspection

Site	Unit Number	Date & Time OFF line	Date & Time ON line	Outage Duration - Hours	Outage Duration, Days	Water Available for unit? (Y or N)	Forced (F) or Scheduled (S)?	Cause of Outage
White Lake	1	6/2/07 12:31	6/2/07 21:30	8.98	0.37	N/A	F	Vibration Alarm
White Lake	1	8/7/07 8:00	8/7/07 14:30	6.50	0.27	N/A	S	Testing
White Lake	1	8/25/07 20:45	8/25/07 21:40	0.92	0.04	N/A	F	Line Fault
White Lake	1	10/8/07 0:00	11/17/07 19:15	979.25	40.80	N/A	S	New Equip Installation
White Lake	1	12/1/07 16:30	12/1/07 18:30	2.00	0.08	N/A	F	Incomplete start
White Lake	1	12/13/07 17:00	12/13/07 19:30	2.50	0.10	N/A	F	Incomplete start