

2nd 2012 Quarter Summary		Todays Date 6-Aug-12		
Source Name	Emission Report Date (electronic)	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu
PT Tamworth	20-Jul-12	0.067	16-Jun-11	0.003
PT Bethlehem	6-Jul-12	0.073	12-Jun-12	0.0012
PSNH SR5	25-Jul-12	0.063	1-Jun-11	0.0029
Indeck Energy	17-Jul-12	0.072	30-Jun-11	0.01
Springfield Power	28-Jul-12	0.066	6/17/2011	0.034
Berlin			not operating	unknown