

RPS Emission Verification Summary

NOx lb/mmbtu | 0.075 lb/mmbtu

TSP lb/mmbtu limit | 0.02 lb/mmbtu

RENEWABLE PORTFOLIO STANDARDS

1st 2013 Quarter Summary			
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu
PT Tamworth	0.067	13-Jun-12	0.003
PT Bethlehem	0.072	12-Jun-12 3-year test frequency approved by DES	0.001
PSNH SR5	0.067	1-Jun-11 3-year test frequency approved by DES	0.0029
Indeck Energy	0.069	19-Jun-12	0.007
Springfield Power		6/20/2012	0.028 0.03
Berlin			