

RPS Emission Verification Summary

3rd 2013 Quarter Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth	0.068	22-May-13	0.007	
PT Bethlehem	0.071	17-May-13 3-year test frequency approved by DES	0.003	
PSNH SR5	0.068	1-Jun-11 3-year test frequency approved by DES	0.0029	
Indeck Energy	0.072	24-May-13	0.003	
Springfield Power	0.06	16-May-13	0.02	
Berlin	[REDACTED]	[REDACTED]	[REDACTED]	
AVH	[REDACTED]	[REDACTED]	[REDACTED]	