



1st Quarter 2015 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth 300019	0.07	May-14	0.004	
PT Bethlehem 900026	0.072	May-14 3-year test frequency approved by DES	0.002	
PT Fitchburg	0.057	19-Jun-14	0.013	
PSNH SR5 1500012	0.069	May-14 3-year test frequency approved by DES	0.0057	
Indeck Energy 900029	0.072	May-14	0.004	
Springfield Power 1900031	0.064	May-14	0.02	
Berlin 790137	0.064	10-Jun-14	0.0034	
Bridgewater Power 900021	0.063		n/a under Alternative Plan	
Ryegate	0.070	Nov-14	0.0007	
Thermal Sources	99% CE	maximum allowed	0.1 lb/mmbtu	
Sullivan County Complex	annual tune-up & CE test	 1-time test		
Conway Memorial	annual tune-up & CE test	 1-time test		
Littleton Regional Healthcare	99.99% CE annual tune-up & CE test	17-Mar-14 boiler #1	0.056	
		18-Mar-14 boiler #2	0.032	
Warwick Mills	99.89% CE annual tune-up & CE test	1-time test 30-Sep-14 1-Oct-14	0.018	
AVH	99.99% CE annual tune-up & CE test	4-Jun-14 1-time test	0.067	