

HYDRO MANAGEMENT GROUP, LLC

C/O ESSEX HYDRO ASSOCIATES, LLC
55 UNION STREET, 4TH FL
BOSTON, MA 02108

TELEPHONE:
E-MAIL:

617-367-0032
al@essexhydro.com

July 26, 2013

Ms. Debra A. Howland
Executive Director and Secretary
State of New Hampshire
Public Utilities Commission
21 S. Fruit Street, Suite 10
Concord, NH 03301-2429

NHPUC 29JUL'13PM2:47

Re: DE 12-210, Spaulding Ave Industrial Complex, LLC's Application for Additional Class I Eligibility for Renewable Energy Certificates ("REC"s) for the Spaulding Pond Hydroelectric Facility, Pursuant to RSA 362-F.

Dear Executive Director Howland,

On July 2, 2013 Hydro Management Group, LLC ("HMG"), as REC aggregator for Spaulding Ave Industrial Complex, LLC ("Spaulding"), was notified, under DE 12-210, that NH PUC Commission Staff had reviewed Spaulding Pond Hydro's application for recognition of the behind-the-meter electricity as a Class I NH RPS resource and had additional questions for clarification. As such, please find the Staff's questions below with the requested answers from Mr. Tom Cusano, the sole member and operating manager of Spaulding Ave Industrial Complex, LLC, owner and operator of the Spaulding Pond Hydroelectric facility.

- 1) *Please confirm that all tenants at the Spaulding Ave Industrial Complex receive electric service on the customer side of the PSNH retail revenue meter. If unable to confirm, please explain.*

Answer: There is one meter for the entire property that is a bi-directional meter located on a utility pole at the street. All tenants are on the customer side of the meter.

- 2) *Please confirm that non of the tenants receiving electric service behind-the-meter at the Spaulding Ave Industrial Complex is a separately-metered retail customer of PSNH or any electric supplier other than Spaulding Ave Industrial Complex, LLC. If unable to confirm, please explain.*

Answer: None of the tenants receiving electric service at the Spaulding Ave Industrial Complex is a separately-metered customer of PSNH or any electric supplier other than the Spaulding Ave Industrial Complex.

3) *Please confirm that all lines providing electric service to tenants at the Spaulding Ave Industrial Complex are owned by Spaulding Ave Industrial Complex, LLC and not by PSNH or any other persons, firm or entity. If unable to confirm, please explain.*

Answer: All lines are owned by Spaulding Ave Industrial Complex. See attached Exhibit 1.

4) *Please confirm that none of the lines providing electric service to tenants at the Spaulding Ave Industrial Complex crosses a public street or right-of-way or other public land. If unable to confirm, please explain.*

Answer: None of the lines providing service to tenants crosses a public street, right-of-way, or other public land.

4) *Please describe in detail the metering configuration for the behind-the-meter electric generation and usage at the Spaulding Ave Industrial Complex and provide a drawing or diagram illustrating this metering configuration.*

Answer: See attached Exhibit 2 for a diagram.

5) *Please describe in detail how these meters will be monitored and read in order to determine and report the behind-the-meter electric generation and usage at the Spaulding Ave Industrial Complex, net of any generation station service or parasitic load of the hydroelectric plant.*

Answer: Mr. William P. Short III, a qualified independent monitor in the State of New Hampshire will be responsible for entering the behind-the-meter RECs into the GIS. Mr. Short will be paid a flat fee for his services, independent of how many RECs the Spaulding Pond facility produces. Please see Exhibit 3 for an explanation from Mr. Short regarding how the meter will be monitored and read in order to report the behind-the-meter electric generation and usage at the Spaulding Ave Industrial Complex, net of any generation station service or parasitic load of the hydroelectric plant.

An electronic copy of this filing was emailed to you at executive.director@puc.nh.gov and Barbara Bernstein at barbara.bernstein@puc.nh.gov on Friday July 26th and three hard copies were delivered to your attention at the New Hampshire PUC on Monday July 29, 2013. Please feel free to contact me at 617-367-0032 or al@essexhydro.com with any questions.

Sincerely,

Spaulding Ave. Industrial Complex, LLC
by Hydro Management Group, LLC, its agent
as aggregator


Andrew Locke
Vice President