

**WES Energy & Environment, LLC**

902 Market Street      520 Wyndham Lane  
Meadville, PA 16335      Waxhaw, NC 28173  
(814) 336-1284      (704) 256-7066

---



March 7, 2016

NHPUC 10MAR'16PM12:21

Deborah A. Howland  
Executive Director  
New Hampshire Public Utilities Commission  
21 South Fruit Street, Suite 10  
Concord, NH 03301-2429

**Re: DE 14-301 - Mascoma Valley Regional High School Thermal REC Revised Application**

Dear Ms. Howland,

Mascoma Valley Regional School District's (MVRSD) biomass facility (Docket # 14-301) was approved as a 0.24 MW equivalent facility for generating Class I Thermal RECs effective as of February 27, 2015. The facility originally installed three (3) of the Froling P4 Model 80/100 boilers. The Froling P4 Model 80/100 can be configured as either an 80 kW or a 100 kW boiler, and it has come to our attention that the capacity of each of these boilers as installed is 100 kW and not the 80 kW that was originally listed in the application to the PUC. Thus, we respectfully request a modification to this facility's approval to increase the size of the facility from 0.24 MW to 0.3 MW retroactive to February 27, 2015.

WESEE thanks the PUC staff for all their efforts in making the Thermal RECs in NH a reality. Please do not hesitate to call either MVRSD or WESEE with any questions or clarifications on this matter.

Sincerely,

WES Energy & Environment, LLC

A handwritten signature in blue ink, appearing to read 'D. Wilson', is written over a horizontal line.

Daniel A. Wilson  
Vice President

**Attachments:**

- None