

1st Quarter 2016 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #MMBTU Quarter Average	TSP Test Date	TSP Emission Average #mmbtu	
PT Tamworth 300019	0.065	May-15	0.005	
PT Bethlehem 900026	0.068	Jun-15 3-year test frequency approved by DES	0.002	
PT Fitchburg	0.064	May-15	0.008	
PSNH SR5 1500012	0.069	May-14 3-year test frequency approved by DES	0.0057	
Indeck Energy 900029	0.073	May-15	0.002	
Springfield Power 1900031		Jun-15	0.037 ineligible	
Berlin 790137	0.058	26-Jun-15	0.0014	
Bridgewater Power 900021	0.068		n/a under Alternative Plan	
Ryegate	0.069	Jun-15	0.0007	
Thermal Sources	99% CE	maximum allowed	0.1 lb/mmbtu	
Sullivan County Complex	annual tune-up & CE test	1-time test	pending	
Conway Memorial	99.999%	9-Sep-15	boiler #1	0.081
	99.993%	10-Sep-15	boiler #2	0.095
	annual tune-up & CE test	1-time test	quarterly reporting of <90% capacity required	
Grafton County Complex	annual tune-up & CE test	1-time test	pending	
State Office Park East	annual tune-up & CE test	1-time test	pending	
City of Claremont	annual tune-up & CE test	1-time test	pending	
Holderness School	99.998% annual tune-up & CE test	1-time test	15-Dec-15	0.0075 quarterly reporting of <90% capacity required
EMD Millipore	99.95% CE annual tune-up & CE test	1-time test	13-Mar-15	0.009
Littleton Regional Healthcare	99.99% CE annual tune-up & CE test	1-time test	17-Mar-14	boiler #1 0.056
		1-time test	18-Mar-14	boiler #2 0.032
Warwick Mills	99.89% CE annual tune-up & CE test	1-time test	30-Sep-14 1-Oct-14	0.018
AVH	99.99% CE annual tune-up & CE test	1-time test	4-Jun-14	0.067