

4th Quarter 2016 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth 300019	0.073	Jul-16	0.001	
PT Bethlehem 900026	0.069	Jun-16 3-year test frequency approved by DES	0.001	
PT Fitchburg	0.063	Jun-16	0.004	
PSNH SR5 1500012	0.068	May-14 3-year test frequency approved by DES	0.0057	
Indeck Energy 900029	0.074	Jun-16	0.002	
Springfield Power 1900031		Jun-16	0.094 ineligible	
Berlin 790137	0.057	16-Jun-16	0.0065	
Bridgewater Power 900021	0.069		n/a under Alternative Plan	
Ryegate	0.073	Jun-16	0.0002	
Thermal Sources	99% CE	maximum allowed	0.1 lb/mmbtu	
Sullivan County Complex	annual tune-up & CE test	1-time test	pending	
Conway Memorial 300006	99.999% 99.993% annual tune-up & CE test	1-time test	9-Sep-15 10-Sep-15	boiler #1 0.081 boiler #2 0.095 quarterly reporting of <90% capacity required
Grafton County Complex	annual tune-up & CE test	1-time test	pending	
Froling Energy	annual tune-up & CE test	1-time test	pending	
State Office Park East	annual tune-up & CE test	1-time test	chose not to apply	
City of Claremont	annual tune-up & CE test	1-time test	pending	
Holderness School 900137	99.998% annual tune-up & CE test	1-time test	15-Dec-15	0.0075 quarterly reporting of <90% capacity required
EMD Millipore 500056	99.95% CE annual tune-up & CE test	1-time test	13-Mar-15	0.009
Littleton Regional Healthcare 990224	99.99% CE annual tune-up & CE test	1-time test	17-Mar-14 18-Mar-14	boiler #1 0.056 boiler #2 0.032
Warwick Mills 110129	99.89% CE annual tune-up & CE test	1-time test	30-Sep-14 1-Oct-14	0.018
AVH 7007	99.99% CE annual tune-up & CE test	1-time test	4-Jun-14	0.067