

Sanborn, Head & Associates, Inc.
1 Technology Park Drive
Westford, MA 01886
978-392-0900

LETTER OF TRANSMITTAL

To: Bill Clark
William.Clark@libertyutilities.com

Number: 3672.00-002
Date: August 31, 2015
Job #: 3672.00

Via: ☐ Overnight
☐ Regular Mail
☐ Hand Delivery
☐ FAX (# of Pages)
☒ Electronically
☐ Other:

Telephone No.:

Fax No.:

WE ARE SENDING YOU:

☒ Attached ☐ Under Separate Cover

☐ Copy of Report ☐ Prints ☐ Plans ☐ Samples ☐ Specifications
☐ Copy of Letter ☐ Change Order ☒ See below

COPIES	DOCUMENT NUMBER	DATE	REVISION	DESCRIPTION
1	-	8/31/15	-	Lebanon Site Fatal Flaw Siting Analysis Memo
1	-	8/12/15	-	Preliminary Design Basis
1	3672.00, G-1	8/31/15	0	Location Plan
1	3672.00, G-2	8/31/15	0	Site Plan
1	3672.00, G-3	8/31/15	0	Site Plan - Flood Plains
1	3672.00, G-4	8/31/15	0	Equipment General Arrangement
1	-	8/31/15	-	LNGFire3 Modeling Output

THESE ARE TRANSMITTED (As Checked Below):

☐ For Approval ☐ Approved as Submitted ☐ Resubmit _____ Copies for Approval
☒ For Your Use ☐ Approved as Noted ☐ Submit _____ Copies for Distribution
☐ As Requested ☐ Returned for Corrections ☐ Return _____ Corrected Prints
☐ For Review & Comment ☐ PRINTS RETURNED AFTER LOAN TO US
☐ FOR BIDS DUE _____

Remarks:

cc: JMF
MAN
CJF
file

SANBORN, HEAD & ASSOCIATES, INC.

Tom Sudol
Project Manager

(IF ENCLOSURES ARE NOT AS NOTED, PLEASE NOTIFY US IMMEDIATELY)



MEMORANDUM

To: Bill Clark | Liberty Utilities
From: Joan Fontaine and Mike Nicoloro
File: 3672.00
Date: August 31, 2015
Re: LNG Facility Fatal Flaw Siting Analysis for West Lebanon, NH Parcel – Initial Phase
cc: Tom Sudol, Maxwell Quinn | Sanborn Head

Project Overview

Liberty Utilities is evaluating a parcel of land in West Lebanon, NH for the potential siting of an LNG storage and vaporization facility. Liberty Utilities requested Sanborn Head to perform an analysis to assess if there are any fatal flaws with respect to siting an LNG facility. The proposed LNG facility is anticipated to have [REDACTED] vaporization, LNG transport offloading, and associated natural gas sendout piping. It is also anticipated that CNG tube trailers will deliver CNG to the facility for use in up to six decompression skids.

Tasks Performed As Part of Initial Phase of Analysis

1. Preliminary Design Basis

We prepared a preliminary design basis that addresses LNG flow rates and natural gas send out flow rates (peak hourly) and associated fluid temperatures and pressures, as well as number of days of on-site storage. A summary table is provided as an attachment to this memo. Key points of the design basis are:

- a. The maximum hourly sendout from the proposed LNG facility is 358 MSCFH which is based on a peak demand estimate from Liberty Utilities. [REDACTED]
- b. The on-site LNG storage provides an estimated four days of storage for uninterruptible users.
- c. It is assumed that the MAOP of the distribution system will be 60 psig and upstream pressure requirements were estimated based on this MAOP.

2. Data Review – Publicly Available and Phase 1 Environmental Site Assessment Report (ESA)

We reviewed publicly available information to assess the proximity of the property to an airport and flood plains. Liberty Utilities also provided a Phase 1 ESA performed for the property for another entity. The findings from this data review

August 31, 2015

20150831 Phase 1 of Fatal Flaw Analysis - Memo.docx

Page 2

3672.00

are outlined below. Additionally, Sanborn Head has extensive knowledge of the property to the north of the parcel being evaluated – the Lebanon Landfill. Our knowledge of this property as it may relate to the parcel south of it is provided below as well.

- a. The Lebanon Municipal Airport's runway is located approximately 6,750 feet (1.3 miles) to the east of the property. This distance does not pose any issue for the layout of the proposed LNG facility with respect to runway and approach distances. Reference Drawing G-1, Location Plan, which depicts where the property is with respect to the airport.
- b. Review of both the ESA and the Federal Emergency Management Agency's National Flood Insurance Program published mapping indicate that there are not any flood plains on the property. Refer to Drawing G-3, Site Plan – Flood Plains, which depicts where the flood plain is located with respect to the property.
- c. Geology – We did hit bedrock unexpectedly during the construction of the last cell. There was an error in the bedrock map provided to us. The mapping we have doesn't include the property to the south, so we cannot comment offered on the depth to bedrock. However, considering the information we have to the north, the change in the river direction, bedrock could have a localized high point almost anywhere. That said, considering that the site is a sand and gravel operations, there should be drilling logs that may provide information about bedrock. Also, if continued excavation is a concern, perhaps the site development could involve engineered backfill areas. In this case the backfilling operations should be monitored to assure that a well-compacted foundation is constructed.
- d. Landfill Gas – Prior to the installation and operation of the active LFG extraction system, there were some LFG migration issues detected along the landfill's east property boundary. The active system should be the mitigation for this condition. LFG migration to the south is less likely because of the unlined landfill is quite a distance away from the south boundary and the newest landfill cell is significantly deeper than the bottom of the older cells (lined and unlined). Of note is that there are plans (not yet permitted) to expand the landfill further south. This phase of the landfill is some years off. While it is not impossible for LFG to migrate from the unlined cell, or even the lined cell of the landfill gas conveyance piping, if things are well managed, the potential risk is limited.
- e. Wetland areas – Considering the site usage, there may be wetlands on the site that could affect the site development. Such information is not typical of an ESA, and a wetland scientist would need to visit the site to verify the presence or absence of wetlands.

3. Conceptual Equipment General Arrangement

We prepared a conceptual equipment general arrangement drawing that depicts the major system components for the proposed LNG facility. Set back and equipment separation distances and containment requirements in accordance with NFPA 59A were incorporated into this conceptual equipment general arrangement. Reference Drawing G-4, Equipment General Arrangement, provided as an attachment to this memo.

4. Site Plan Drawing

Refer to Drawing G-2, Site Plan, which overlays the equipment general arrangement onto the property. At this preliminary phase, we did not include the proposed CNG equipment or truck egress and access routes.

5. Conceptual Level Thermal Radiation Modeling

We performed conceptual level thermal radiation modeling using LNGFire3 modeling software. Climactic data from the last six years was researched to establish the input parameters to the model (e.g., wind speed, relative humidity, temperature) in accordance with the regulations. Exclusion zone radii are depicted on the site plan developed in Item 4, above. Code requires that the 10,000 BTU/hr-ft² zone stay within the property boundaries; this is achievable based on this first round of modeling. The modeling printout is provided as an attachment.

Conclusions

The first phase of this fatal flaw analysis has not identified any fatal flaws in areas studied that would pre-empt Liberty Utilities from proceeding with the next level assessment.

Recommended Next Steps

Performing vapor dispersion modeling will be a critical aspect to more definitively qualify the property being considered. We strongly recommend that the vapor dispersion modeling be performed as soon as possible, since it is our experience that keeping the 50% LEL exclusion zone within the property boundaries is typically more challenging than keeping the 10,000 BTU/hr-ft² exclusion zone within the property boundaries. Please note that the recommended vapor dispersion modeling will provide worse case conditions. It may even show that the 50% LEL will travel beyond the property limits. Mitigation measures such as insulated concrete, vapor fences and water spray systems would be studied in the detailed design phase if we conclude that the 50% LEL goes beyond property boundaries.

As part of this next phase of the analysis, we may need to consider reducing the amount of on-site storage, using smaller LNG tanks, and optimizing the size of the subimpoundment within the LNG containment in order to meet exclusion zone requirements. Each of these elements will have an impact on the extent of the modeled vapor dispersion zones.

JMF/MAN: jmf

Encl. Preliminary Design Basis
Drawing G-1, Location Plan

August 31, 2015

20150831 Phase 1 of Fatal Flaw Analysis - Memo.docx

Page 4

3672.00

Drawing G-2, Site Plan
Drawing G-3, Site Plan - Flood Plains
Drawing G-4, Equipment General Arrangement
LNGFire3 Modeling Output

P:\3600s\3672.00\Work\Lebanon Site Fatal Flaw Analysis\20150831 Phase 1 of Fatal Flaw Analysis - Memo.docx

SANBORN |||| HEAD

Design Basis Liberty Utilities - Lebanon NH Site Fatal Flaw Analysis					
Equipment/Service	Fluid	Flow Rate	Pressure	Temperature	Comment
LNG Offloading	LNG	200 gpm (maximum)	80 psig (nominal) 100 psig (maximum)	-260 °F	(2) 100% capacity pumps, off-loading stations. Pumps to increase pressure from 20-40 psig in transports to 80 psig nominal pressure in tanks.
LNG Tanks	LNG	--	80 psig (nominal) 100 psig (maximum allowable)	-260 °F	
Vaporized LNG	Natural Gas	358 MSCFH (maximum) 45 MSCFH (minimum)	70 psig	50 °F	Maximum hourly flow rate based on peak demand estimate from Liberty Utilities (does not include Dartmouth College). Minimum flow rate assumes an 8:1 turndown.
NG Sendout	Natural Gas	358 MSCFH (maximum) 45 MSCFH (minimum)	60 psig	50 °F	Pressure based on distribution system MAOP.
LNG Vaporizer	TBD	--	--	--	6.5 MMBtu/hr - required heat output.
Boil Off Gas	Natural Gas	0.74 MSCFH	80 psig	-240 °F	Assumes a boil off rate of 0.1 % per day of the 90% full tank volume.
Boil Off Gas (after ambient heat exchanger)	Natural Gas	0.74 MSCFH	70 psig	Ambient Temperature less 20 °F	Downstream of ambient heat exchanger.

- NOTES
1. THE COMPLETION OF THE FOLLOWING DOCUMENTS IS REQUIRED ON THIS DRAWING:
 - A. THE BASE MAP WAS DRAWN FROM A GOOGLE IMAGE, DATE 05/18/15 WITH AN ORIGINAL SCALE OF 1"=1000'
 - B. THE PROPERTY BOUNDARY WAS DRAWN FROM THE LEBANON ONLINE ASSESSING DATABASE FOUND AT [HTTP://WWW.OPUBLIC.NET/7878/LEBANON/](http://www.opublic.net/7878/LEBANON/)
 2. PER 49 CFR 193.2155(b), AN LNG STORAGE TANK MUST NOT BE LOCATED WITHIN A HORIZONTAL DISTANCE OF ONE MILE (1.6 KM) FROM THE ENDS, OR 1/4 MILE (0.4 KM) FROM THE NEAREST POC RUNWAY, WHICHEVER IS LONGER.



SANBORN HEAD		GRAPHICAL SCALE 0 500 1000 FEET		DRAWN BY: MJQ DESIGNED BY: MJQ REVIEWED BY: JMF PROJECT MGR: JMF PIC: MAN DATE: AUGUST 2015		LEBANON SITE FATAL FLAW ANALYSIS LIBERTY UTILITIES LEBANON, NH		PAGE 36
8 08/11/15 ISSUED TO CLIENT - PHASE 1 FATAL FLAW (EXCEPTED)						LOCATION PLAN		SHEET

- NOTES:
1. THE COMPILATION OF THE FOLLOWING DOCUMENTS IS REPRESENTED ON THIS DRAWING:
 - A. THE BASE MAP WAS DRAWN FROM A GOOGLE IMAGE, DATED 08/18/15 WITH AN ORIGINAL SCALE OF 1"=100'
 - B. THE PROPERTY BOUNDARY WAS DRAWN FROM THE LEBANON ONLINE ASSESSING DATABASE FOUND AT [HTTP://WWW.OPUBLIC.NET/AH/LEBANON/](http://www.opublic.net/ah/lebanon/)



SANBORN HEAD



0	08/19/15	ISSUED TO CLIENT - PHASE 1 FATAL FLAW ANALYSIS		MJD	
NO	DATE	DESCRIPTION		BY	

DRAWN BY: MJD
DESIGNED BY: MJD
REVIEWED BY: JMF
PROJECT MGR: JMF
PIC: MAN
DATE: AUGUST 2015


LEBANON SITE FATAL FLAW ANALYSIS
LIBERTY UTILITIES
LEBANON, NH

SITE PLAN


PROJECT NUMBER
3672.00


SHEET NUMBER
G-2

- NOTES
1. THE COMPILED OF THE FOLLOWING DOCUMENTS IS REPRESENTED ON THIS DRAWING:
 - A. THE BASE MAP WAS DRAWN FROM A GOOGLE IMAGE, DATE 08/15/15 WITH AN ORIGINAL SCALE OF 1" = 200'
 - B. FEMA FLOOD MAP SERVICE CENTER, TITLED "GRAFTON COL. FLOOD INSURANCE RATE MAP", DATE 02/20/06
 - C. THE PROPERTY BOUNDARY WAS DRAWN FROM THE LEBANON ONLINE ASSESSING DATABASE FOUND AT [HTTP://WWW.OPUBLIC.NET/LEBANON](http://www.opublic.net/lebanon)



SANBORN HEAD	GRAPHICAL SCALE 100' 50' 0' 100' 200'	0 08/1/15 ISSUED TO CLIENT - PHASE 1 FATAL FLAW 100' DATE DE 15/08/2015	DRAWN BY: MJQ DESIGNED BY: MJQ REVIEWED BY: JMF PROJECT MGR: JMF INC. MAN DATE: AUGUST 2015	LEBANON SITE FATAL FLAW ANALYSIS LIBERTY UTILITIES LEBANON, NH	PROJ# 36
				SITE PLAN - FLOOD PLAINS	SHEET



SANBORN HEAD						DRAWN BY TFS	LEBANON SITE FATAL FLAW ANALYSIS LIBERTY UTILITIES LEBANON, NH	PROJECT NUMBER
						DESIGNED BY TFS		3758.00
						REVIEWED BY JMF		
						PROJECT MGR JMF	EQUIPMENT GENERAL ARRANGEMENT	SHEET NUMBER G-4
						PIC MAN		
						DATE AUGUST 2015		
		0 08/01/15 ISSUED TO CLIENT - PHASE 1 FATAL FLAW TFS						
		10 08/16 ISSUED TO CLIENT - PHASE 1 FATAL FLAW 02						

RECTANGULAR DIKE FIRE
TRENCH FIRE

FUEL

Name : LNG LIGHT (METHANE)
Pool temperature : -258.79 ° F

CONSTANT PROPERTIES

Molecular weight : 16.04
Boiling point : -258.79 ° F
Critical temperature : -116.68 ° F
Critical pressure : 667.2 psi
Heat of combustion : 2.15E+04 Btu/lb
Flame temperature : 1880 ° F

CALCULATED PROPERTIES

Liquid compressibility factor : 0.004
Liquid density : 29.69 lb/cu ft

DIMENSIONS

Pool width : 147.5 ft
Pool length : 181.0 ft
Pool liquid height : 4.0 ft
Height of flame base : 4.0 ft
Height for Radiation Calculations : 4.0 ft

LOCAL AMBIENT CONDITIONS

Air temperature : 3.0 ° F
Ambient pressure : 1.0 atm
Wind speed : 27.0 mph
Relative humidity : 24.0%

RESULTS

Mass burning rate : 0.023 lb/ft² s
Flame length : 207.57 ft
Flame tilt from vertical (front view) : 60.14°
Flame tilt from vertical (side view) : 58.99°
Flame drag ratio (front view) : 1.52
Flame drag ratio (side view) : 1.41
Maximum emissive power : 60,230 Btu/ft² hr
Effective emissive power (front view) : 60229.68 Btu/ft² hr
Effective emissive power (side view) : 60229.68 Btu/ft² hr

Front view (view along dike/trench width)

Thermal flux (Btu/ft² hr)	Distance from center of pool (ft)
1000	449.84
4000	563.40
1600	729.22

Side view (view along dike/trench length)

Thermal flux (Btu/ft² hr)	Distance from center of pool (ft)
1000	447.06
4000	553.37
1600	706.63

Maximum emissive power : 190.0 kW/m²

Front view (view along dike/trench width)

Distance from center of pool (ft)	Thermal flux to horizontal target (Btu/ft² hr)	Thermal flux to vertical target (Btu/ft² hr)	Maximum flux to target (Btu/ft² hr)
110.63	Target in flame	Target in flame	Target in flame
147.50	Target in flame	Target in flame	Target in flame
184.38	50,920	28,482	53,814
221.25	46,751	27,572	50,823
295.00	32,383	23,538	39,309
368.75	13,484	17,814	22,339
442.50	4,203	9,864	10,721
590.00	675.72	3,292	3,360

885.00	83.49	866.18	870.15
1,475	9.80	212.43	212.65

Side view (view along dike/trench length)

Distance from center of pool (ft)	Thermal flux to horizontal target (Btu/ft ² hr)	Thermal flux to vertical target (Btu/ft ² hr)	Maximum flux to target (Btu/ft ² hr)
135.75	Target in flame	Target in flame	Target in flame
181.00	51,700	28,537	54,292
226.25	46,029	27,286	50,136
271.50	37,608	24,214	42,920
362.00	15,879	17,458	23,598
452.50	3,850	8,659	9,475
543.00	1,127	4,172	4,321
724.00	211.57	1,456	1,472
1,086	30.99	418.92	420.03
1,810	4.04	109.05	109.11

RECTANGULAR DIKE FIRE
 TRENCH FIRE

FUEL

Name : LNG LIGHT (METHANE)
 Pool temperature : -258.79 ° F

CONSTANT PROPERTIES

Molecular weight : 16.04
 Boiling point : -258.79 ° F
 Critical temperature : -116.68 ° F
 Critical pressure : 667.2 psi
 Heat of combustion : 2.15E+04 Btu/lb
 Flame temperature : 1880 ° F

CALCULATED PROPERTIES

Liquid compressibility factor : 0.004
 Liquid density : 29.69 lb/cu ft

DIMENSIONS

Pool width : 109.0 ft
 Pool length : 121.0 ft
 Pool liquid height : 4.0 ft
 Height of flame base : 4.0 ft
 Height for Radiation Calculations : 1.64 ft

LOCAL AMBIENT CONDITIONS

Air temperature : 3.0 ° F
 Ambient pressure : 1.0 atm
 Wind speed : 27.0 mph
 Relative humidity : 24.0%

RESULTS

Mass burning rate : 0.023 lb/ft² s
 Flame length : 168.21 ft
 Flame tilt from vertical (front view) : 61.75°
 Flame tilt from vertical (side view) : 61.2°
 Flame drag ratio (front view) : 1.57
 Flame drag ratio (side view) : 1.51
 Maximum emissive power : 60,230 Btu/ft² hr
 Effective emissive power (front view) : 60229.67 Btu/ft² hr
 Effective emissive power (side view) : 60229.67 Btu/ft² hr

Front view (view along dike/trench width)

Thermal flux (Btu/ft² hr)	Distance from center of pool (ft)
1000	347.07
4000	430.45
1600	550.98

Side view (view along dike/trench length)

Thermal flux (Btu/ft² hr)	Distance from center of pool (ft)
1000	345.92
4000	426.71
1600	542.61

Maximum emissive power : 190.0 kW/m²

Front view (view along dike/trench width)

Distance from center of pool (ft)	Thermal flux to horizontal target (Btu/ft² hr)	Thermal flux to vertical target (Btu/ft² hr)	Maximum flux to target (Btu/ft² hr)
81.75	Target in flame	Target in flame	Target in flame
109.00	Target in flame	Target in flame	Target in flame
136.25	51,564	25,283	53,266
163.50	47,767	26,254	50,890
218.00	35,543	22,694	40,739
272.50	18,413	18,323	25,975
327.00	6,272	11,362	12,977
436.00	916.51	3,688	3,800

654.00	101.00	907.39	912.93
1,090	11.14	214.03	214.31

Side view (view along dike/trench length)

Distance from center of pool (ft)	Thermal flux to horizontal target (Btu/ft ² hr)	Thermal flux to vertical target (Btu/ft ² hr)	Maximum flux to target (Btu/ft ² hr)
90.75	Target in flame	Target in flame	Target in flame
121.00	Target in flame	Target in flame	Target in flame
151.25	49,806	26,027	52,254
181.50	44,097	25,187	47,797
242.00	28,203	19,986	34,005
302.50	10,763	14,175	17,798
363.00	3,142	7,419	8,057
484.00	485.64	2,380	2,429
726.00	59.60	618.58	621.43
1,210	7.02	151.49	151.65