



Knollwood Energy of MA LLC
 P.O. Box 30
 Chester, New Jersey 07930

January 14, 2016

Debra A. Howland
 Executive Director
 New Hampshire Public Utilities Commission
 21 South Fruit Street, Suite 10
 Concord, NH 03301-2429

NHPUC 19 JAN 16 PM 2:54

Dear Ms Howland,

Enclosed please find applications for 12 systems to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.

Also enclosed are the Simplified Process Interconnection Application and Service Agreement, and the Certificate of Completion.

Electronic versions have been entered into the new online application system under batch number KN16007.

Michael Abbott	Derek Brown
Doug Averill	George Chase
Barrington Rollinsford Mill/Jack Bingham	John Chirico Jr.
Timothy Bohlin	David Ciarla
Matt Boyer	Bruce Courtney
Alan Brady	Shawn Hassell

Please feel free to contact me with any questions or further instructions.
 Thank you for your consideration,

Linda Modica
 New England REC Operations Manager
Knollwood Energy of MA LLC
 973.879.7826
linda@knollwoodenergy.com

NH Public Utilities Commission

REC Aggregator Portal

New Users [CLICK HERE](#) to setup your account for this form. Creating an account enables you to partially complete the form and return later to finish it or to make changes after the form is submitted. Be sure to create your account **BEFORE** entering information into the form, or the information will be lost.

Existing Users [CLICK HERE](#)

Basic Information

Who is submitting this request?

Aggregator

Aggregator Batch Number

KN16007

Aggregator name

Knollwood Energy

Aggregator Email

linda@knollwoodenergy.com

Other Aggregator name

Other aggregator email address

Facility Owner Name

Michael Abbott

Facility Owner email

mike@myabg.net

Owner Phone

603-491-1435

Facility Address

152 Merrimack St

Facility Town/City

Hooksett

Facility State

NH

Facility Zip

03106

Is the facility address the same as the owner's mailing address

- Yes
 No

Mailing Address

Mailing Town/City

Mailing State

Mailing Zip

Primary Contact (who should we call with questions)

Linda Modica

Contact Phone

Other Email Address

Facility Information

Class

II

Utility

Eversource

Other Utility Name

To obtain a GIS ID contact:

James Webb
408 517 2174
jwebb@apx.com

GIS ID (include "NON")

NON58730

Date of Initial Operation

09/12/2015

Facility Operator Name, if applicable

Panel Quantity

86

Panel Make

Q-Cell

Panel Model

Other

Panel Rated Output

270

System capacity based on panels

0.2322

Inverter Quantity

2

Inverter Make

Solar Edge

Inverter Rated Output

10000

Add'l Inverter Quantity

NA

Additional Inverter Make

None

Add'l Inverter Model

Rated Output - Primary Inverter

10000

Rated Output - Additional Inverter

System capacity based on single inverter make

2.00

System capacity based on two inverter types

System capacity in mW as stated on the interconnection agreement

21.8

Revenue Grade Meter Make

GE

Was this facility installed directly by the customer (no electrician involved)?

- Yes
 No

Electrician Name & Number

Lenn Johnson8633M

Other Electrician Name & Number

Installation Company

Other

Other Installation Company Name

V.H. Energy

Other Inst. Company Address

275 Bear Hill Rd

Other Inst. Company City

Chichester

Other Inst. Company State

NH

Other Inst. Company Zip

03258

Independent Monitor Name & Company

Tom Kelly - Natural Capital

Other Monitor Name and Company

Is the installer also the equipment supplier?

Yes

No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

https://fs30.formsite.com/jan1947/files/f-5-99-5882898_0pCftMmr_Abbott_SPIA.pdf

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-168-5882898_kMdkSkKQ_Abbott_COC.pdf

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-173-5882898_DuhAr0xz_Abbott_NHOS.pdf

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.




Print Name

Linda Modica

Date Signed

01/14/2016

Revised



EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA

Simplified Process Interconnection Application and Service Agreement

Eversource Application Project ID#: N 3632

Contact Information:

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)

Customer or Company Name (print): Michael Abbott

Contact Person, if Company: Michael Abbott

Mailing Address: 152 Merrimack St.

City: Hooksett State: NH Zip Code: 03106

Telephone (Daytime): 603-491-1435 (Evening): 603-491-1435

Facsimile Number: _____ E-Mail Address: mike@myabg.net

Alternative Contact Information (e.g., System installation contractor or coordinating company, if appropriate):

Name: V.H. Energy - Vladimlr Hromis

Mailing Address: 275 Bear Hill Rd.

City: Chichester State: NH Zip Code: 03258

Telephone (Daytime): 603-731-3169 (Evening): 603-731-3169

Facsimile Number: _____ E-Mail Address: vhromis@vh-energy.com

Electrical Contractor Contact Information (if appropriate):

Name: Lenn Johnson - (Lic 8633)

Mailing Address: 454 Micol Rd.

City: Pembroke State: NH Zip Code: 03275

Telephone (Daytime): 603-498-3990 (Evening): 603-498-3990

Facsimile Number: _____ E-Mail Address: lennstang@comcast.net

Facility Site Information:

Facility (Site) Address: 152 Merrimack st

City: Hooksett State: NH Zip Code: 03106

Electric

Service Company: Eversource Account Number: 56665841003 Meter Number: 571037010

Account and Meter Number: Please consult an actual Eversource electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the Eversource Work Request number.

Eversource Work Request # 2585706

Non-Default Service Customers Only:

Competitive Electric

Energy Supply Company: _____ Account Number: _____

(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)

EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA

Simplified Process Interconnection Application and Service Agreement

Facility Machine Information:

Generator/ Model Name &
Inverter Manufacturer: Solar Edge Number: SE10000A-US 208/240VAC Quantity: ~~4~~ 2
Nameplate Rating: 10.950 (kW) 10.950 (kVA) (AC Volts) Phase: Single Three

Nameplate Rating: The AC Nameplate rating of the individual inverter.

System Design Capacity: ~~49.9~~ 21.8 (kW) ~~49.9~~ 21.8 (kVA) Battery Backup: Yes No

System Design Capacity: The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.

Net Metering: If Renewably Fueled, will the account be Net Metered? Yes No

Prime Mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other _____

Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other _____

Inverter-based Generating Facilities:

UL 1741 / IEEE 1547.1 Compliant (Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)
Yes No

The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.

External Manual Disconnect Switch:

An External Manual Disconnect Switch shall be installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'


Yes No

Location of External Manual Disconnect Switch: Next to utility meter

Project Estimated Install Date: 7/1/2015 Project Estimated In-Service Date: ~~7/15/2015~~ 9/15/2015

Interconnecting Customer Signature:

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the Terms and Conditions for Simplified Process Interconnections attached hereto:

Customer Signature:  Title: Home Owner Date: 6/24/15


Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the Eversource meter socket. Applications without such a diagram may be returned.

For Eversource Use Only

Approval to Install Facility:
Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.
Are system modifications required? Yes No To be Determined

Company Signature:  Title: Associate Date: 9/8/15

Eversource
Interconnection Standards For Inverters Sized Up To 100 kVA
Exhibit B - Certificate of Completion for Simplified Process Interconnections



Installation Information:

Check if owner-installed

Customer or Company Name (print): Michael Abbott

Contact Person, if Company: _____

Mailing Address: 152 Merrimack St

City: Hooksett State: NH Zip Code: 03106

Telephone (Daytime): (603) 491-1435 (Evening): _____

Facsimile Number: _____ E-Mail Address: mike@myabg.net

Facility Information: Meter # S71037010

Address of Facility (if different from above): N/A

City: _____ State: _____ Zip Code: _____

Electrical Contractor Contact Information:

Electrical Contractor's Name (if appropriate): Lenn Johnson

Mailing Address: 454 Micol Rd

City: Pembroke State: NH Zip Code: 03275

Telephone (Daytime): (603) 496-3990 (Evening): _____

Facsimile Number: _____ E-Mail Address: LennJohnson@comcast.net

License number: 8633

Date of approval to install Facility granted by the Company: 7/16/2015

Eversource Application ID number: #N 3632

Inspection:

The system has been installed and inspected in compliance with the local Building/Electrical Code of:

City: Hooksett NH County: Merrimack

Signed (Local Electrical Wiring Inspector, or attach signed electrical inspection):

Signature: [Signature]

Name (printed): Matthew Lavoie Date: 9.12.15

Customer Certification:

I hereby certify that, to the best of my knowledge, all information contained in this Exhibit B - Certification of Completion is true and correct. This system has been installed and shall be operated in compliance with applicable standards. Also, the initial start-up test required by Puc. 905.04 has been successfully completed.

Customer Signature: [Signature] 9.12.15

As a condition of interconnection you are required to send/fax a copy of this form to:

Eversource
Distributed Generation
780 North Commercial Street
P. O. Box 330, Manchester, NH 03105-0330
Fax No.: (603) 634-2924

New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.


The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Michael DAbbott

Printed Name of signature owner



Michael D. Abbott (Nov 16, 2015)

Signature of system owner