



**KNOLLWOOD ENERGY**

Knollwood Energy of MA LLC  
P.O. Box 30  
Chester, New Jersey 07930

January 22, 2016

Debra A. Howland  
Executive Director  
New Hampshire Public Utilities Commission  
21 South Fruit Street, Suite 10  
Concord, NH 03301-2429

NHPUC 26 JAN 16 AM 11:55

Dear Ms Howland,

Enclosed please find applications for 12 systems to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.

Also enclosed are the Simplified Process Interconnection Application and Service Agreement, and the Certificate of Completion.

Electronic versions have been entered into the new online application system under batch number KN16009.

Barrington Power DUUF	Johanna Publow
Resource Management/Marty Riehs	Bill Radzelovage
Sean Carter	Malcom Sandberg
Mike Conroy	Theresa Tarsa
Tom Noonan/Judy Stewart	Jamie Troon
Craig Putnam	Richard Vass

Please feel free to contact me with any questions or further instructions.  
Thank you for your consideration,

Linda Modica  
New England REC Operations Manager  
**Knollwood Energy of MA LLC**  
973.879.7826  
[linda@knollwoodenergy.com](mailto:linda@knollwoodenergy.com)

## NH Public Utilities Commission

REC Aggregator Portal

---

New Users [CLICK HERE](#) to setup your account for this form. Creating an account enables you to partially complete the form and return later to finish it or to make changes after the form is submitted. Be sure to create your account **BEFORE** entering information into the form, or the information will be lost.

Existing Users [CLICK HERE](#)

**Basic Information**

---

Who is submitting this request?

Aggregator Batch Number

Aggregator name

Aggregator Email

Other Aggregator name

Other aggregator email address

Facility Owner Name

Facility Owner email

Owner Phone

Facility Address

Facility Town/City

Pembroke

Facility State

NH

Facility Zip

03275

Is the facility address the same as the owner's mailing address

- Yes
- No

Mailing Address

Mailing Town/City

Mailing State

Mailing Zip

Primary Contact (who should we call with questions)

Linda Modica

Contact Phone

Other Email Address

Facility Information

---

Class

II

Utility

Eversource

Other Utility Name

To obtain a GIS ID contact:

James Webb

408 517 2174

jwebb@apx.com

GIS ID (include "NON")

NON60286

Date of Initial Operation

10/07/2015

Facility Operator Name, if applicable

Panel Quantity

46

Panel Make

LG

Panel Model

305NIC G3

Panel Rated Output

305

System capacity based on panels

0.1403

Inverter Quantity

1

Inverter Make

Solar Edge

Add'l Inverter Quantity

1

Additional Inverter Make

None

Add'l Inverter Model

Rated Output - Primary Inverter

Rated Output - Additional Inverter

System capacity based on single inverter make

System capacity based on two inverter types

System capacity in mW as stated on the interconnection agreement

Revenue Grade Meter Make

Was this facility installed directly by the customer (no electrician involved)?

- Yes
- No

Electrician Name & Number

Other Electrician Name & Number

Installation Company

Other Installation Company Name

Other Inst. Company Address

Other Inst. Company City

Other Inst. Company State

Other Inst. Company Zip

Independent Monitor Name & Company

Paul Button - Energy Audits Unlimited

Other Monitor Name and Company

Is the installer also the equipment supplier?

- Yes  
 No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

[https://fs30.formsite.com/jan1947/files/f-5-99-5944614\\_1ERIYSon\\_Carter\\_SPIA.pdf](https://fs30.formsite.com/jan1947/files/f-5-99-5944614_1ERIYSon_Carter_SPIA.pdf)

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Please attach additional document here

[https://fs30.formsite.com/jan1947/files/f-5-168-5944614\\_DJh5dHlo\\_Carter\\_COC.pdf](https://fs30.formsite.com/jan1947/files/f-5-168-5944614_DJh5dHlo_Carter_COC.pdf)

Please attach additional document here

[https://fs30.formsite.com/jan1947/files/f-5-173-5944614\\_7vsGQIQV\\_Carter\\_Agreements\\_part\\_3\\_-\\_sigl](https://fs30.formsite.com/jan1947/files/f-5-173-5944614_7vsGQIQV_Carter_Agreements_part_3_-_sigl)

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.




Print Name

Linda Modica

Date Signed

01/22/2016

Revision



EVERSOURCE  
INTERCONNECTION STANDARDS FOR INVERTERS  
SIZED UP TO 100 KVA  
Simplified Process Interconnection Application and Service Agreement

Eversource Application Project ID#: N 3561

**Contact Information:**

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)

Customer or Company Name (print): SEAN + KIM CARTER

Contact Person, if Company: \_\_\_\_\_

Mailing Address: 457 4TH RANGE RD

City: PEMBROKE State: NH Zip Code: 03275

Telephone (Daytime): 603-485-5006 (Evening): 603 485-5006

Facsimile Number: \_\_\_\_\_ E-Mail Address: SEAN + CARTER @ TD.COM

**Alternative Contact Information** (e.g., System installation contractor or coordinating company, if appropriate):

Name: FRASE ELECTRIC LLC

Mailing Address: 789 Whittier Highway

City: SOUTH TOWN State: NH Zip Code: 03883

Telephone (Daytime): 603-284-6618 (Evening): 603 284 6618

Facsimile Number: 603-284-6343 E-Mail Address: KIM @ FRASE ELECTRIC.COM

**Electrical Contractor Contact Information** (if appropriate):

Name: N/A

Mailing Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

Telephone (Daytime): \_\_\_\_\_ (Evening): \_\_\_\_\_

Facsimile Number: \_\_\_\_\_ E-Mail Address: \_\_\_\_\_

**Facility Site Information:**

Facility (Site) Address: 457 4th RANGE RD

City: PEMBROKE State: NH Zip Code: 03275

Electric Service Company: Eversource Account Number: 56304841083 Meter Number: 871002602

Account and Meter Number: Please consult an actual Eversource electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the Eversource Work Request number.

Eversource Work Request # \_\_\_\_\_

**Non-Default Service Customers Only:**

Competitive Electric Energy Supply Company: ENH POWER Account Number: 56304841083

(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)

**EVERSOURCE  
INTERCONNECTION STANDARDS FOR INVERTERS  
SIZED UP TO 100 KVA  
Simplified Process Interconnection Application and Service Agreement**

**Facility Machine Information:** LG 305NIC-183 44  
 Generator/ LG Model Name & SE 6000A-US  
 Inverter Manufacturer: Solar Edge Number: SE7600A-US Quantity: 1  
 Nameplate Rating: 14.35 (kW) 14.35 (kVA) (AC Volts) Phase: Single  Three   
 Nameplate Rating: *The AC Nameplate rating of the individual inverter.*  
 System Design Capacity: 14.35 (kW) 14.35 (kVA) Battery Backup: Yes  No   
 System Design Capacity: *The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.*  
 Net Metering: If Renewably Fueled, will the account be Net Metered? Yes  No   
 Prime Mover: Photovoltaic  Reciprocating Engine  Fuel Cell  Turbine  Other \_\_\_\_\_  
 Energy Source: Solar  Wind  Hydro  Diesel  Natural Gas  Fuel Oil  Other \_\_\_\_\_

**Inverter-based Generating Facilities:**  
 UL 1741 / IEEE 1547.1 Compliant (Refer To Part Pac 906 Compliance Path For Inverter Units, Part Pac 906.01 Inverter Requirements)  
 Yes  No   
 The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. *Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.*


**External Manual Disconnect Switch:**  
 An External Manual Disconnect Switch shall be installed in accordance with 'Part Pac 905 Technical Requirements For Interconnections For Facilities, Pac 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'  
 Yes  No   
 Location of External Manual Disconnect Switch: By Net meter  
 Project Estimated Install Date: 7/10 Project Estimated In-Service Date: 7/30

**Interconnecting Customer Signature:**  
 I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the Terms and Conditions for Simplified Process Interconnections attached hereto:  
 Customer Signature: [Signature] Title: \_\_\_\_\_ Date: 5/26/2015

*Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the Eversource meter socket. Applications without such a diagram may be returned.*

**For Eversource Use Only**

Approval to Install Facility:  
 Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.  
 Are system modifications required? Yes  No  To be Determined   
 Company Signature: [Signature] Title: Associate Date: 8/27/15  
 Eversource SPIA rev. 03/14 E.N. Neer Page 2 of 4



Eversource  
Interconnection Standards For Inverters Sized Up To 100 kVA  
Exhibit B - Certificate of Completion for Simplified Process Interconnections

**Installation Information:**  Check if owner-installed  
Customer or Company Name (print): Sean + Kim Carter  
Contact Person, if Company: \_\_\_\_\_  
Mailing Address: 457 4th Range Rd.  
City: Rembroke State: NH Zip Code: 03275  
Telephone (Daytime): 603 485-5006 (Evening): Same  
Facsimile Number: \_\_\_\_\_ E-Mail Address: Sean.Carter@td.com

**Facility Information:** → Eversource Meter # S-71002602  
Address of Facility (if different from above): \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

**Electrical Contractor Contact Information:**  
Electrical Contractor's Name (if appropriate): Frase Electric LLC  
Mailing Address: 789 Whittier Hwy  
City: So. Tamworth State: NH Zip Code: 03883  
Telephone (Daytime): 603 284-6618 (Evening): 284-6618  
Facsimile Number: 284-6343 E-Mail Address: Kim@fraseelectric.com  
License number: 4446M

Date of approval to install Facility granted by the Company: \_\_\_\_\_  
Eversource Application ID number: #N 3561

**Inspection:**  
The system has been installed and inspected in compliance with the local Building/Electrical Code of:  
City: REMBROKE County: MERRIMACK  
Signed (Local Electrical Wiring Inspector, or attach signed electrical inspection):  
Signature: \_\_\_\_\_  
Name (printed): EVERETT HODGE Date: 10-7-05

**Customer Certification:**  
I hereby certify that, to the best of my knowledge, all information contained in this Exhibit B - Certification of Completion is true and correct. This system has been installed and shall be operated in compliance with applicable standards. Also, the initial start-up test required by Puc. 905.04 has been successfully completed.  
Please remember to provide digital photos of the installation, including the AC disconnect switch (if required), the existing Eversource meter, the inverters, and the point of electrical interconnection.  
Customer Signature: \_\_\_\_\_

As a condition of interconnection you are required to send/fax a copy of this form to:

Eversource  
Distributed Generation  
780 North Commercial Street  
P. O. Box 330, Manchester, NH 03105-0330  
Fax No.: (603) 634-2924

## New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Sean M Carter

---

Printed Name of signature owner

Sean M Carter  
Sean M Carter (Dec 22, 2015)

---

Signature of system owner