

NH Public Utilities Commission

REC Aggregator Portal

NHPUC 4MAR'16AM11:45

New Users [CLICK HERE](#) to setup your account for this form. Creating an account enables you to partially complete the form and return later to finish it or to make changes after the form is submitted. Be sure to create your account **BEFORE** entering information into the form, or the information will be lost.

Existing Users [CLICK HERE](#)

Basic Information

Who is submitting this request?

Aggregator Batch Number

Are you registered in NH

- Yes
 No

Aggregator name

NH Reg #

Aggregator Email

Other Aggregator name

Other aggregator email address

Facility Owner Name

Facility Owner email

Owner Phone

603-321-7000

Facility Address

152 Charlestown Road

Facility Town/City

Claremont

Facility State

NH

Facility Zip

03743

Is the facility address the same as the owner's mailing address

- Yes
 No

Mailing Address

Mailing Town/City

Mailing State

Mailing Zip

Primary Contact

Karen Tenneson

Primary Contact

Other Email Address

karenton@knollwoodenergy.com

Facility Information

Class

II

Utility

Eversource

Other Utility Name

To obtain a GIS ID contact:

James Webb

408 517 2174

jwebb@apx.com

GIS ID (include "NON")

NON69888

Date of Initial Operation

12/24/2015

Facility Operator Name, if applicable

Panel Quantity

440

Panel Make

Other

Panel Model

Other

Panel Rated Output

260

System capacity based on panels

114400

Inverter Quantity

4

Inverter Make

SMA

Add'l Inverter Quantity

NA

Additional Inverter Make

None

Rated Output - Primary Inverter

480

Rated Output - Additional Inverter

System capacity based on single inverter make

1920

System capacity based on two inverter types

System capacity in kW as stated on the interconnection agreement

Revenue Grade Meter Make

Other

Was this facility installed directly by the customer (no electrician involved)?

- Yes
- No

Electrician Name & Number

Cassandra Acacia 1365M

Other Electrician Name & Number

Installation Company

Boston Solar

Other Installation Company Name

Other Inst. Company Address

Other Inst. Company City

Other Inst. Company State

Other Inst. Company Zip

Independent Monitor Name & Company

Paul Button - Energy Audits Unlimited

Other Monitor Name and Company

Is the installer also the equipment supplier?

- Yes
 No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

https://fs30.formsite.com/jan1947/files/f-5-99-6227344_syGNpqjO_Subaru_Mans_SPIA.pdf

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Please attach additional document here


https://fs30.formsite.com/jan1947/files/f-5-168-6227344_W5c1pl5L_Sullivan_County_PTO_-_COC.pdf

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-173-6227344_bIACLSnw_Mans_NHOS1.pdf

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.



Print Name

Karen Tonnesen

Date Signed

03/01/2016

New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.


The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Peter R. Mans

Printed Name of signature owner



Peter R. Mans (Dec 18, 2015)

Signature of system owner

#N3915 Sullivan Cnty Mtrs Inc (Claremont) - Authorization to Interconnect

diane.cecchetti@eversource.com on behalf of DG@eversource.com

Mon 12/21/2015 4:02 PM

To: pmans@subaru7.com <pmans@subaru7.com>; Cassandra <cassandra.acacia@bostonsolar.us>;

Cc: michael.motta@eversource.com <michael.motta@eversource.com>; richard.labrecque@eversource.com <richard.labrecque@eversource.com>;

 2 attachments (435 KB)

N3915 Sullivan Cnty Mtrs Inc. PV - Certificate of Completion.pdf; N3915 Sullivan Cnty Mtrs Inc. PV - Processed Application.pdf;

Dear Mr. Yard:

We have processed the Exhibit B - Certificate of Completion for project # N3915 Sullivan Cnty Mtrs Inc (Claremont) located at 152 Charlestown Road, Claremont, NH.

The Certificate of Completion has been reviewed and processed and a new net meter has been installed. Enrollment into the Net Metering program is complete and you may interconnect your project to the Eversource electrical distribution system in accordance with the *New Hampshire Code of Administrative Rules Chapter Puc 900 Net Metering For Customer-Owned Renewable Energy Generation Resources of 1000 Kilowatts or Less*, and the *Terms and Conditions for Simplified Process Interconnections*. Attached for your records is a copy of the "Certificate of Completion" and the "Simplified Process Interconnection Application and Service Agreement."


Please contact Michael.Motta@eversource.com or by calling (603) 634-2920 should you have any questions or require additional information.

Sincerely,

Michael D. Motta
Senior Engineer, Eversource Distributed Generation

This electronic message contains information from Eversource Energy or its affiliates that may be confidential, proprietary or otherwise protected from disclosure. The information is intended to be used solely by the recipient(s) named. Any views or opinions expressed in this message are not necessarily those of Eversource Energy or its affiliates. Any disclosure, copying or distribution of this message or the taking of any action based on its contents, other than by the intended recipient for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Email transmission cannot be guaranteed to be error-free or secure or free from viruses, and Eversource Energy disclaims all liability for any resulting damage, errors, or omissions.

EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA



Simplified Process Interconnection Application and Service Agreement

Eversource Application Project ID# N 3915

Contact Information:

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)
Customer or Company Name (print): Sullivan City MTRD INC
Contact Person, if Company: Peter Mond
Mailing Address: 102 Charlestown Road
City: Claremont State: NH Zip Code: 03743
Telephone (Daytime): 603-821-7000 (Evening): _____
Facsimile Number: _____ E-Mail Address: pmond@subaru.com

Alternative Contact Information (e.g., System installation contractor or coordinating company, if appropriate):

Name: Boston Solar - Cassandra Accia
Mailing Address: 55 Sixth Road
City: Woburn State: MA Zip Code: 01801
Telephone (Daytime): 617-855-1645 (Evening): _____
Facsimile Number: _____ E-Mail Address: cassandra.accia@boston-solar.com

Electrical Contractor Contact Information (if appropriate):

Name: _____
Mailing Address: _____
City: _____ State: _____ Zip Code: _____
Telephone (Daytime): _____ (Evening): _____
Facsimile Number: _____ E-Mail Address: _____

Facility Site Information:

Facility (Site) Address: 102 Charlestown Road
City: Claremont State: NH Zip Code: 03743
Electric Service Company: Eversource Account Number: 50536451016 Meter Number: D88359614

Account and Meter Number: Please consult an actual Eversource electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the Eversource Work Request number.

Eversource Work Request # 2579799

Non-Default Service Customers Only:

Competitive Electric Energy Supply Company: _____ Account Number: _____
(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)

**EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA
Simplified Process Interconnection Application and Service Agreement**

Facility Machine Information:

Generator/ Inverter Manufacturer: SMA America Model Name & Number: Sunny Tripower 24000TL-US Quantity: 4
 Nameplate Rating: 24 (kW) 24 (kVA) 480 (AC Volts) Phase: Single Three
 Nameplate Rating: *The AC Nameplate rating of the individual inverter.*
 System Design Capacity: 96 (kW) 96 (KVA) Battery Backup: Yes No
 System Design Capacity: *The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.*
 Net Metering: If Renewably Fueled, will the account be Net Metered? Yes No
 Prime Mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other _____
 Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other _____

Inverter-based Generating Facilities:

UL 1741 / IEEE 1547.1 Compliant (Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)
 Yes No
 The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. *Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.*

External Manual Disconnect Switch:

An External Manual Disconnect Switch shall be installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'
 Yes No
 Location of External Manual Disconnect Switch: Adjacent to Utility meter Socket
 Project Estimated Install Date: 10/15/15 Project Estimated In-Service Date: 12/15/15

Interconnecting Customer Signature:

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the **Terms and Conditions for Simplified Process Interconnections** attached hereto:

Customer Signature: _____ Title: President Date: 8/12/2015

Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the Eversource meter socket. Applications without such a diagram may be returned.

For Eversource Use Only

Approval to Install Facility:

Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.

Are system modifications required? Yes No To be Determined **REFERENCE EVERSOURCE WR 2589289 FOR REQUIRED UPGRADES.**

Company Signature: Michael Motta Title: SR. ENGINEER Date: 10/01/15

EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA

Terms and Conditions for Simplified Process Interconnections

Company waives inspection/Witness Test: Yes No

Date of inspection/Witness Test: PLEASE CONTACT
EVERSOURCE TO
SCHEDULE.

1. **Construction of the Facility.** The Interconnecting Customer may proceed to construct the Facility in compliance with the specifications of its Application once the Approval to Install the Facility has been signed by the Company. Such Approval relates only to the Eversource and Puc 900 electrical interconnection requirements, and does not convey any permissions or rights associated with permits, code enforcement, easements, rights of way, set back, or other physical construction issues.
2. **Interconnection and operation.** The Interconnecting Customer may operate Facility and interconnect with the Company's system once the all of the following has occurred:
 - 2.1. **Municipal Inspection.** Upon completing construction, the Interconnecting Customer will cause the Facility to be inspected or otherwise certified by the local electrical wiring inspector with jurisdiction.
 - 2.2. **Certificate of Completion.** The Interconnecting Customer returns the Certificate of Completion to the Agreement to the Company at address noted.
 - 2.3. **Company has completed or waived the right to inspection.**
3. **Company Right of Inspection.** The Company will make every attempt within ten (10) business days after receipt of the Certificate of Completion, and upon reasonable notice and at a mutually convenient time, conduct an inspection of the Facility to ensure that all equipment has been appropriately installed and that all electrical connections have been made in accordance with the Interconnection Standard. The Company has the right to disconnect the Facility in the event of improper installation or failure to return Certificate of Completion. All projects larger than 10 kVA will be witness tested, unless waived by the Company.
4. **Safe Operations and Maintenance.** The Interconnecting Customer shall be fully responsible to operate, maintain, and repair the Facility.
5. **Disconnection.** The Company may temporarily disconnect the Facility to facilitate planned or emergency Company work.
6. **Metering and Billing.** All renewable Facilities approved under this Agreement that qualify for net metering, as approved by the Commission from time to time, and the following is necessary to implement the net metering provisions:
 - 6.1. **Interconnecting Customer Provides:** The Interconnecting Customer shall furnish and install, if not already in place, the necessary meter socket and wiring in accordance with accepted electrical standards. In some cases the Interconnecting Customer may be required to install a separate telephone line.
 - 6.2. **Company Installs Meter:** The Company will make every attempt to furnish and install a meter capable of net metering within ten (10) business days after receipt of the Certificate of Completion if inspection is waived, or within 10 business days after the inspection is completed, if such meter is not already in place.
7. **Indemnification.** Interconnecting Customer and Company shall each indemnify, defend and hold the other, its directors, officers, employees and agents (including, but not limited to, Affiliates and contractors and their employees), harmless from and against all liabilities, damages, losses, penalties, claims, demands, suits and proceedings of any nature whatsoever for personal injury (including death) or property damages to unaffiliated third parties that arise out of, or are in any manner connected with, the performance of this Agreement by that party, except to the extent that such injury or damages to unaffiliated third parties may be attributable to the negligence or willful misconduct of the party seeking indemnification.
8. **Limitation of Liability.** Each party's liability to the other party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either party be liable to the other party for any indirect, incidental, special, consequential, or punitive damages of any kind whatsoever.
9. **Termination.** This Agreement may be terminated under the following conditions:
 - 9.1. **By Mutual Agreement.** The Parties agree in writing to terminate the Agreement.
 - 9.2. **By Interconnecting Customer.** The Interconnecting Customer may terminate this Agreement by providing written notice to Company.
 - 9.3. **By Company.** The Company may terminate this Agreement (1) if the Facility fails to operate for any consecutive 12 month period, or (2) in the event that the Facility impairs or, in the good faith judgment of the Company, may imminently impair the operation of the electric distribution system or service to other customers or materially impairs the local circuit and the Interconnecting Customer does not cure the impairment.
10. **Assignment/Transfer of Ownership of the Facility.** This Agreement shall survive the transfer of ownership of the Facility to a new owner when the new owner agrees in writing to comply with the terms of this Agreement and so notifies the Company.
11. **Interconnection Standard.** These Terms and Conditions are pursuant to the Company's "Interconnection Standards for Inverters Sized Up to 100 kVA" for the Interconnection of Customer-Owned Generating Facilities, as approved by the Commission and as the same may be amended from time to time ("Interconnection Standard"). All defined terms set forth in these Terms and Conditions are as defined in the Interconnection Standard (see Company's website for the complete document).

#N3915 Sullivan County Motors PV - Conditional Approval

From: Michael D. Motta <DISTRIBUTED GENERATION > <634-2920 >
To: Cassandra Acacia

10/01/2015 11:03 AM

Good Morning Cassandra,

Project #N3915 Sullivan County Motors PV located at 152 Charlestwon Road in Claremont, NH is "approved" contingent on the Eversource upgrades necessary to facilitate this interconnection - refer to Eversource Work Request #2589289. Please remember all costs associate with any required Eversource upgrades shall be borne by the customer and/or developer.

Please do not hesitate to call me directly should you have any questions or require additional information.

Regards,

Michael D. Motta

Senior Engineer, Eversource - New Hampshire Distributed Generation

780 North Commercial Street

Manchester, NH 03105

Office: 603.634.2920

Fax: 603.634.2924

michael.motta@eversource.com