



August 8, 2016

Via Email and Federal Express

Debra A. Howland
Executive Director and Secretary
New Hampshire Public Utilities Commission
21 S. Fruit Street, Suite 10
Concord, NH 03301

NHPLUC 9AUG16PM12:02

RE: Wiggin Farm Homeowners Association Authorization for Temporary Emergency Connection to Aquarion Water Company of New Hampshire

Dear Ms. Howland:

Pursuant to RSA 378:18, Aquarion Water Company of New Hampshire ("AWC-NH") requests authorization from the Public Utilities Commission to provide service to the Wiggin Farm Homeowners Association ("WFHA") water systems through an emergency interconnection. Also, this letter serves to inform the Towns of Hampton, North Hampton, and Rye and the Office of the Consumer Advocate on the matter of the emergency interconnection.

AWC-NH has received a request from the WFHA for a temporary connection to our system on an emergency basis. The WFHA water system yield is not sufficient to meet basic domestic water needs. A temporary connection between the end of WFHA's system to Aquarion's nearest hydrant on Winterberry Lane will feed a few thousand gallons per day, on average, to meet the basic domestic water needs. The temporary supply to WFHA will only draw a few thousand gallons per day and will not have an adverse impact on the water services to our existing customer base. The emergency interconnection will be configured as a standard hydrant rig with approximately 300 feet of 2-inch piping. The service connection will be billed based on our current seasonal customer rates.

Attached to this letter is WFHA approval from the New Hampshire Department of Environmental Services for the emergency interconnection.

Please let me know if you have any questions. I can be reached at (603) 926-3319.

Sincerely,

Carl McMorran
Operations Manager