

1. Service Pipe

a. Location.

(1) Single Family Homes: Service pipe connections will be made in the street which is nearest to the premises served.

(2) Condominiums and Other Multi-Family Residences: One main service pipe may serve the total structure with individual connections to all units therein from a distribution manifold located on common property owned by the property owners' association.

(3) Commercial Buildings: Service pipe connections will be made in the street which is nearest to the premises served and one main service pipe may serve the total structure with individual connections to all businesses/units therein from a distribution manifold.

b. Installation, Ownership, and Maintenance.

(1) Single Family Homes: All service pipes from the main to the property line or common area including the premises exterior shut-off valve shall be owned and maintained by the Company. From the property line or common area to the premise served, the service pipe shall be installed, owned and maintained by the customer(s). Such installations shall be in a manner approved by the Company in writing prior to construction and shall be no less than 3/4 inch inside diameter. All new exterior shut-off valves shall be placed at the property line or common area.

(2) Condominiums and Other Multi-Family Residences: All service pipes from the main to the property line or common area including the unit's exterior shut-off valve shall be owned and maintained by the Company. From the property line or common area to the premises served the service pipe shall be installed, owned and maintained by the association or customer(s).

(3) Commercial Building: Effective for service pipes installed on and after August 9, 2016: All service pipes from the main to the property line or common area including the premises' exterior shut-off valve shall be owned and maintained by the Company. From the property line or common area to the premises served, the service pipe shall be installed, owned, and maintained by the customer(s). Service pipes installed prior to August 9, 2016 are governed by tariff provisions previously in effect, as follows:

Issued: October 1, 2021
Effective: June 30, 2021

Issued By: Donald Vaughan
Title: Chairman

Authorized by NHPUC Order No. 26,493 in Docket No. DW 19-131 dated June 30, 2021.