THE STATE OF NEW HAMPSHIRE BEFORE THE PUBLIC UTILITIES COMMISSION

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE d/b/a EVERSOURCE ENERGY

DOCKET	No.	DE 20-	
--------	-----	--------	--

PETITION OF PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE D/B/A EVERSOURCE ENERGY FOR LICENSE TO CONSTRUCT AND MAINTAIN ELECTRIC LINES OVER AND ACROSS STATE OWNED LAND IN CANTERBURY, NEW HAMPSHIRE

Pursuant to RSA 371:17, Public Service Company of New Hampshire d/b/a Eversource Energy ("Eversource" or "the Company"), a public utility engaged in the transmission, distribution and sale of electricity in the State of New Hampshire, hereby petitions the Public Utilities Commission ("Commission"), for a license to construct and maintain electric lines over and across certain State owned land in the Town of Canterbury. In support of this petition Eversource states as follows:

- 1. In order to meet the requirements for reasonable service to the public, Eversource has previously constructed and currently operates and maintains an overhead 115 kV electrical transmission line, designated as the Eversource F139 Line, over and across State owned land in Canterbury, New Hampshire, comprising a portion of former B&M Railroad ROW. The B&M Railroad previously granted a license for the crossing location in file FDA 304, however, this crossing has not been previously licensed by the PUC, but will be fully licensed pursuant to this petition. The location of the State owned land span which is the subject of this petition are depicted on the Overview Map attached hereto as Exhibit #1.
- 2. Eversource is commencing a project to replace a number of structures on its existing F139 Line including structures 241 and 243 which crosses State owned land in Canterbury. Said structures are approximately 54 years old and have been subjected to environmental damage. Therefore, they require replacement to continue to function safely and reliability. No wires will be replaced as part of this project; instead, existing conductor and static wire will be transferred to

the replacement structures, which will be a weathered steel replacement of the existing wood structures. Structure 242, which is a wood structure located in between Structures 241 and 243 and within the median of Interstate I93, will be removed and will not be replaced to eliminate the need for future maintenance work within the interstate median.

- 3. The design and proposed construction of the replacement crossings for the F139 Line over the State owned land is in accordance with the National Electrical Safety Code (NESC) and is depicted on the Eversource Plan and Profile Drawing attached as Exhibits 2. Structure 241 will be moved approximately 20' from the existing structure location owing to conditions on the ground and Structure 243 will be located within 10' of the original wood structures so as not to disturb the original structures' foundation while the wires are being transferred.
- Wire and structure specification for the State owned land crossings are depicted and noted on the Structure Detail and Cable Schedule of Exhibit 2.
- 5. The location of the structures creates the following crossing span:
 - Former B&M Railroad ROW: Canterbury (Exhibit 2)
 - i. Structures: 241 to 243
 - ii. Structure Span (ft): 646.5
 - iii. State Owned Land Span (ft): 98
- The conductor and static wire have been drawn on Exhibit 2 to show the minimum clearance at maximum sag conditions in reference to the State owned land span.
- 7. Eversource will maintain and operate the clearances of the crossings over the State owned land crossings at a height no less than what is required by the 2017 National Electrical Safety Code (NESC, Table 232-1). The State owned land crossing requires at least 28.1 feet to ground for land with railroad track under 115kV open supply conductors. The actual minimum height over the State owned land crossing is depicted on the attached Exhibits 2 and exceeds the minimum requirements.

8. A New Hampshire Department of Environmental Services statutory permit by notification (SPN) is required for construction access and work activities which involve the temporary minor alteration of nontidal wetlands, nontidal surface waters, and banks adjacent to nontidal surface waters and is applicable to the public water crossings. A SPN has been obtained in Canterbury (2020-00118).

9. It is not anticipated that abutters on either side of the State owned land crossings will be affected by the proposed structure replacements, as the F139 Line is an existing line and the crossing structures to be replaced are within Eversource's existing utility easements. Eversource is working with the Dept. of Transportation to obtain traffic management approval concerning the removal of Str. 242 within the I93 median.

10. Eversource submits that the license petitioned for herein may be exercised without substantially affecting the rights of the public in the State owned land. Minimum safe clearances land surfaces shall be maintained at all times. The use and enjoyment by the public of the State owned parcel will not be diminished in any material respect as a result of the proposed structure replacements.

WHEREFORE, Eversource respectfully requests that the Commission:

1. Find that the license petitioned for herein may be exercised without substantially affecting the public rights in the State owned lands which are the subject of this petition;

 Grant Eversource a license to construct and maintain electric lines over and across the State owned land as identified and described in this petition;

3. Authorize Eversource to submit any future proposed alteration(s) to the amended licenses granted herein at least 60 days prior to undertaking any such alteration(s); and

4.	Issue an	order	Nisi	and	orders	for	its	publication.
								P

Dated at Manchester, New Hampshire this ____ day of _____, 2020.

Respectfully submitted, PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE D/B/A EVERSOURCE ENERGY By Its Attorney

Erik R. Newman, Senior Counsel, Legal

780 North Commercial Street

Manchester, NH 03101

(603) 634-2459