

From: Delisle, Jeana M <jeana.delisle@eversource.com>
Sent: Friday, September 25, 2020 11:13 AM
To: O'Brien, Terrence <Terrence_O'Brien@cable.comcast.com>; Lepage, Linda (Contractor) <Linda_Lepage@cable.comcast.com>
Cc: Carter, Mark (Epping, NH) <Mark_Carter@cable.comcast.com>; Jolly, Regina (Contractor) <Regina_Jolly@cable.comcast.com>; NHattach <NHattach@eversource.com>
Subject: [EXTERNAL] RE: BMT-20-601, Request for Update

Attached is the revised Form 3 for License LBFT-05 with the approved riser additions. I will cancel BMT-20-601.


Thanks,

Jeana

Jeana Delisle
Associate Analyst | Operations Support

EVERSOURCE

 PO Box 330 | Manchester, NH 03105

 (603) 634-3234

**PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
 d/b/a EVERSOURCE ENERGY
 Pole Make- Ready Work Charges**

Date of Survey : November 6, 2019

PAGE 15 of 17

Total Poles Surveyed: _____ Total poles Requiring Make-Ready Work _____ Telco: _____ Eversource: _____

FIELD SURVEY / MAKE-READY WORK FORM																		
LICENSEE INFORMATION					FAIRPOINT INFORMATION					EVERSOURCE INFORMATION								
Application #		LBFT-05			Work Order #					Work Request #		3315399 / 91920896						
Company Name		Comcast of NH/ME Inc.			Application #					ALA #		ALA-317						
Surveyor Name		DAVE TESSIER			Exchange Code					AWC		41-Tilton						
Surveyor Phone #		(603) 327-5501			State Code					Municipality		Belmont						
					Surveyor Name					J ROBINSON								
					Surveyor Name					D SIMKINS								
STREET		TELEPHONE			ELECTRIC			Pole		*ATT		Ownership			Make-Ready		REMARKS	
POLE LOCATION		RTE	POLE		RTE	POLE		SIZE	BIRTH MARK	HEIGHT OF ATTCH	F, C, P.S., RISER	FO	JO	TO	JU	Yes		No
71 Bishop Rd		1100	6		187	6					F		X				X	186 COMM GO UP TO 40" METROCAST GO UP TO 52" COMCAST GO AT 64"
72 Bishop Rd		1100	5		187	5					F		X				X	METROCAST UP TO 52" COMCAST GO AT 64"
73 Bishop Rd		1100	4		187	4					F		X				X	TEL TO GO TO 76" COMCAST GO AT 64"
74 Bishop Rd		1100	3		187	3					F		X				X	TEL TO GO TO 76" COMCAST GO AT 64"
75 Bishop Rd		1100	2		187	2					F/R		X				X	TEL TO GO TO 76" COMCAST GO AT 64" Added riser 9/25/20 JMD

Licensee to complete bold italicized areas only

* ATT: F=Fiber C= Copper or Coaxial PS= Power Supply R= Riser Pole

Revised: 3/16/2015

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
d/b/a EVERSOURCE ENERGY
Pole Make- Ready Work Charges

Date of Survey : November 6, 2019

PAGE 16 of 17

Total Poles Surveyed: _____ Total poles Requiring Make-Ready Work _____ Telco: _____ Eversource: _____

FIELD SURVEY / MAKE-READY WORK FORM																
LICENSEE INFORMATION					FAIRPOINT INFORMATION					EVERSOURCE INFORMATION						
Application #		LBFT-05			Work Order #					Work Request #		3315399 / 91920896				
Company Name		Comcast of NH/ME Inc.			Application #					ALA #		ALA-317				
Surveyor Name		DAVE TESSIER			Exchange Code					AWC		41-Tilton				
Surveyor Phone #		(603) 327-5501			State Code					Municipality		Belmont				
					Surveyor Name		J ROBINSON			Surveyor Name		D SIMKINS				
STREET		TELEPHONE		ELECTRIC		Pole			*ATT		Ownership			Make-Ready		REMARKS
POLE LOCATION	RTE	POLE	RTE	POLE	SIZE	BIRTH MARK	HEIGHT OF ATTCH	F, C, P.S., RISER	FO	JO	TO	JU	Yes	No		
76	Bishop Rd	1100	1	187	1			F							DUE TO 155KV/35KV LINE XING CANNOT ATTACH	
77	Mile Hill Rd c/o Old Ladd Hill Rd & Bishop Rd	110	47	18	49			F/R		X				X	***DO NOT LICENSE*** TEL TO MOVE TO 76" COMCAST GO AT 64" Added riser 9/25/20 JMD	
78	Mile Hill Rd	110	46	18	48			F		X			X/N C		REPLACE 35' POLE W/45' POLE -- T+5	
79	Mile Hill Rd	110	45	18	47			F		X			X/N C		REPLACE 40' POLE W/45' POLE -- T+5	
80	Mile Hill Rd	110	44	18	46			F		X				X	TEL TO MOVE TO 76" COMCAST GO AT 64"	

Licensee to complete bold italicized areas only

* ATT: F=Fiber C= Copper or Coaxial PS= Power Supply R= Riser Pole

Revised: 3/16/2015