

EXHIBIT “A”

From: [McClure, Jeffrey](#)
To: [Countie, Chris](#); [Webster, Gary](#)
Cc: [Delude, Jim](#)
Subject: RE: Dame Well Cleaning Update
Date: Thursday, October 06, 2011 3:51:25 PM

Gary and Chris,

The cleaning has been going well and specific capacity of the well has been restored to original 1983 levels. The largest concern noted is that the static groundwater level is approx. 8 feet lower today than in 1983.

Surging and pumping the well will end tomorrow. Although not confirmed by Maher, we expect the pump and motor to be back on site mid-week. This may allow for chlorinating and flushing of the well and taking a sample at the end of next week.

I have not yet received a quote from Maher regarding the motor leads replacement cost. The pump was found in excellent shape.

I will keep you informed as information presents itself.

Thanks,
Jeff

From: Countie, Chris [mailto:chris.countie@PENNICHUCK.com]
Sent: Friday, September 23, 2011 8:37 AM
To: McClure, Jeffrey; Webster, Gary
Cc: Delude, Jim
Subject: RE: Dame Well Cleaning Update

Jeff,

We will need to isolate the Dame well and adjust the chemical pacing for the Ducharme well. If Dennis is certain he will be there on Tuesday or Wednesday, we will make the necessary arrangements on Monday.

Chris

Chris Countie

Water Supply Manager

Pennichuck Water Works, Inc.

25 Manchester St.

Merrimack, NH 03054

(603) 913-2372