

Request DOE 1-004:

Reference Schedule CGKS-2, Circuit 56X1 – Convert Route 125 Kingston, at Bates 1530-1532. It appears from the project description and justification (at Bates 1532) that this project was undertaken to supply a new commercial development.

- a. Please explain why this project was classified as non-growth on Schedule CGKS-1, p. 2 of 3, line 19, when Schedule CGKS-2, p. 1514 of 2741 (Bates 1532) states that the work is being performed to accommodate new commercial development in the Kingston area.
- b. Please provide the completion date for the new commercial development consisting of “three buildings with 1200 amp service each.”

Response:

Part a:

Growth related projects consist of line extensions, new customer services, customer transformers and customer meters used to directly service known new load.

System capacity increases are categorized non-growth projects because the project is not only designed to provide capacity to known load, but also capacity to serve load growth in the future.

Part b:

The first building of the commercial development was completed in August 2022.