

**STATE OF NEW HAMPSHIRE**  
**BEFORE THE**  
**NEW HAMPSHIRE PUBLIC UTILITIES COMMISSION**

**DOCKET NO. DE 24-070**  
**REQUEST FOR CHANGE IN RATES**

**DIRECT TESTIMONY OF**  
**Lavelle A. Freeman, Jennifer A. Schilling, Elli Ntakou,**  
**Gerhard Walker, and Paul R. Renaud**  
*Distribution System Planning and Solutions*

**On behalf of Public Service Company of New Hampshire**  
**d/b/a Eversource Energy**  
**June 11, 2024**

**TABLE OF CONTENTS**

**I. INTRODUCTION..... 1**

**II. DISTRIBUTION SOLUTIONS PLAN (“DSP”)..... 12**

**III. CURRENT STATE OF THE SYSTEM ..... 14**

**IV. DEMAND FORECAST ..... 20**

**V. PROJECT PLANNING STANDARDS AND PROCESS ..... 32**

**VI. FIVE-YEAR INVESTMENT OVERVIEW ..... 43**

**VII. CONCLUSION ..... 64**

**STATE OF NEW HAMPSHIRE**  
**BEFORE THE NEW HAMPSHIRE PUBLIC UTILITIES COMMISSION**  
**DIRECT TESTIMONY OF LAVELLE A. FREEMAN, JENNIFER A. SCHILLING,**  
**ELLI NTAKOU, GERHARD WALKER, AND PAUL R. RENAUD**  
**PETITION OF PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE**  
**d/b/a EVERSOURCE ENERGY**  
**REQUEST FOR CHANGE IN RATES**

**June 11, 2024**

**Docket No. DE 24-070**

---

1 **I. INTRODUCTION**

2 *Lavelle A. Freeman*

3 **Q. Please state your name, position, and business address.**

4 A. My name is Lavelle A. Freeman. I am the Director of Distribution System Planning  
5 for Eversource Energy. My business address is 247 Station Ave, Westwood,  
6 Massachusetts 02090.

7 **Q. What are your principal responsibilities in your position?**

8 A. I am responsible for overseeing distribution system planning and distributed energy  
9 resource (“DER”) interconnection activities in Eversource’s service areas in  
10 Connecticut, Massachusetts and New Hampshire. In this proceeding, I am testifying  
11 on behalf of Public Service Company of New Hampshire (“PSNH” or the “Company”).

1 **Q. Please describe your educational background and professional experience.**

2 A. I earned a Bachelor of Science degree in Electrical Engineering from the University of  
3 Alabama. Subsequently, I earned a Master of Science degree in Electrical Engineering  
4 with Power Systems concentration from the University of North Carolina at Charlotte  
5 and earned a Master of Science degree in Computer Engineering from North Carolina  
6 State University. I joined the IEEE Power Engineering Society while in graduate  
7 school and have been on the ANSI C84.1 Standard Committee since 2019.

8 I started my power systems career as an R&D Engineer at ABB Corporate Research in  
9 Raleigh, NC, where I devised innovative new products, algorithms and solutions to  
10 improve the value and efficiency of transmission and distribution product offerings  
11 within ABB Power T&D Inc. Thereafter, I joined the ABB Utility Consulting group  
12 in Raleigh, NC as a Senior Consulting Engineer where I performed system studies in  
13 distribution and transmission planning for utility customers, worked with customers to  
14 implement changes, and developed and supported power systems software applications  
15 that improved the efficiency, marketability, and cost-effectiveness of the group.

16 From 2003 to 2013, I was a Senior Engineer and then a Principal Engineer at General  
17 Electric Energy in Schenectady, NY, where I led consulting studies in distribution  
18 planning and analysis, power systems engineering, equipment applications, smart grid  
19 initiatives, and renewables impact and contributed to development of new products and  
20 technology for various General Electric Energy businesses. From 2013 to 2016, I was  
21 Manager of Transmission and Distribution at General Electric Energy Consulting

1 where I directed a broad spectrum of client activities in the T&D space, with emphasis  
2 on power systems operation and planning, equipment application, renewables impact,  
3 and systems analysis. From 2016 through 2020, I was Technical Director at General  
4 Electric Energy Consulting in Schenectady, NY. In this position, I led project teams  
5 and developed business opportunities in the distribution space with emphasis on DER  
6 integration, microgrid design, grid modernization, reliability, power quality, and  
7 resiliency. I developed and led execution of over \$5M in distribution-related projects  
8 in New York, New Jersey, and Massachusetts. I also successfully completed four  
9 ground-breaking New York Prize Stage 2 microgrid design projects and managed the  
10 peer research consortium working extensively with distribution planners and engineers  
11 in investor-owned, municipal and cooperative utilities all across the country. In 2020,  
12 I joined Eversource Energy as Director, Distribution System Planning.

13 **Q. Have you previously testified before the New Hampshire Public Utilities**  
14 **Commission (“Commission”)?**

15 A. Yes, I have testified before the Commission in the Company’s Least Cost Integrated  
16 Resource Planning proceeding (Docket No. DE-20-161).

17 **Q. Have you previously testified before any other regulatory body?**

18 A. Yes, I have testified before the Massachusetts Department of Public Utilities and the  
19 Connecticut Public Utilities Regulatory Authority numerous times, including base  
20 distribution rate proceedings for the Company’s affiliates.

1           ***Jennifer A. Schilling***

2           **Q.    Please state your name, position, and business address.**

3           A.    My name is Jennifer A. Schilling. I am Vice President of Grid Modernization for  
4           Eversource Energy. My business address is 247 Station Drive, Westwood,  
5           Massachusetts 02090.

6           **Q.    What are your principal responsibilities in your position?**

7           A.    As Vice President of Grid Modernization, I am responsible for the Company's grid  
8           modernization development, as well as developing strategies to increase the capacity  
9           of the Company's distribution system to optimize the integration of DERs, while  
10          improving the safety, security, reliability, and cost-effectiveness of the system.

11          **Q.    Please describe your educational background and professional experience.**

12          A.    I graduated with a Bachelor of Arts degree in environmental science and political  
13          Science from Barnard College, Columbia University in 1995. In 2001, I earned a  
14          Master of Business Administration from Duke University. From 2001 to 2008, I held  
15          several positions at Reliant Energy in Houston Texas, ending my tenure in the position  
16          of Director, Corporate Strategy. In 2008, I joined the Northeast Utilities System as the  
17          Director of Business Planning for Western Massachusetts Electric Company  
18          ("WMECO"). I subsequently accepted the role of Director, Asset Management for  
19          WMECO and then Director, Distribution Engineering for Eversource, prior to  
20          assuming my current role.

1 **Q. Have you previously testified before the Commission?**

2 A. Yes, I have testified before the Commission in the Company's most recent base  
3 distribution rate case, Docket No. DE 19-057.

4 **Q. Have you previously testified before any other regulatory body?**

5 A. Yes, I have testified before the Massachusetts Department of Public Utilities numerous  
6 times, including in support of the Company's affiliate's grid modernization plan  
7 (D.P.U. 21-80 and electric sector modernization plan (D.P.U. 24-10).

8 *Elli Ntakou*

9 **Q. Please state your name, position, and business address.**

10 A. My name is Elli Ntakou. I am Manager of System Resiliency and Reliability at  
11 Eversource Energy. My business address is 247 Station Drive, Westwood, MA 02090.

12 **Q. What are your principal responsibilities in your position?**

13 A. As the Manager of System Resilience and Reliability Planning, I am responsible for  
14 Eversource's reliability and resilience programs for its electrical infrastructure. The  
15 Company's efforts focus on assessing a wide portfolio of reliability and resilience  
16 solutions and prioritizing, optimizing, and granularly targeting these solutions to its  
17 transmission and distribution grid needs to be based on historical data, data forecasts,  
18 and engineering models.

1 **Q. Please describe your educational background and professional experience.**

2 A. I graduated from Boston University College of Engineering with a Master of Science  
3 and a PhD, both in Systems Engineering. Subsequently, I worked for ESAI Power  
4 LLC, leading their Northeast wholesale power market modeling efforts. From 2018 to  
5 July 2022, I was employed by Quanta Technology, in various positions, most recently  
6 as Senior Advisor. As part of my role, I advised a breadth of clients in the power sector  
7 on various topics including resilience and reliability, non-wires alternatives, storage  
8 use-cases and integration, grid modernization and scenario planning. In July 2022, I  
9 joined Eversource as the Manager of System Resilience and Reliability Planning.

10 **Q. Have you previously testified before the Commission**

11 A. Yes, I have previously provided testimony to the Commission in Docket No.  
12 DE-23-021.

13 **Q. Have you previously testified before any other regulatory body?**

14 A. Yes, I have testified before the Massachusetts Department of Public Utilities numerous  
15 times, including in support of the Company's affiliate's electric sector modernization  
16 plan (D.P.U. 24-10).



1           ***Gerhard Walker***

2           **Q.    Please state your name, position, and business address.**

3           A.    My name is Gerhard Walker. I am Manager for Advanced Forecasting and Modeling  
4           for Eversource Energy and its operating companies, including PSNH. My business  
5           address is 247 Station Drive, Westwood, Massachusetts 02090.

6           **Q.    What are your principal responsibilities in your position?**

7           A.    As the Manager for Advanced Forecasting and Modeling, I oversee the Company's  
8           system planning forecasts. The Company's efforts focus on the development of  
9           forecasts that provide short- and long-term visibility. I further oversee System  
10          Plannings Non-Wires Alternatives Framework and Modeling Capabilities and the  
11          Company's integrated energy planning efforts.

12          **Q.    Please describe your educational background and professional experience.**

13          A.    I hold a Doctorate in electrical engineering from University of Stuttgart, Germany. I  
14          began my career in 2013 at the Netze BW, Germany's third largest distribution system  
15          operator. While at Netze BW, I led research and development efforts into probabilistic  
16          forecasting, advanced system planning, and electric vehicle grid integration.  
17          Additionally, I oversaw efforts with the Association of German Energy and Water  
18          Industries to align DSO objectives with the automotive industry on issues regarding  
19          charge specifications and load management, as well as ELT coordination across all  
20          Netze BW subsidiaries on grid modification topics. In 2016, I joined General Electric

1 Current as the Director for Grid Solutions in Boston, to develop distribution use cases  
2 for virtual power plant aggregation of DERs. In 2017, I became the Director for  
3 Product Management at Opus One Solutions, a Canadian Utility Software supplier,  
4 where I led the scaling up of software solutions and successful customer acquisitions  
5 including HECO, SCE, Ameren, as well as expansions into the UK and Germany. I  
6 joined Eversource Energy in 2020 as a Principal Engineer in System Planning.

7 **Q. Have you previously testified before the Commission?**

8 A. Yes, I have testified before the Commission in the Company's Least Cost Integrated  
9 Resource Planning proceeding (Docket No. DE-20-161).

10 **Q. Have you previously testified before any other regulatory body?**

11 A. Yes, I have testified before the Massachusetts Department of Public Utilities numerous  
12 times, including in support of the Company's affiliate's base distribution rate case  
13 (D.P.U. 22-22) and its electric sector modernization plan (D.P.U. 24-10).

14 ***Paul R. Renaud***

15 **Q. Please state your full name and business address.**

16 A. My name is Paul R. Renaud. My business address is 247 Station Drive, Westwood,  
17 Massachusetts 02090.

1 **Q. By whom are you employed and in what capacity?**

2 A. I am the Vice President of Engineering for ESC, which provides centralized corporate,  
3 financial and engineering services to the operating subsidiaries of Eversource Energy.  
4 In this position, I am currently responsible for distribution engineering and design,  
5 single pole administration and distribution network and underground systems  
6 engineering for Eversource Energy's operating utility subsidiaries in Massachusetts  
7 and New Hampshire, including PSNH.

8 **Q. Please briefly summarize your educational background and business experience.**

9 A. I graduated from the University of Bridgeport in Bridgeport, Connecticut with a  
10 Bachelor of Science Degree in Electrical Engineering. I subsequently received a  
11 Master of Science Electrical Engineering, Power Systems degree from Northeastern  
12 University in Boston, Massachusetts. I am a registered Professional Engineer in the  
13 State of Massachusetts. From 2000 through 2011, I worked for National Grid USA in  
14 Waltham, Massachusetts, where I held lead engineering roles for Transmission Market  
15 Development and Transmission Regulation and Policy areas in 2001 through 2004. In  
16 2005, I became the Manager for Transmission Asset Strategy and in 2008 through 2011  
17 held the position of Vice President of Transmission Asset Management and managed  
18 the company's transmission assets in New York and New England. Beginning in 2011,  
19 I worked for Vermont Electric Power Company, where I served as Director of System  
20 Planning, Engineering, and Telecommunication. I provided strategic and day-to-day  
21 direction on all engineering and planning activities related to Vermont's high voltage

1 transmission system. In March 2014, I was hired by Eversource (then Northeast  
2 Utilities) as Vice President of Massachusetts Engineering. In 2018, I accepted the  
3 position as Vice President, Engineering, for the Eversource Energy electric operating  
4 subsidiaries in Connecticut, Massachusetts and New Hampshire.

5 **Q. Have you previously testified before the New Hampshire Public Utilities**  
6 **Commission?**

7 A. No, I have not previously testified before the Commission.

8 **Q. Have you previously testified before any other regulatory body?**

9 A. Yes. I have sponsored testimony before the Massachusetts Department of Public  
10 Utilities in several proceedings including NSTAR Electric Company's 2017 and 2022  
11 base distribution rate proceedings.

12 **Q. What is the purpose of this joint testimony?**

13 A. This joint testimony presents an illustration of the Company's comprehensive  
14 forecasting and planning process to position the PSNH transmission and distribution  
15 system to meet the needs of customers both from a reliability and resiliency  
16 perspective. The aging infrastructure, regional customer growth, and adoption of DERs  
17 and electric vehicles, will require significant upgrades in substations, distribution and  
18 transmission lines necessary to support customer demand over the long term. In that  
19 regard, this testimony and the attached Distribution Solutions Plan ("DSP") is designed

1 to provide insight into the Company’s analytical approach to assess total demand and  
2 system need over the next ten years.

3 Second, this testimony also presents the Company’s projected capital budget for the  
4 period 2025-2029. As discussed in the Joint Testimony of Douglas W. Foley, Robert S.  
5 Coates, Jr. and Douglas P. Horton (“Case Overview Testimony”), the projected capital  
6 budget is used to establish the annual cap on capital additions included in the annual  
7 K-bar adjustment under the proposed Performance Based Ratemaking (“PBR”) plan.

8 **Q. Are you sponsoring any attachments through your testimony?**

9 A. Yes. We are jointly supporting the Company’s DSP (Attachment ES-DSP-1).

10 **Q. How is your testimony organized?**

11 A. Section I of this testimony is the introduction. Section II provides an overview of the  
12 Company’s DSP. Section III provides an overview of the current state of the  
13 distribution system. Section IV provides a summary of the Company’s demand  
14 forecasting process and results. Section V provides an overview of the Company’s  
15 project planning standards and process. Section VI provides an overview of the  
16 Company’s proposed capital and grid enhancement proposals. Section VII is the  
17 conclusion.

1 **II. DISTRIBUTION SOLUTIONS PLAN (“DSP”)**

2 **Q. Please discuss the purpose of the DSP**

3 A. The Company is committed to providing safe, reliable, resilient, and cost-efficient  
4 electric service to New Hampshire customers. In furtherance of that objective, the DSP  
5 provides a comprehensive discussion of the current state of the Company’s distribution  
6 system; the forecast of system demand over the next ten years; and a summary of the  
7 Company’s solutions to address system needs. In recognition of the importance that  
8 electricity has in the daily lives of customers (both residential and business), the DSP  
9 sets forth the Company’s analysis and approach to the replacement and upgrade of  
10 aging infrastructure to support reliability and infrastructure development to address  
11 increasing localized demand due to population growth, economic development and  
12 electrification. The DSP is also designed to maintain safe and reliable service at a  
13 measured pace of investment and to develop targeted investments to address extreme  
14 weather impacts that are becoming more prevalent.

15 **Q. Please provide an overview of the DSP.**

16 A. Section 1 of the DSP is an executive summary and highlights the key areas of  
17 investment that the Company must undertake to continue to deliver safe and reliable  
18 electric service to customers. Section 2 presents an overview of the current state of the  
19 distribution system, including the challenges the Company must address. In Section 2,  
20 the Company also provides a region-by-region summary of capacity and reliability  
21 issues. The distribution planning process is described in Section 3 of the DSP. This

1 section includes an overview of the integrated planning process, the bulk substation  
2 capacity planning process, substation asset condition assessments, as well as  
3 distribution feeder capacity, reliability, and resiliency tools, process, standards, and  
4 criteria. As discussed above, Section 4 provides an overview of the Company's 5- and  
5 10-year demand forecast.

6 In Section 5, the Company discusses the planning solutions to address the capacity,  
7 aging infrastructure, and reliability challenges discussed in the DSP. This section also  
8 includes a discussion of proposed grid modernization, Company-owned solar,  
9 resiliency, and co-optimized reliability enhancements that, with the Commission's  
10 authorization, could be implemented in the next five years to provide enhanced benefits  
11 to customers and modernize the PSNH distribution system to provide safe, reliable, and  
12 cost-efficient service while meeting the evolving needs of customers. The Company's  
13 five-year capital budget is summarized in Section 6. This section also describes the  
14 customer benefits that will be achieved under the Company's five-year investment  
15 plan. All investment plans include a level of uncertainty, which the Company also  
16 discusses in Section 6. Section 7 is the DSP conclusion and Section 8 is the Appendix,  
17 which includes a Glossary, list of acronyms, historical substation loads, and a reference  
18 table of figures and tables included in the DSP.

1 **III. CURRENT STATE OF THE SYSTEM**


2 **Q. What is the state of the current distribution system?**

3 A. The current state of the distribution system reflects an ongoing evolution from a stable  
4 system that relied on centralized generation to a more dynamic grid that integrates  
5 distributed energy resources such as generation from solar and wind, grid-scale energy  
6 storage, flexible loads and demand response, as well as increased electric demand, new  
7 technologies like electric vehicles, and higher requirements for reliable and resilient  
8 service. As discussed in more detail in Section 2 of the DSP, the Company has  
9 delivered overall consistent reliable service based on System Average Interruption  
10 Duration Index (SAIDI), System Average Interruption Frequency Index (SAIFI) and  
11 Customer Average Interruption Duration Index (CAIDI) metrics. In addition, the  
12 Company has implemented distribution automation devices and TripSavers to drive  
13 improved reliability. Despite this success from recent system improvements, there are  
14 still many challenges that are inherent to an aging, overhead distribution system, with  
15 long radial feeders operating at multiple voltages over difficult terrain and traversing  
16 through heavily treed areas, especially in light of progressing climate change and  
17 associated weather events. Several circuits have limited fault current availability  
18 making them difficult to sectionalize, and many distribution assets are nearing the end  
19 of useful life.

20 Today, the Company is the primary electric provider for 211 towns and cities, covering  
21 approximately 5,630 square miles across New Hampshire. The Company provides



1 service to approximately 539,000 customer accounts. Across the five planning regions,  
2 the 50 bulk distribution substations shown in the below map serve customers residing  
3 in an average area of almost 200 square miles per substation.



4

1 The distribution system includes a total of 123 substations (including the 50 bulk  
2 distribution substations discussed above) with an aggregate nameplate capacity of 3.9  
3 GW, as well as 186 substation transformers, 12,300 circuit miles of overhead lines,  
4 2,100 circuit miles of underground lines, and 287,900 service transformers. Of the 186  
5 substation transformers, almost 70% are greater than 20 years old, and 15% are older  
6 than 60 years. Of the 475 distribution station breakers currently serving PSNH  
7 customers, over 75% are older than 10 years old, and 12% are over 50 years old.

8 For much of the last decade, peak load throughout New Hampshire has generally been  
9 flat as economic growth was offset by two primary load-reduction drivers: (1) the  
10 energy efficiency programs run by the Company and (2) adoption of solar. The  
11 NHSaves program efforts are primarily focused on reducing load on the electric and  
12 natural gas distribution systems. The current 2024-2026 plan expands the prior active  
13 demand response pilots into full programs with larger budgets to further target load  
14 curtailment during the ISO-NE system peak.

15 System-wide economic growth continues to be offset by energy efficiency and solar.  
16 However, more recently, localized economic and customer growth has outpaced the  
17 achievable energy efficiency reductions and some areas are experiencing capacity  
18 constraints at substations and transformers. Additionally, New Hampshire is beginning  
19 to experience increases in electrification of heating and transportation sectors. In 2023,  
20 the state saw a 3,487 increase in electric vehicles. Over the next few decades, the

1 Company anticipates that the state will see further increases in electric vehicle  
2 adoption. This is especially true for electric vehicle charging to meet the needs of  
3 travelers visiting the state from neighboring jurisdictions.

4 Considering aggregate demand from these various sources, available capacity in certain  
5 areas of the existing network has already been maximized. As shown in Section 8.2 of  
6 the DSP, seven substations are currently at or near maximum capacity.

7 During the past few years, the Company has taken several steps to modernize its system  
8 to ensure safe and reliable service. The Distribution Automation program and  
9 associated telecom network is the foundational layer of remote control and monitoring  
10 that is used by control room operators to operate the distribution system safely, reliably,  
11 and optimally. This network of field devices consists of over 1,900 “smart” switches.  
12 These devices provide status and measurement information of the distribution grid. In  
13 the past 10 years, 10 new radio towers were built and commissioned. These towers  
14 increase the data radio coverage by 200 percent. In addition, a standard equipment  
15 design for the use of cellular communications was also established. This provided an  
16 additional option for areas where radio coverage was not sufficient. However, the  
17 communications network continues to have a need to ensure that proper coverage,  
18 reliability, and data throughput are available for the field devices that are required to  
19 operate the grid safely, reliably, and optimally.

1 The Company is utilizing advances in technology to build and operate a smarter,  
2 flexible, and resilient grid. The changing nature of the grid with increased automation  
3 driving operational complexity requires new approaches. The new technologies the  
4 Company is investing in provide improvements in (1) visibility and situational  
5 awareness; (2) automated reconfiguration; (3) voltage management; (4) storm  
6 response; (5) asset management; and (6) data analytics.

7 **Q. What are the challenges that the current distribution system faces?**

8 A. While investments to maintain the network to ensure the safe and reliable operation of  
9 the Company's existing assets continue to be made, the need for such investments is  
10 increasing. The Company has identified challenges discussed in the DSP. Some of the  
11 challenges include:

- 12 • **Aging infrastructure:** Aging equipment, such as transformers, switchgear,  
13 conductor, cables, insulators, and related ancillary equipment, can lead to  
14 decreased reliability, safety risks, reduced capacity, and lower system  
15 efficiency as their condition worsens.
- 16 • **Voltage regulation/Power quality:** Maintaining appropriate voltage levels  
17 and power quality is crucial for the distribution grid's reliable and efficient  
18 operation. High load conditions can cause voltage to decrease, and high  
19 concentrations of generation can cause voltage to increase. Introducing  
20 generation throughout the distribution system, particularly intermittent

1 generation (e.g., solar, wind), impacts the voltage profile and power quality  
2 often in unpredictable ways.

3 • **Connecting renewables:** Continued investment in the Company’s distribution  
4 infrastructure is necessary to ensure that DERs can be safely and reliably  
5 connected and operated to handle reverse power flow from the distribution to  
6 transmission system.

7 • **Pockets of Significant Customer Growth:** Migration of customers into the  
8 Eastern, Southern, and Central regions of New Hampshire has resulted in  
9 significant new construction and step loads on the system, requiring the need  
10 to buildout and upgrade infrastructure.

11 • **Increased load from electrifying heat and transportation:** The growth in  
12 electricity consumption from electric transport and heating will impact the  
13 system over time, potentially leading to overloading in certain areas.  
14 Overloading can cause asset damage, premature aging of assets, and the  
15 inability to manage contingencies, leading to reliability issues.

16 • **Increasing resilience:** The more frequent and severe weather events, like high  
17 winds, snowstorms, icing events, and river and coastal flooding, as well as  
18 more extreme temperature days, all pose risks to grid infrastructure and  
19 customer service.

1 **IV. DEMAND FORECAST**

2 **Q. What is the purpose of the 5- and 10-year electric demand forecast?**

3 A. The five- and ten-year electric demand forecast described in Section 4 of the DSP (Att.  
4 ES-DSP-1) is a critical input into the distribution planning process. The basic goal of  
5 planning is to provide orderly expansion of the equipment and facilities to meet future  
6 system demand with acceptable system performance – prior to reliability issues arising.  
7 The key objectives include building sufficient infrastructure capacity and technology  
8 capabilities to meet instantaneous demand and manage instantaneous demand to be  
9 sufficiently below the infrastructure equipment capacity acceptable limits; satisfy  
10 power quality/voltage requirement within applicable limits; provide adequate  
11 availability to meet customer requirements; and deliver power with required frequency.  
12 Effective planning accounts for lead time to deploy distribution assets in developing  
13 solutions for performance requirements. In other words, we need to plan because it  
14 takes time to build capacity on the system. Currently, it can take more than ten years  
15 to build transmission, and well over five years to place a bulk distribution substation in  
16 service. This includes time required to: perform field audits and environmental  
17 evaluation; develop engineering designs and cost estimates; procure equipment  
18 (current lead time for power transformers and switchgear is over two years); and obtain  
19 siting/permitting approvals. Given these construction lead times, the Company must  
20 conduct a 5- and 10-year forecast to ensure projects are initiated in a timely manner so  
21 as to be in-service by the time of need. Said differently, if the Company fails to ensure

1 sufficient capacity is available to meet the 10-year forecast, considering all applicable  
2 timelines, this can result in system capacity deficits, equipment overloads, and loss of  
3 service to customers in the future.

4 **Q. What are the main components of the 5- and 10-year electric demand forecast?**

5 A. The 5- and 10-year forecast is comprised of four load growth components, two load  
6 reducing components, and battery storage systems. The four load growth components  
7 are the underlying trend load, load growth that is uniformly spread across the system  
8 relative to the economic development of each region. Added to the trend load, electric  
9 vehicles are considered with their on peak charging contributions, as well as step loads,  
10 or large, new customer additions, such as factories, residential developments, or high  
11 voltage fast chargers. Lastly, the Company forecasts building heating electrification.  
12 However, until the system is winter peaking, heating electrification does not contribute  
13 to the peak load and as such, is not yet reflected in the Company's 10-year forecasted  
14 peak. Depending on customer load make up in a given region, heating electrification  
15 through heat pumps can add to summer loads as whole house cooling is introduced.  
16 Modeling these impacts is critically important to providing long term reliable service.  
17 Reductions of the load forecast are driven by impacts from the Company's energy  
18 efficiency programs, as well as firm reductions of the peak load at time of peak driven  
19 by distributed solar, both ground-mounted and rooftop installed. Storage systems are  
20 also forecasted, both standalone and co-sited with solar, for the 5- and 10-year forecast.

1 **Q. Which of the components of the 5- and 10-year electric demand forecast drive**  
2 **demand growth?**

3 A. The key driver of gross demand increase in the 5- and 10-year forecast is about 49 MW  
4 of step loads, which almost exclusively appear in the Eastern and Southern regions,  
5 driven by increases in customer load in the population centers of the Merrimack River  
6 Valley (Manchester and Nashua) and in the Seacoast region (Portsmouth, Dover, and  
7 Rochester). Step loads represent large, new load additions to the Company's  
8 substations which the Company has direct customer information on, and for which it  
9 has received load letters. These step loads can include new commercial and industrial  
10 ("C&I") development, upgrades to existing customer sites, large multi-unit residential  
11 developments, battery storage, or electric vehicle charging. As discussed in Section  
12 5.1.1 of the DSP, all station upgrades considered by the Company to address load  
13 constraints are driven directly by confirmed and certain step loads, as fulfillment of  
14 direct customer requests are the priority. The Company also forecasted 12 MW of  
15 potential residential electric vehicle charging across all regions consistent with the  
16 system peak. However, the electric vehicle loads are significantly more evenly spread  
17 across the territory and as a result, from a local distribution system impact perspective,  
18 are less acute in driving demand growth at a bulk station level compared to the step  
19 loads.



1 **Q. Please explain the process around developing the 5- and 10-year electric demand**  
2 **forecast.**

3 A. Consistent with the Company’s typical electric demand forecast methodology, the first  
4 step in each forecasting cycle is an assessment of net station peaks at each distribution  
5 bulk station in the Company’s territory. The Company commences its forecasting  
6 process annually during the summer peak month where it monitors station peaks across  
7 all bulk substations and records these net peaks (i.e., demand that is actually measured).

8 The second step is to disaggregate the net station peak to separate out historical gross  
9 load peak and the historical impact of solar, switching operations, weather conditions,  
10 or other factors which might have contributed to a higher, or lower, net station reading.  
11 Over the last 15 years, net peaks have been relatively flat to declining because the  
12 impacts of energy efficiency and photovoltaics (“PV”) have offset underlying customer  
13 demand growth from new customers and economic growth. This effect has caused net  
14 peaks to have consistently shifted to later in the day where solar offset is less  
15 pronounced. If only the net demand were modeled, as opposed to gross load, the  
16 Company’s modeling would miss the nuances of the effects of baseload and the various  
17 DERs, and the Company would be less able to project the effects on net demand of  
18 changes in customer growth or DER penetration going forward.

19 Once the historical gross load peak is determined, a weather normalized trend load  
20 forecast is created which utilizes a 90/10 weather assumption on a three-day rolling  
21 weighted temperature humidity index (“THI”). This ensures that forecasted load

1 reflects possible extremely hot and humid weather events and consequently ensures  
2 sufficient system capacity to serve customers during such conditions.

3 The Company then corrects this forecast for all known step loads which are ranked by  
4 certainty of the projects coming to fruition. For electric vehicles, travel and mobility  
5 data is collected at a zip code level and aggregated to bulk stations to provide station  
6 by station specific charging profiles for light duty electric vehicles (“LDV”). Medium-  
7 duty (“MDV”) and heavy-duty vehicles (“HDV”) are tracked through the step load  
8 process. Energy efficiency impacts are modeled based on currently approved energy  
9 efficiency programs. Demand response and behind the meter storage systems that  
10 consistently deliver peak demand reductions are captured in the trend forecast as they  
11 impact the recorded peaks and are therefore not separately modeled. Installed solar  
12 capacity is projected for both ground mounted and rooftop solar. PV generation (hourly  
13 solar output) is modeled using satellite-based irradiance data in combination with a  
14 probabilistic weather model to ascertain firm solar contributions to peak load. Once  
15 the forecast is completed in March of the following year, it is issued to the planning  
16 departments to conduct a review of all stations and projects based on the new forecast  
17 data.

18 In summary, each substation’s peak load forecast is a function of the substation’s  
19 historical peaks and the relevant service territory peak load history and forecast.  
20 Adjustments are made to individual substation forecasts for: (1) specific, identified

1 large development projects and expected changes in system configuration or operation  
2 that could not otherwise be predicted by the Company’s econometric forecasts or an  
3 individual substation’s share of those forecasts; (2) Company sponsored energy  
4 efficiency and PV installations which decrease the forecast; and (3) future electric  
5 vehicle charging which increase the forecast. The result of these adjustments yields  
6 the weather normalized, 90/10 net station peak load forecast.

7 **Q. Did the Company conduct any sensitivity analysis in the 5- and 10-year electric**  
8 **demand forecast? If not, please explain the Company’s rationale.**

9 A. No, the purpose of the 5- and 10-year forecast is to provide the Company with a  
10 capacity need assessment of its system that it can use to authorize and prioritize capital  
11 projects. As a result, the Company considers only the 90/10 net station load forecast  
12 with all its adjustments for electric vehicles, PV generation, Company-sponsored  
13 energy efficiency and step loads (for which it considers only those projects that are  
14 “certain” or have high confidence). Given project timelines for bulk stations range  
15 between 5-10 years, assessing sensitivities are not conducive to the process as they  
16 introduce unnecessary uncertainty in the short term. Further, the uncertainties in the  
17 forecast are minimal as all information is either based on known projects or state-  
18 approved programs. The Company selects a single demand scenario upon which it acts  
19 to ensure that imminently needed upgrades can be constructed in time to ensure reliable  
20 service for its customers.

1 **Q. Did the Company account for load growth in its forecast?**

2 A. Yes. The Company builds a 10-year econometric model based on the past 10 years of  
3 station peaks with 90/10 weather normalization and future economic indicators. This  
4 trend forecast reflects the growth of the underpinning load on the system today and  
5 load growth relative to the development of the economy. However, some load growth  
6 appears very localized and cannot be accurately spread across the system. The  
7 Company therefore incorporates projected new load additions, or step loads (typically  
8 representing single load increases of 500 kW or more such as new commercial and  
9 industrial development, upgrades to existing sites, large multi-unit residential  
10 developments, electrification, grid charging battery energy storage systems (“ESS”),  
11 and electric vehicle charging), to the Company’s substations forecast.

12 The Company also accounts for load growth from electric vehicles, including light,  
13 medium, and heavy-duty vehicles. Light duty vehicles are accounted for in the 10-year  
14 forecast using an adoption model in line with the state policy and mobility data, while  
15 medium- and heavy-duty vehicles vehicle charging, as well as HVDC charging stations  
16 for light duty vehicles, are tracked, and accounted for through the step load tracking  
17 process as these loads are significantly more localized and require a greater degree of  
18 certainty. Additionally, the Company accounts for load growth from heating  
19 electrification across its system. The Company has the ability to make local  
20 adjustments for municipalities that accelerate the deployment of electric vehicles, heat  
21 pumps, or solar installations in a specific region. In all cases, the Company assumes

1 full compliance with local laws, building codes, and ordinances, especially when new  
2 loads are introduced into the system.

3 **Q. How did the Company account for large load or step loads in its forecast?**

4 A. Typically, the Company will track projected incremental load increases at a bulk station  
5 level starting at the 500-kW threshold, depending on if the load addition is associated  
6 with a distribution non bulk station or a bulk substation. The challenge with step loads  
7 is that they are relatively large compared to other forecast components. Specifically  
8 for the Company in New Hampshire, step loads make up the majority of the gross  
9 forecast system-wide, and in the Eastern and Southern regions the percentage is  
10 significantly higher.

11 The Company acquires this information through detailed coordination with its national  
12 and strategic accounts and their respective customer representatives within the  
13 Company. Because these loads are driven directly by customer decisions, the Company  
14 is heavily reliant on customer-provided information to accurately model the impact on  
15 forecasted demand, both in terms of timing and magnitude. The majority of this  
16 engagement is handled by the Company's Strategic and National Account Executives  
17 to get an early indication of customer development plans, as well as the Company's  
18 Distribution Engineering teams who review the capacity requirements.

19 Step loads are the primary driver for substation capital investments undertaken by the  
20 Company, which in turn exposes the Company's capital plan to the risk of changes to

1 the developer projects – a canceled project could mean a substation upgrade is no  
2 longer needed in the near-term, or a last-minute change to add significant load can pull  
3 a substation need to earlier than the Company can feasibly build requisite infrastructure.

4 Step loads are categorized based on the level of certainty as follows:

- 5 • Certain: A work order signed, and payment has been received.
- 6 • Probable: Public statements have been made and permits requested, or other  
7 actions have announced the customers intention to the broader public making a  
8 withdrawal less likely.
- 9 • Possible: Customer is engaging with PSNH in earnest discussions about the  
10 project, distribution engineering is included, and some public statements have  
11 been made.
- 12 • Uncertain: Discussions happen only with strategic and national accounts and  
13 at a conceptual level.
- 14 • Forecasted: Assumed load potential based on state or local electrification  
15 objectives and customer goals.

16 The step load tracking process is updated as projects arise and are incorporated into the  
17 Company’s forecasts on a yearly basis. Currently, only loads that are “Certain” are  
18 included in the forecast; taken at 100% of rated capacity (or other capacity as indicated  
19 by the customer) and expected to be online by their PTO (“permission to operate”) date  
20 (usually in 2-3 years) to minimize the risk of projects dropping from the queue and  
21 requiring changes to the Company’s capital plan.

22 **Q. How did the Company account for heating electrification in the forecast?**

23 A. The Company monitors the development of the electric heating market in New  
24 Hampshire. In addition, the Company is seeking advanced forecasting capabilities to

1 model adoption curves in greater local detail. While the Company reviews electric  
2 heating as part of the 5- and 10- year forecast, the forecasted electric heating load in  
3 the 10-year horizon is not expected to be sufficient to make the winter peak surpass the  
4 summer peak. As a result, all peak forecast values described in the DSP and this  
5 testimony for the 5- and 10-year forecast are for summer peak only, and do not include  
6 an electric heating component.

7 **Q. How did the Company account for electric vehicle charging in its forecast?**

8 A. The Company analyzes: (1) system-level electric vehicle adoption; (2) conversion of  
9 internal combustions vehicles to electric vehicles; and (3) charging profiles and  
10 locations.

11 The Company utilizes mobility data in a travel model to determine the time during a  
12 day when electric vehicle charging is likely to coincide with the peak. The travel model  
13 uses advanced data analytics and GPS tracking data from cellular service and App  
14 providers to create travel profiles showing when, how many, and where vehicles  
15 terminate a trip. This then allows the creation of charging profiles for the Company  
16 with temporal and spatial resolution. One important consideration is that this is done  
17 by season (Winter, Spring, Summer and Fall) and day type (Weekdays (Monday-  
18 Thursday), Fridays, Weekend Days (Saturday-Sunday), and Holidays) to capture  
19 dynamics such as weekend and holiday travel.

1           These travel profiles, and the resulting charging profiles can be created at a zip-code  
2           level and then aggregated up to a substation, resulting in unique charging profiles by  
3           substation, based on the different customers and needs of the customers the station  
4           services.

5   **Q.   Did the Company account for technologies and programs that reduce electric**  
6   **demand in its forecast?**

7   A.   Yes. As discussed in Section 4.2 of the DSP, the Company’s forecast incorporates  
8       reductions in peak demand from energy efficiency and distributed PV generation. The  
9       Company also forecasts storage adoption in the 5- and 10-year forecast. The  
10      Company’s forecasting methodology includes all behind-the-meter (BTM) ESS that  
11      consistently (over multiple years) impact the station peaks and as such includes these  
12      storage systems in the forecast. The Company does not attribute any load reduction to  
13      co-sited or stand-alone front-of-the-meter (FTM) ESS as there are currently no  
14      mechanisms in place that would give the Company operational control over third party  
15      systems. Instead, large scale standalone and co-sited ESS are treated as step loads in  
16      the forecast if their interconnection agreement allows the system to charge during peak  
17      hours (see Section 4.2.6 of the DSP for a discussion of ESS).

18   **Q.   What are the key takeaways from the 5- and 10-year forecast and the planning**  
19   **implications for Eversource?**

20   A.   The Company’s 5- and 10-year forecast shows significant load growth in population  
21      centers in the Eastern and Southern planning regions. In these regions, the Company



1 may need to upgrade 4 substations driven by step loads. In addition to substation  
2 upgrades, more localized load growth will require distribution circuit capacity upgrades  
3 discussed in Section 5.1.2 of the DSP. In the Central region, pockets of new residential  
4 and C&I load growth due to migration from Massachusetts are resulting in overloaded  
5 step transformers and distribution substation transformers. Similar to the Central  
6 region, the Eastern region is also experiencing customer growth, as well as the  
7 challenges of aging infrastructure. In particular, in the Pease area rapid C&I load  
8 growth continues from the development of the pharmaceutical industry. Large towns  
9 with historic 4.16 kV systems require conversion to 12 kV, and some even require  
10 conversion to 34.5 kV systems. The Southern region is experiencing similar customer  
11 growth with pockets of new residential complexes, retail facilities, and warehouses  
12 along the Evergreen Parkway and I-93 Corridor, resulting in overladed step  
13 transformers and distribution substation transformers and requiring upgrades to higher  
14 distribution voltages.

15 In the Northern and Western regions, the load profile used to include vacation  
16 campsites that are transitioning to vacation homes, such as in the Lake Sunapee area.  
17 These regions also continue to experience substantial load demand from ski resorts and  
18 industrial load centers served by long radial circuits that can be severely impacted by  
19 lack of electrical strength and low short circuit fault currents. The town areas are served  
20 by overhead step transformers which are at or near overload conditions and downtown  
21 systems are near end of life.

1 In summary, the demand forecast projects in pockets of the state that will require  
2 significant system upgrades due to localized capacity constraints, even though the  
3 service territory as a whole is experiencing relatively limited load growth. As discussed  
4 further in Section 5.2, the Company must also undertake significant infrastructure  
5 upgrades in local areas to address reliability conditions and aging infrastructure.

6 **V. PROJECT PLANNING STANDARDS AND PROCESS**

7 **Q. Would you describe the Company's electrical power system planning criteria**  
8 **standards?**

9 A. The Company's Electric Power System ("EPS") Planning Criteria and Standards  
10 provide a consistent uniform approach to designing an efficient and reliable electric  
11 transmission and distribution system that provides the quality of service expected by  
12 our customers. As a regulated utility, the Company has an obligation to provide reliable  
13 service in accordance with applicable safety codes and regulatory requirements. The  
14 basic goal is to provide orderly, economic expansion of equipment and facilities to meet  
15 future system demand with acceptable system performance. The key objectives include  
16 to: build sufficient capacity to meet instantaneous demand; satisfy power  
17 quality/voltage requirements within applicable standards; provide adequate availability  
18 to meet customer requirements; and deliver power with the required frequency.

19 To meet these objectives, the transmission system is designed in accordance with  
20 NERC reliability standards, NPCC regional standards, and ISO-NE planning  
21 procedures. At the distribution level, the Company's Distribution System Planning

1 Guide (“DSPG”), along with reference procedure SYSPLAN-010 (Bulk Distribution  
2 Substation Assessment), establishes the Company’s criteria and guidelines for the  
3 planning and design of its bulk substation and electric distribution facilities. The  
4 Company must also comply with planning standards SYSPLAN-001 and  
5 SYSPLAN-015 (transmission system deficiencies) and mitigate the consequences of  
6 the N-1 and N-1-1 contingencies.

7 The scope of the Distribution System Planning Guide is comprehensive, including  
8 traditional planning considerations for expanding the system to avoid capacity, voltage,  
9 and reliability violations as well as advanced integrated planning concepts related to  
10 non-wires alternatives (“NWA”), ESS, other DER applications and probabilistic  
11 load/DER evaluation with electric vehicle adoption.

12 **Q. Would you please describe the Company’s bulk substation planning criteria?**

13 A. At the distribution level, it is the Company’s goal to have customer electric service  
14 automatically restored upon loss of supply to Bulk Distribution Supply Buses. In high  
15 load density areas, a higher degree of reliability is ensured by maintaining supply,  
16 without the loss of power, to Bulk Distribution Buses following an N-1 Contingency  
17 Condition.

18 The Company’s Bulk Distribution Substation Assessment Procedure, SYSPLAN-010  
19 and the DSPG established the Company’s criteria and guidelines for the planning and  
20 design of its bulk substation and distribution facilities, and sets forth the various

1 reliability criteria by which the capacity and reliability performance of the Company's  
2 supply systems are gauged, and how these assessments are conducted. SYSPLAN-010  
3 states that plans need to be developed to ensure that:

- 4 • Each distribution bus has at least two means of supply (primary and secondary).
- 5 • Upon loss of a source of supply, customer electric service is automatically  
6 restored.
- 7 • The number of bulk distribution buses with no power source because of a single  
8 contingency is minimized.

9 In the performance of system planning studies to establish the need for system  
10 upgrades, the Company employs detailed steady-state and dynamic electrical models  
11 of its transmission, substation and distribution systems using various tools, including  
12 PSS/E (Power System Simulator for Engineering) for transmission load flow and  
13 stability assessment, Synergi Electric for distribution analysis including DER impact,  
14 and PSCAD (Power Systems Computer Aided Design), for Electromagnetic Transients  
15 (EMT) analysis. The planning standards set forth in SYSPLAN-010 are those  
16 employed in the Company's overall assessment of its system.

17 In accordance with the planning standards set forth in the DSPG, under normal  
18 operating conditions and configurations (N-0), substation transformer loads should not  
19 exceed 75% of the normal rating and substation transformers; and under N-1  
20 emergency conditions involving loss of a bulk transformer, loads for remaining  
21 substation transformers should not exceed their LTE rating after implementation of the  
22 automatic bus restoral ("ABR") scheme. When actual or projected transformer loads

1 approach 95% of the normal rating (under normal operating conditions), there are two  
2 primary options available: (1) permanently transfer loads to other substations in the  
3 area, or (2) provide additional transformer capacity by installing a larger transformer,  
4 or additional transformers in the area.

5 **Q. Would you please describe the Company’s planning criteria for feeders and lines?**

6 A. The DSPG also states the criteria for designing and upgrading distribution feeders.  
7 There are different criteria for the feeders serving underground (“UG”) facilities,  
8 feeders serving overhead (“OH”) facilities, feeders supplying UG network systems, and  
9 distribution supply system (“DSS”) lines that function like transmission lines (to  
10 transfer load between stations), but at the distribution voltage level. The criteria dictate  
11 the percentage loading at which each category of feeder should be maintained.

12 As noted above, the DSPG and SYSPLAN-010 also define the planning criteria for  
13 NWA solutions and the use of ESS. The Company evaluates NWA solutions as  
14 alternatives to traditional distribution upgrade solutions and incorporates those  
15 alternatives where they meet suitability criteria, are technically viable, and justifiable  
16 on a benefit-cost basis.

17 **Q. Please describe the Company’s capital planning process, and decision-making**  
18 **process for distribution system capital investments.**

19 A. The Company’s planning and decision-making process is discussed in Chapter 3 of the  
20 DSP. As part of the Company’s Capital Planning process, the near-term forecast

1 informs capital planning for substation projects and helps prioritize investments based  
2 on immediate need. This is necessary to ensure that any proposed solution will be  
3 suitable to meet the near-term load.

4 Based on the system analysis results, the Company's planning engineers design and  
5 implement a variety of projects to resolve thermal/capacity, power quality/voltage,  
6 reliability, and stability violations where station and line equipment may be operating  
7 under conditions beyond their design limits. As part of this process, the Company  
8 generally applies several design concepts to resolve and mitigate issues identified in  
9 system analysis. Five of the more common design concepts include: reconfigure the  
10 system, upgrade existing equipment, add new equipment/capacity, construct or apply  
11 NWA solutions, and/or build a new substation (see Section 3.2.3 of the DSP for more  
12 information). The Company always considers the performance aspect of the solution  
13 alongside the total cost in choosing the most cost-effective solution that meets the need.

14 Typically, several solutions are developed for each capacity/reliability need and the  
15 process to select a final solution involves several groups and engineering disciplines  
16 which consider and compare a range of attributes for each alternative, including cost,  
17 reliability, constructability, and environmental impact. Once the comprehensive  
18 solution and/or solution alternatives are determined, the Company's project  
19 approval/construction process is used to initiate and implement a capital project. The

1 process is designed to ensure that the technical approach is sound, and resources are  
2 budgeted and allocated to facilitate successful and timely execution of the projects.

3 Substation and transmission projects are large, complex, multi-disciplinary projects  
4 that require many years of planning and engineering, in addition to regulatory approval  
5 for siting and permitting. A typical timeline from planning to in-service for distribution  
6 bulk substation projects includes 20-42 months of planning and studies, 24-36 months  
7 of siting and permitting, and 54-78 months of construction. This reinforces the need  
8 for developing and implementing a 10-year capital planning process, since a delay on  
9 any of these projects could result in years of risk from equipment operated above  
10 thermal limits – risks that only increase in severity as load grows.

11 In identifying, designing, and implementing upgrade solutions to resolve violations,  
12 increase capacity, and improve reliability, the Company relies on its existing reliability  
13 criteria and planning standards to guide the selection of technically viable solutions.  
14 These standards (1) provide a consistent uniform approach for planning and designing  
15 an efficient, reliable, and safe electric power system; and (2) facilitate efficient study,  
16 interconnection, and operation of DER on the Company's system. Ultimately, the goal  
17 for a system experiencing demand growth is to provide reliable service in accordance  
18 with applicable safety codes and regulatory requirements and to provide orderly,  
19 economic expansion of the equipment and facilities to meet future system demand with  
20 acceptable system performance.

1 To meet its obligations, the Company takes a bottoms-up approach to integrated  
2 planning, with an annual cyclical planning cycle that starts with forecasting the net load  
3 on the system, i.e., the demand accounting for offsets due to DER production. As part  
4 of this process, the Company conducts a yearly analysis to build a 90/10 weather-  
5 normalized load forecast based on an econometric model for each of its operating  
6 companies, as described above. This forecast is conducted on a yearly basis to support  
7 the business-planning process.

8 As discussed in Section 3.2.2 of the DSP, to ensure the power system is adequately  
9 planned, three scenarios are typically considered when planning for large substation  
10 projects: a summer peak, a winter peak, and low load.

11 Based on the 90/10 weather normalized near-term load forecast, detailed analyses are  
12 performed to determine when and where violations in planning criteria and  
13 performance requirements occur. Following these analyses, the Company identifies  
14 the need to plan and construct new equipment, including non-wires alternatives, which  
15 expand the capacity of the system and increase reliability. This then increases the  
16 headroom for new loads as well providing additional hosting capacity for DERs to  
17 interconnect. Load and enabled DER capacity are then aggregated to the transmission  
18 level and constraints on the transmission system are identified, considering generation  
19 sources, retirements, and commitments.



1       Once violations and system deficiencies are identified, the Company develops  
2       comprehensive plans to position the electric transmission and distribution systems to  
3       meet the needs of customers from capacity, reliability, and resiliency perspectives.  
4       Projects authorized based on need identified in the 5- and 10-year forecast are  
5       developed, considering the potential for future growth to ensure that work done on the  
6       system today can handle projected future need and avoid early replacement of  
7       infrastructure.

8       Based on the system analysis results, the Company's engineers identify potential  
9       solutions to resolve thermal/capacity, power quality/voltage, reliability and stability  
10      violations where station and line equipment may be operating under conditions beyond  
11      their design limits. The solution development method is a complex and iterative  
12      process which addresses the system needs in conjunction with the capital budget and  
13      involves a wide array of disciplines and departments across the Company including  
14      siting, community engagement, engineering, system planning, substation design,  
15      permitting, environmental affairs, and more. PSNH considers options including  
16      upgrading existing equipment, constructing new equipment or capacity, reconfiguring  
17      the system, and constructing or applying NWAs. All studies to determine the best-fit  
18      solution are conducted prior to developing the preferred solution recommended for  
19      authorization. Once a preferred comprehensive solution and/or solution alternatives  
20      are determined via the system analysis process, the project approval/construction  
21      process is used to initiate and implement a project.

1 The Company follows a standardized process for initiating and then obtaining technical  
2 and financial approval for capital projects. This process ensures that the best solution  
3 is selected and that guiding principles are followed. It includes the review of project  
4 alternatives, scope, and cost estimates. Once a preferred solution with scope definition  
5 is chosen, it proceeds with the engineering analysis that includes more in-depth  
6 constructability review, below grade investigation, preferred routing selection, and  
7 equipment specification to obtain a more accurate project cost estimate. Initial siting  
8 and permitting preparation activities are also required at the preliminary engineering  
9 level.

10 **Q. How has distribution planning evolved to address the current challenges on the**  
11 **distribution system?**

12 A. The Company has integrated transmission planning, distribution planning, DER  
13 planning, reliability and resiliency planning, and advanced forecasting and modeling  
14 into a cohesive planning unit. This integrated planning organizational structure allows  
15 the Company to efficiently perform many complex distribution and transmission  
16 studies in a relatively short time.

17 In September 2020, the Company developed a comprehensive DSPG to provide a  
18 consistent, uniform approach to designing an efficient and reliable system that ensures  
19 the quality of service expected by our customers. Shortly thereafter, the Company  
20 developed an NWA Framework to provide a standardized and expedited process to  
21 screen an NWA solution's technical and economic feasibility to meet a need at a

1 specific location identified in accordance with the distribution planning criteria, and  
2 where deemed feasible, inform the application of non-wires technology or a  
3 combination of technologies through comparison of their relative benefits, performance  
4 and costs (see Section 5.1.4 of the DSP for more information about the NWA  
5 framework). Both the DSPG and the NWA Framework are essential components of  
6 our evolving approach to distribution planning and assessment of systems with high  
7 DER penetration.

8 Historically, the Company focused primarily on maximum (peak) load analysis as the  
9 driver for system design changes. Peak load analysis is focused on a specific time  
10 during a peak day when the system experiences the highest net demand, typically  
11 occurring during high load and low DER generation times. With increasing quantities  
12 of DER potentially leading to reverse flow during low load periods, this paradigm  
13 shifted, and minimum load models became just as important, depending on the amount  
14 of installed DER. However, because the interaction of load and DER is weather and  
15 time dependent, and due to increase in battery storage applications, our analysis  
16 timeframes have shifted even more from a peak and minimum load analysis to an 8760  
17 load-flow model that accounts for all hours of the year.

18 Our analytic methods for assessing grid needs have also evolved with the nature and  
19 magnitude of demand on the system. As part of our integrated planning process the

1 following analyses are conducted in accordance with the applicable standards and  
2 criteria identified in the DSPG:

- 3 • **Steady-state analysis** (in the minutes to hours timescale) to assess thermal  
4 overloads and voltage limit violations resulting from load and DER  
5 interconnections. The steady state analysis is conducted through time series  
6 power flow simulations in our distribution analysis package.
- 7 • **Dynamic/transient analysis** (in the milliseconds to seconds timescale) to  
8 verify acceptable model performance and to identify any violations of stability  
9 criteria or transient overvoltage criteria following system disturbances and  
10 switching actions. For this, the steady-state electric models are converted to  
11 dynamic models to allow for power systems EMT (electromagnetic transients)  
12 simulations.
- 13 • **Short-circuit analysis** to assess if circuit breaker fault interrupting capability  
14 or bus work short-circuit structural limitations or distribution equipment ratings  
15 are exceeded as a result of the interconnection.
- 16 • **Protection review** to assess if direct transfer trip (DTT), ground fault (zero  
17 sequence) overvoltage (3V0) protection or other special protection schemes are  
18 required based on the risk of islanding, back-feed at stations, and other  
19 operational requirements.

- 1           • **Reliability and operational flexibility assessment** to determine loss of  
2           load/DER reliability risk and degradation in transfer capability following a  
3           single-contingency event. This does not constitute a stand-alone analysis, but  
4           rather signifies that all previous analyses must account for the various  
5           permutations of system configuration, ensuring that the EPS is safe and reliable  
6           under all practical scenarios.

7           Over the same period, the Company examined potential tools with advanced planning  
8           methods. As discussed below and in Section 5.4.3 of the DSP, the Company would  
9           like to develop advance forecasting capabilities for system planning. The Company's  
10          Massachusetts affiliate received approval of funding to deploy an Advanced  
11          Forecasting system planning tool and has fully operationalized the tool in 2024 in  
12          Massachusetts. If the Commission approves the project in this proceeding, PSNH can  
13          develop an Advanced Forecasting tool leveraging its affiliates efforts, which will allow  
14          a detailed assessment of forecasts and support probabilistic modeling of scenarios for  
15          risk-based investment prioritization, as well as produce long-term electric demand  
16          assessments beyond the ten-year planning horizon.


17   **VI. FIVE-YEAR INVESTMENT OVERVIEW**

18   **Q. Please provide an overview of the Company's planned solutions to address system**  
19   **needs.**

20   **A.** Section 5 of the DSP describes the Company's solution set to address the capacity,  
21   reliability and system needs over the next five years. The 2025-2029 DSP includes

1 multiple categories of investments that will improve the safety, reliability, resiliency,  
2 and clean energy enablement capabilities of the Company’s electric distribution  
3 system, delivering value to customers on many fronts. The total investment is  
4 approximately \$1.4 billion in capital over the DSP five-year term and is focused on  
5 reliability and resiliency and includes technologies to assist in optimizing the grid.  
6 Figure 1 below provides a summary of the Company’s capital investment plan.

7 **Figure 1: 2025-2029 Capital Investments (\$ thousands)**



1 The capital investment plan consists of two categories of investments: (1) core electric  
2 operation investments and (2) grid modernization and resiliency investments.

3 The first category of investments are the capital expenditures required to maintain safe  
4 and reliable service for customers. These investments include upgrades and new build  
5 of substations and distribution lines to accommodate load growth and maintain  
6 reliability, as well as improved telecommunications and upgrades to the Company's  
7 outage management system. The core electric operation investments are discussed in  
8 Sections 5.1 and 5.2 of the DSP.

9 The second category of investments included proposed investments that could be  
10 supported through the Company's proposed PBR mechanism with a K-bar, if the  
11 Commission authorizes the Company to do so. The proposed grid modernization and  
12 resiliency investments will harden the distribution system against more prevalent and  
13 stronger weather events, improve control room technology, optimize the system  
14 through voltage management, and provide planning tools for advanced forecasting and  
15 DER interconnection. The proposed grid modernization and resiliency investments are  
16 described in Section 5.3 and 5.4 of the DSP.

17 **Q. Please summarize the Company's capacity need investments.**

18 A. Based on the 5- and 10-year forecasts, the Company has identified substation upgrades  
19 and distribution circuit upgrades necessary to address capacity constraints. As  
20 discussed in Section 5.1.1 of the DSP, four substations (Cutts Street, Dover, Salmon

1 Falls, and South Milford) require upgrades or rebuilds to address specific capacity  
2 needs. The Cutts Street and Dover substation projects also will address reliability needs  
3 in addition to capacity. Specifically, the Cutts Street (Portsmouth) 12 kV capacity  
4 project will help address reliability needs at the Mill Pond Substation. The Dover  
5 substation rebuild will also address existing reliability needs at that substation.

6 Substation projects increase capacity or reliability in areas where projected capacity or  
7 reliability violations have been identified through the forecasting and demand  
8 assessment processes. New substation capacity that transforms power between the  
9 transmission and distribution systems is the foundation to make a meaningful and  
10 sustainable step-change in the amount of load and DER an area can accommodate.  
11 Over the next decade, the substation capacity and reliability projects in Section 5.1 and  
12 5.2 of the DSP will add a total of 660 MW of transformer capacity, an increase of 17%  
13 over the existing 3.9 GW installed base.

14 In addition to substation projects, the Company has identified distribution circuit  
15 capacity constraints that need to be addressed in each region of its service territory.  
16 The Central region circuit capacity has had one to two percent growth with pockets of  
17 new commercial and residential load growth as migration from Massachusetts  
18 continues along the I-93 corridor. Current load growth in the area is outside of the  
19 downtown Manchester area, specifically with growth near the Manchester Airport and  
20 rural growth as well. Current and future capacity projects are planned in the Central



1 region to support overloaded step transformers or overloaded distribution substation  
2 transformers (4.16 kV or 12.47 kV).

3 The Eastern region load continues to grow, with large commercial and residential  
4 growth in the area as migration from Massachusetts continues along the I-95 corridor.  
5 In the Pease area exponential commercial load growth continues as industrial load  
6 grows from the pharmaceutical industry. The Company needs to continue the  
7 expansion of its circuits in the Portsmouth downtown area, which is in a revitalization  
8 process, with new 12 kV systems. Other large towns in the Eastern region have historic  
9 4.16 kV systems which are in the process of conversion, such as Dover where it is near  
10 completion of a conversion to 12 kV. Other towns in the region have growth where  
11 the overloaded steps require the conversion of the 4.16 kV system to 34.5 kV. Other  
12 portions of the Eastern region have overloaded step transformers which require a  
13 voltage conversion, as pockets of residential load and electric vehicle adoption continue  
14 to develop. This conversion also addresses aging infrastructure and when possible, the  
15 conversion facilitates additional circuit ties to be developed.

16 The load profiles of the Northern and Western regions have changed over the years.  
17 Vacation campsites have become vacation houses. In addition to new residential load,  
18 the regions are famous for their ski resorts which are large load centers. The Northern  
19 and Western region town areas are served by pockets of 4.16 kV systems which are fed  
20 from overhead step transformers. These transformers are at or near thermal capacity

1 limits and the downtown system is near its end of useful life. These regions require kV  
2 conversions to provide additional load-serving capabilities.

3 The Southern region is similar to the Central region as it has experienced one to two  
4 percent growth with pockets of new commercial and residential load growth as  
5 migration from Massachusetts continues along the I-93 corridor. Current load growth  
6 pockets are from new residential complexes, retail facilities or warehouses along the  
7 Evergreen Parkway or I-93 Corridor. Current capacity projects are due to overloaded  
8 step transformers or overloaded distribution substation transformers (4.16 kV or 12.47  
9 kV).

10 **Q. Please summarize the Company's planned reliability investments.**

11 A. The Company's reliability needs and solutions are described in Section 5.2 of the DSP.  
12 Within its service territory, PSNH supplies a range of rural and urban areas which often  
13 differ in electric supply characteristics and requirements. To maintain adequate levels  
14 of reserve capacity, power quality, and reliability that meet or exceed our customer's  
15 increased expectations, PSNH designs its bulk substations to sustain any single  
16 contingency event with no load loss. The single contingency events that are planned  
17 for include loss of a bulk power transformer, loss of a distribution bus section, and bus  
18 tie breaker failure. Based on criteria violations, the Company has identified  
19 25 substation reliability projects, which are listed in the below table:

1

**Table 1: Substations with Reliability Needs**

<b>Substation Name and Location</b>	<b>Communities Supplied</b>	<b>Criteria Violation(s)</b>	<b>Project Solution</b>
<b>Bedford Substation</b> <i>Bedford</i>	Bedford, Litchfield, Londonderry, Manchester, Merrimack	Transformer Load & Bus Tie Breaker	Manchester Area Reliability Project
<b>Eddy Substation</b> <i>Manchester</i>	Manchester	Transformer Load & Bus Tie Breaker	Manchester Area Reliability Project
<b>Garvins Substation</b> <i>Bow</i>	Allenstown, Bow, Concord, Chichester, Hooksett, Epsom, Pembroke	Bus Section	Garvins Reliability Project
<b>Huse Road Substation</b> <i>Manchester</i>	Londonderry, Manchester	Transformer Load & Bus Section	Manchester Area Reliability Project
<b>Pine Hill Substation</b> <i>Hooksett</i>	Allenstown, Auburn, Candia, Chester, Deerfield, Hooksett, Manchester, Raymond	Transformer Load, Bus Section & Bus Tie Breaker	Manchester Area Reliability Project
<b>Rimmon Substation</b> <i>Goffstown</i>	Amherst, Bedford, Bow, Dunbarton, Goffstown, Hooksett, Manchester, Merrimack, Milford, Mont Vernon	Transformer Load, Bus Section & Bus Tie Breaker	Manchester Area Reliability Project
<b>Brentwood Substation</b> <i>Brentwood</i>	Brentwood, Chester, Epping, Fremont, Nottingham, Raymond	Transformer & Bus Section	Madbury Area Project
<b>Dover Substation</b> <i>Dover</i>	Dover, Rochester, Rollinsford, Somersworth	Transformer Load & Bus Section	Dover Substation Rebuild
<b>Madbury Substation</b> <i>Madbury</i>	Barnstead, Barrington, Brentwood, Deerfield, Dover, Durham, Epping, Epsom, Lee, Madbury, Newfields, Newmarket, Northwood, Nottingham, Pittsfield, Rochester, Strafford	Transformer Load & Bus Section	Madbury Area Project
<b>Mill Pond Substation</b> <i>Portsmouth</i>	Portsmouth	Transformer & Bus Section	Portsmouth 12 kV Capacity Project
<b>Portsmouth Substation</b> <i>Portsmouth</i>	Newington, Portsmouth	Bus Tie Breaker	Portsmouth 34.5 kV Project
<b>Berlin Substation</b> <i>Berlin</i>	Berlin, Cambridge, Dummer, Errol, Gorham, Green's Grant, Jefferson, Martin's Location, Milan, Millsfield, Pinkham's Grant, Randolph, Shelburne, Stark, Success, Wentworth's Location	Bus Section	Berlin Reliability Project

<b>Substation Name and Location</b>	<b>Communities Supplied</b>	<b>Criteria Violation(s)</b>	<b>Project Solution</b>
<b>Laconia Substation</b> <i>Laconia</i>	Belmont, Gilford, Laconia, Meredith, Sanbornton, Tilton	Transformer Load & Bus Section	Laconia Reliability Project
<b>Oak Hill Substation</b> <i>Concord</i>	Alton, Barnstead, Belmont, Boscawen, Canterbury, Chichester, Concord, Dunbarton, Gilmanton, Henniker, Hopkinton, Loudon, Pittsfield, Salisbury, Strafford, Warner, Weare, Webster	Bus Section & Bus Tie Breaker	Madbury Area Project
<b>Pemigewasset Substation</b> <i>New Hampton</i>	Alexandria, Bridgewater, Bristol, Danbury, Grafton, Hebron, Hill, Laconia, Meredith, New Hampton, Orange, Wilton	Transformer & Bus Section	Ashland Area Reliability Project
<b>White Lake Substation</b> <i>Tamworth</i>	Albany, Conway, Effingham, Freedom, Madison, Ossipee, Sandwich, Tamworth, Tuftonboro, Wakefield, Waterville	Transformer, Transformer Load & Bus Section	White Lake Reliability Project
<b>Bridge Street Substation</b> <i>Nashua</i>	Merrimack, Nashua	Transformer Load & Bus Section	Nashua Area Reliability Project
<b>Hudson Substation</b> <i>Hudson</i>	Hudson, Litchfield, Londonderry, Nashua, Pelham	Bus Section	Hudson Reliability Project
<b>Lawrence Road Substation</b> <i>Hudson</i>	Hudson, Nashua, Pelham, Windham	Transformer & Bus Section	Lawrence Road Reliability Project
<b>Long Hill Substation</b> <i>Nashua</i>	Nashua	Transformer Load & Bus Section	Nashua Area Reliability Project
<b>Scobie Pond Substation</b> <i>Derry</i>	Derry, Londonderry, Windham	Bus Section & Bus Tie Breaker	Derry 12.47 kV Reliability Project
<b>Chestnut Hill Substation</b> <i>Hinsdale</i>	Chesterfield, Hinsdale, Richmond, Spofford, Stoddard, Swanzey, Westmoreland, Winchester	Transformer & Bus Section	Chestnut Hill Reliability Project
<b>Jackman Substation</b> <i>Hillsborough</i>	Antrim, Bennington, Bradford, Deering, Frankestown, Greenfield, Hancock, Henniker, Hillsborough, Lyndeborough, New Boston, Peterborough, Nelson, Stoddard, Warner, Washington, Weare, Windsor	Transformer Load & Bus Section	Jackman Reliability Project
<b>Monadnock Substation</b> <i>Troy</i>	Fitzwilliam, Jaffrey, Marlborough, New Ipswich,	Transformer, Transformer Load,	Monadnock Substation Rebuild

Substation Name and Location	Communities Supplied	Criteria Violation(s)	Project Solution
	Richmond, Rindge, Troy, Winchester	Bus Section & Bus Tie Breaker	
<b>North Road Substation</b> <i>Sunapee</i>	Bradford, Claremont, Croydon, Enfield, Goshen, Grantham, Lempster, New London, Newbury, Newport, Springfield, Sunapee, Sutton, Unity, Warner, Wilmot	Bus Section	North Road Reliability Project

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

In addition to the specific substation reliability projects, the Company has general reliability programs discussed in Section 5.2.2.1 of the DSP. These programs address and replace obsolete substation equipment that has reached the end of its useful life, e.g., breakers (non-oil), reclosers, reactors, motor operated disconnects, fencing, ground grid, and annunciators. It also includes new substations, monitoring, and other equipment needed to improve substation or distribution system reliability. The need for equipment replacement under the general reliability programs is determined by inspections, testing, age of equipment, safety issues, operating issues, changes to standards, and spare parts availability. Currently, there are programs under way such as: battery replacements, relay replacements, RTU replacements, gas monitor replacements, gas monitor and health monitor installation, station service transformer replacements, battery monitoring installations, capacitor bank switch replacements, oil circuit breaker, oil filled recloser, and ancillary equipment replacement, substation animal protection installations and substation eliminations.

1 The Company's circuit reliability program discussed in Section 5.2.3 of the DSP  
2 utilizes a tool bench of data analytics tools to evaluate the most cost-effective approach  
3 for improving circuit reliability. Over the next several years, based on data and  
4 analysis, the improvement in available fault current, line segmentation, and the creation  
5 of circuit ties will ensure the reliability of Eversource's system both in blue and grey  
6 sky days.

7 **Q. Please describe the Company's telecommunication replacement strategy.**

8 A. The strategy is described in Section 5.2.5 of the DSP. Voice communication is a critical  
9 tool that the Company uses daily to maintain and operate the system. A reliable voice  
10 radio system is critical to PSNH's business because it is a lifeline for field crews that  
11 enables the communication between teams in various locations, provides fast and  
12 secure communications, operates independently of public cellular networks, and can  
13 enable continuous communication during emergencies or black starts when other  
14 existing communication methods may not be operable. These capabilities are key to  
15 enhanced situational awareness and ultimately employee safety.

16 There currently are 39 base radios used to create the voice radio network which  
17 connects approximately 825 mobile and portable radios. This equipment has been in  
18 service up to 30 years and is at end of life. The Company plans to update all the existing  
19 equipment to enable a digital mobile radio network. The digital mobile radio network  
20 will provide several benefits over the existing analog system, including improved audio

1 quality, enhanced privacy and security, better coverage and range, integrated data  
2 services, scalability and flexibility, enhanced features and functionality, and  
3 interoperability. These benefits are described in detail in Section 5.2.5 of the DSP.

4 **Q. Please describe the Company's outage management system upgrade.**

5 A. The planned upgrade is described in Section 5.2.6 of the DSP. The Company's outage  
6 management system is planned to be upgraded to enable new capabilities and prepare  
7 for future use cases. The upgrade will include a common network model to improve  
8 situational awareness, enhanced web viewer for improved access and performance  
9 during major events, optimized process flows, improved mobile app for damage  
10 assessment, and enable future advanced metering infrastructure integration. The  
11 upgrade also ensures the software stays compliant, secure and compatible with the  
12 overall IT environment.

13 **Q. Please explain why the Company is seeking authorization to implement the**  
14 **proposed grid modernization and resilience investments.**

15 A. As discussed above and in the DSP, customer interaction and reliance on the electric  
16 grid is evolving. Customers are increasingly adopting DERs, electric vehicles, and  
17 relying on smart technologies and automated/computerized systems for their  
18 businesses. In addition, the region has experienced increasing number and severity of  
19 storms that threaten the electric grid. As the distribution system continues to evolve,  
20 so will the operational challenges and opportunities that face the system.

1 The proposed grid modernization and resilience investments can provide significant  
2 benefits to customers by hardening the distribution system, improving control room  
3 technology, optimizing the system through voltage management, and providing  
4 additional planning tools for advanced forecasting and DER interconnection.  
5 Specifically, with regard to resilience, proactive system hardening has benefits in storm  
6 response and restoration. The proposed grid modernization investments include Volt-  
7 VAR Optimization (“VVO”), Distributed Energy Resource Management system  
8 (“DERMS”), Advanced Forecasting for system planning, and Hosting Capacity and  
9 Interconnection Automation solutions. These enhancements, however, require  
10 significant revenue support and will be prioritized after the core electric operation  
11 investments discussed above and in Sections 5.1 and 5.2 of the DSP. The Company,  
12 therefore, requests authorization from the Commission to pursue these important  
13 modernization investments to deliver improved service and resiliency for customers.  
14 If approved, the Company does not propose to recover the costs of these investments  
15 through a reconciling factor. Instead, the Company will implement the investments  
16 and seek cost recovery as capital additions in the Company’s next rate case proceeding,  
17 provided the Commission approves the proposed PBR mechanism with the three-year  
18 rolling average K-bar discussed in the Case Overview Testimony. The proposed PBR  
19 mechanism will provide the Company with the necessary revenue support to implement  
20 the proposed grid modernization and resiliency investments during the PBR term. As  
21 with all capital investments, the investments would remain subject to a prudence review



1 and potential disallowance from rate base as part of the Company's next base-rate  
2 proceeding.

3 **Q. Please summarize the Company's proposed resiliency investments.**

4 A. The Company describes the resiliency investments in Section 5.3 of the DSP.

5 New England has already started seeing the impacts of climate change through the  
6 increased frequency and intensity of storm events resulting in elevated all-in SAIDI.  
7 New England was hit by three catastrophic hurricanes since 2010 – Isaias, Sandy and  
8 Irene. New England was also subjected to Winter Storm Alfred – also coined the 2011  
9 Halloween Nor'easter – which arrived just two months after Irene. When looking at  
10 40 years of storm data, these storms range between 1 in 30-year to 1 in 50-year events.  
11 But shortening the lookback period to more recent 15 years of storm data, suggests a  
12 dramatic compression in catastrophic storm probabilities in the range of 1 in 19-year to  
13 1 in 23-year events. This substantial compression in storm probabilities when looking  
14 at more recent storm history demonstrates that these catastrophic storms are becoming  
15 significantly more likely in New England. Increasing transportation and building  
16 electrification, the proliferation of renewables and distributed energy resources as well  
17 as extensive reliance on the Internet for daily life, place the electric grid at the epicenter  
18 of various social and economic sectors. As a result, effective resilience planning to  
19 enable the grid to withstand outages and reduce the impacts of unavoidable events has  
20 become increasingly critical.

1 Under the resilience program, the Company will seek to enhance the resiliency of the  
2 system through (i) targeted undergrounding, (ii) reconductoring, and (iii) vegetation  
3 management.

4 The Company proposes to plan for resiliency using a data-driven approach. The  
5 resilience methodology scans the entire system for vulnerabilities and focuses  
6 specifically on high criticality outages, meaning outages with many customers  
7 impacted, long duration outages and multiple outages at the same zone (chronic  
8 problems). This comprehensive system scan enables a resilience program that targets  
9 high-yield projects first rather than across-the-board, generic, state-wide program  
10 implementation. This is based on advanced data analytics using highly granular outage  
11 data. The Company then uses data engineering to understand which attributes of  
12 outages and of the circuits are optimally responsive to projects. The resilience plan  
13 targets zones with high criticality; either those with multiple events (chronic problems/  
14 repeat offenders) or those with high Customer Minutes of Interruption (“CMI”) impacts  
15 per event. Eligible zones were paired with mitigations based on a combinatorial index  
16 of the number of events and the all-in SAIDI impact of the events. The projects were  
17 then ranked based on the SAIDI saved per dollar spent and the projects that are included  
18 in the Company’s 10-year \$150M resilience plan are the ones that fall under the optimal  
19 investment saturation point. Based on the analysis, the Company has identified 48  
20 projects (14 undergrounding projects, 23 reconductoring projects and 11 vegetation

1 work projects). The breakdown of the projects by region is discussed in Section 5.3.1.5  
2 of the DSP.

3 **Q. Please summarize the Company's proposed grid modernization investments.**

4 A. The grid modernization investments are described in Section 5.4 of the DSP.

5 VVO is the process of optimally managing voltage levels and reactive power to achieve  
6 more efficient grid operation with the benefit of reducing system losses and energy  
7 consumption and improving the management of peak demand. VVO ensures that  
8 distribution voltages remain within prescribed tolerances and are not moving up and  
9 down rapidly as more DER is added to the system. In addition, managing these  
10 voltages to reduce energy consumption and optimizing demand will provide direct  
11 benefits to customers. The result is lower costs for customers, decreased carbon  
12 emissions, and increased DER hosting capacity.

13 The VVO program has three investment components: The first is to deploy and/or  
14 upgrade the substation transformer load tap changers, substation feeder metering,  
15 feeder voltage regulators, and feeder capacitor banks to enable two-way  
16 communication (also known as SCADA) such that the devices can be actively  
17 controlled by a centralized system in response to real-time voltage and reactive power  
18 fluctuations. The second component is the centralized intelligence program used to  
19 collect real-time data from the system, perform analyses and calculations, and send  
20 control signals to devices. The third component is the communications infrastructure

1 needed to enable the two-way communication between the field devices and  
2 Eversource's centralized SCADA system. By deploying a VVO scheme on a  
3 distribution feeder, Eversource can improve the efficiency of this energy delivery,  
4 while at the same time dramatically increasing visibility into real-time grid conditions.

5 The Company is also continuing to improve its core control room technologies through  
6 software upgrades that deliver additional functionality and capabilities. The potential  
7 use of DER to provide grid services is driving the need for a DERMS to assist operators  
8 in managing DER assets. The DERMS is a software platform that can manage DER to  
9 deliver grid services and provide operators a tool to balance demand with supply on the  
10 distribution network. To achieve the optimal use of distribution system assets, the  
11 DERMS will organize connected assets and provide critical operational data for each  
12 asset to be a data input into the DMS. The DERMS will also act as the system from  
13 which the system operator will be able to issue commands to the DER to guarantee the  
14 safe and reliable operation of the distribution system in real time.

15 As discussed above, the Company's grid modernization investments also include  
16 leveraging Company affiliates' experiences to develop and deploy advanced  
17 forecasting capabilities in New Hampshire which will allow a detailed and automated  
18 assessment of bulk circuit level forecasts and support probabilistic modeling of  
19 scenarios for risk-based investment prioritization. While the Company has robust  
20 forecasting analysis, further support is needed to continue to advance the Company's

1 forecasting and modeling capabilities. The growing complexity of the distribution  
2 system, characterized by two-way power flow and self-healing automation, will  
3 continue to drive the need for scenario planning that identifies system needs under  
4 multiple possible future configurations of load and generation growth. If the proposed  
5 advanced planning proposal is approved, the Company will leverage existing  
6 knowledge and capabilities to develop large scale power flow automation that can  
7 ingest the forecasts, conduct Monte Carlo simulations on various input parameters, and  
8 produce reports that inform distribution engineering, system planning, and regulators  
9 and policy makers on future investment decisions. The Company will develop, as part  
10 of its advanced forecasting capabilities, long-term demand assessment approaches  
11 which provide a 20–30-year outlook on state policy objectives and macroeconomic  
12 trends. These results will then be used as inputs into solution design of projects to  
13 ensure the Company develops only those solutions that serve a long-term purpose.

14 Finally, there is growing recognition in the electric power industry of the need to  
15 improve the efficiency and effectiveness of the process for assessing the impact of  
16 interconnecting DERs to reduce time and lower costs for customers. The volume of  
17 applications and the complexity of analysis are increasingly stressing the limits of  
18 existing engineering resources and their current processes. In recent years, new  
19 software tools have been introduced to effectively automate portions of the study  
20 process. These tools increase capability, reduce study time and free up high value  
21 resources to focus on more complex planning activities. The Company has invested in

1 tools and solutions including Synergi Electric and Hosting Capacity Maps. Additional  
2 tools used in the interconnection process include Power Systems Computer Aided  
3 Design (PSCAD) and Power Clerk. However, to better service our customers, a more  
4 automated and streamlined approach needs to be considered.

5 In support of increasing the efficiency and effectiveness of the interconnection  
6 application study process, the Company is proposing to procure a software solution to  
7 enhance the Company's capabilities to quickly and accurately assess interconnection  
8 impacts in order to safely and reliably interconnect as much DER as possible.  
9 Specifically, PSNH will purchase a software solution to provide a dedicated and  
10 specifically tailored solution to DER planners while leveraging legacy investments in  
11 Synergi, PSCAD and Power Clerk by increasing integration and automation between  
12 the tools. In addition, the Company will merge hosting capacity information into the  
13 interconnection platform and provide users the ability to interact with the hosting  
14 capacity data to evaluate various options (location, curtailment, active management,  
15 storage, etc.) directly during the interconnection process.

16 The Company will also improve hosting capacity calculations to provide easy access  
17 to guidance on improvements to interconnection applicants. The proposed hosting  
18 capacity calculation enhancements will include time series to allow for the evaluation  
19 of specific operating modes and dispatch patterns.

1 The Company intends to develop a customer user flow allowing customers to actively  
2 engage with the interconnection portal and receive direct feedback on possible  
3 constraints of their application. While this will not replace an interconnection study,  
4 modifying the interconnection to better fit the available grid capacity significantly  
5 reduces the risk of associated interconnection cost. Furthermore, it will provide  
6 developers with more information on options to utilize storage assets or other measures  
7 to actively reduce their possible cost to interconnect.

8 Finally, by developing automation of all feasible study steps and an improved case  
9 management, PSNH expects a reduction of effort, and consequently time, required to  
10 study the interconnection request. The result will manifest itself with faster turnaround  
11 times for interconnecting customers, which directly results in reduced risk to projects.

12 These investments would build on the existing solutions. The Company has already  
13 undergone contracting with a vendor in Massachusetts to deploy these capabilities and  
14 intends to fully leverage this relationship for New Hampshire provided the Commission  
15 approves the proposed requests.

16 **Q. Please explain the Company's plans for company-owned solar projects in New**  
17 **Hampshire.**

18 A. As discussed in Section 5.5 of the DSP, PSNH is actively pursuing development of  
19 potential company-owned solar projects in New Hampshire on company-owned  
20 properties. The specific projects, their overall size and costs are currently under

1 development. Under RSA 374-G, New Hampshire electric distribution companies are  
2 permitted to build, own and operate distributed generation under specific circumstances  
3 including when the benefits of such projects exceed the cost to ratepayers.

4 The Company is not seeking approval of its proposed solar projects at this time. The  
5 proposed projects were included in the DSP to provide the Commission with a  
6 comprehensive overview of the potential investments the Company may undertake  
7 over the next five-years based on approval of the Company's proposed PBR  
8 mechanism. As discussed in the Case Overview Testimony, the Company's proposed  
9 PBR mechanism is designed to reduce administrative burdens by eliminating the  
10 reconciliation of certain costs and providing revenue support for the Company. The  
11 Company's proposed three-year rolling average K-bar could provide the revenue  
12 support for the Company to pursue company-owned solar under RSA 374-G, without  
13 the need for a reconciling mechanism or step adjustments. Accordingly, if the  
14 Commission approves the K-bar proposal and the Company separately receives  
15 approval of a company-owned solar proposal, the Company will implement the solar  
16 projects subject to a prudence review and potential disallowance from rate base as part  
17 of the Company's next base-rate proceeding.

18 **Q. Please explain the Company's co-optimized reliability enhancement proposal.**

19 A. As discussed in Section 5.2.4 of the DSP, periodically, the Company must make  
20 significant infrastructure investments to accommodate a large new or expanded



1 customer load. The customer contributes to the cost of the project through a  
2 contribution in aid of construction (CIAC) charge. However, these projects may also  
3 provide an opportunity for limited incremental investment to address broader capacity,  
4 reliability, and resiliency needs that benefit the broader customer base. For example,  
5 if a new customer load requires the construction of a new substation, the Company  
6 could also reconfigure the distribution lines to serve other customers from the new  
7 substation and alleviate constraints on existing substations, thereby improving service  
8 reliability. In this manner, for limited incremental cost, the Company can take  
9 advantage of these periodic opportunities to enhance safe and reliable service and  
10 potentially future-proof investments for the benefit of the broader customer base, rather  
11 than just the customer triggering the infrastructure upgrade.

12 The Company requests Commission authorization to pursue these grid reliability  
13 enhancements through co-optimization of customer-driven investments under the  
14 K-bar proposal described in the Case Overview Testimony. If the Commission  
15 approves the proposal, when the opportunity arises, the Company will seek to co-  
16 optimize customer-driven investments to provide customers with cost-efficient  
17 reliability benefits. The Company proposes that these projects will be incremental to  
18 any capital investments included in the K-bar calculation, and not subject to the K-bar  
19 cap. Since these investment opportunities are not within the control of the Company  
20 and costs may be significant, the Company needs flexibility to pursue co-optimization  
21 opportunities outside of the planned annual capital budget. Similar to the proposed

1 solar investments, the Company proposes to implement the co-optimization reliability  
2 enhancement projects subject to a prudence review and potential disallowance from  
3 rate base as part of the Company's next base-rate proceeding.

4 **VII. CONCLUSION**

5 **Q. Does this conclude your testimony?**

6 A. Yes. On behalf of PSNH, we appreciate the Commission's consideration of the  
7 Company's proposals in this case.