

Comment on DE-24-087

On the U-199 easement Eversource contractors have built roads and construction lots and mesas. Near the Littleton substation they have erected many new metal structures, felled the 55 years young wood structures, and strung the new larger conductor and Optical Ground Wire (OPGW.)

Structures 10 (closest), 9 and 8 below are 27', 29' and 36' taller than the wood structures they replaced.



Closer to Bethlehem, contractors have drilled or augered 4' diameter holes and set caissons in them to support the new structures.

There has been nothing official posted on the PUC docket for this waiver since December 16, 2024.

Eversource is accruing expenses it will pass on to rate-payers, on the assumption that the PUC will trump Bethlehem's height zoning.

It would be helpful if the PUC would clarify the status of this docket.

kris pastoriza February 16, 2025