



NEW HAMPSHIRE HISTORICAL OUTAGES ALL UTILITIES For WIDE SCALE STORMS
 Prepared by NHPUC Safety Division Rev 06/12/2015

		Worst Outage	2nd Worst Outage	3rd Worst Outage	4th Worst Outage	5th Worst Outage	6th Worst Outage		
Eversource	Event Name	December 11-24, 2008 Ice Storm	February 25-March 4, 2010 Windstorm	Oct 29-Nov 4, 2011 Nor'easter (snow)	Nov 26 - Dec 1 2014 Thanksgiving Eve Snowstorm	Oct 26 - 31 2012 Hurricane Sandy	Aug 28 - Sept 1 2011 Tropical Storm Irene		
	# of Customers Affected	322,438	265,728	237,000	207,359	137,070	125,714		
	% of Customers Affected	66%	53%	47%	41%	27%	25%		
	Duration of Restoration	312	144	159	114	106	79		
	# of Restoration Crews (ex Tree/Dmg Assrs)	788	396	379	729	386	381		
	Wire Reattached/Replaced (ft)	554,400	168,960	89,760	97,803	116,160	63,360		
	# of Transformers Replaced	1,300	592	196	129	299	155		
	# of Poles Set	783	175	177	59	161	57		
	# of Cross-arms Replaced	1,255	Unknown	Unknown	157	Unknown	Unknown		
Total Cost	\$72,709,000	\$26,523,000	\$15,700,000	\$32,500,000	\$11,200,000	\$7,100,000			
NHEC	Event Name	December 11-24, 2008 Ice Storm	February 25-March 4, 2010 Windstorm	February 17 - 20, 2006	April 15 - 22, 2007	Nov 26 - Dec 1 2014 Thanksgiving Eve Snowstorm	Oct 26 - 31 2012 Hurricane Sandy	Aug 28 - Sept 1 2011 Tropical Storm Irene	Oct 29-Nov 4, 2011 Nor'easter (snow)
	# of Customers Affected	48,230	45,000	40,000	35,000	29,308	22,000	19,436	18,687
	% of Customers Affected	61%	59%	51%	45%	36%	28%	29%	24%
	Duration of Restoration (hrs)	190	128	72	168	102	108	77	66
	# of Restoration Crews (ex Tree/Dmg Assrs)	59	63	Unknown	Unknown	93	80	53	29
	Wire Reattached/Replaced (ft)	6,959	40,000	Unknown	316,800	820	Unknown	Unknown	Unknown
	# of Transformers Replaced	82	80	Unknown	Unknown	3	Unknown	Unknown	Unknown
	# of Poles Set	70	70	Unknown	75	17	Unknown	Unknown	Unknown
	# of Cross-arms Replaced	120	180	Unknown	Unknown	4	Unknown	Unknown	Unknown
Total Cost	\$2,126,000	\$1,314,854	Unknown	Unknown	\$1,500,165	\$2,532,429	\$288,000	\$248,000	
Unitil	Event Name	February 25-March 4, 2010 Windstorm	Oct 29-Nov 4, 2011 Nor'easter (snow)	December 11-24, 2008 Ice Storm	Nov 26 - Dec 1 2014 Thanksgiving Eve Snowstorm	Oct 26 - 31 2012 Hurricane Sandy	Aug 28 - Sept 1 2011 Tropical Storm Irene		
	# of Customers Affected	61,602	51,262	39,996	34,575	31,437	31,355		
	% of Customers Affected	84%	69%	55%	46%	42%	42%		
	Duration of Restoration (hrs)	96	88	288	86	61	36		
	# of Restoration Crews (ex Tree/Dmg Assrs)	176	78	63	98	63	144		
	Wire Reattached/Replaced (ft)	103,600	5,700	93,012	18,599	21,819	2,400		
	# of Transformers Replaced	66	8	71	14	23	13		
	# of Poles Set	137	9	67	9	18	0		
	# of Cross-arms Replaced	325	35	239	46	26	10		
Total Cost	\$4,577,281.00	\$3,265,000.00	\$2,043,881.00	\$2,071,048.00	\$2,659,587.00	\$2,554,000.00			
Liberty	Event Name	December 11-24, 2008 Ice Storm	Oct 29-Nov 4, 2011 Nor'easter (snow)	Aug 28 - Sept 1 2011 Tropical Storm Irene	February 25-March 4, 2010 Windstorm	Oct 26 - 31 2012 Hurricane Sandy	March 7 - 10 2011 Ice/Rain storm	Nov 26 - Dec 1 2014 Thanksgiving Eve Snowstorm	
	# of Customers Affected	24,164	17,000	11,400	11,319	10,200	4,709	2,900	
	% of Customers Affected	63%	41%	28%	27%	25%	11%	7%	
	Duration of Restoration (hrs)	168	108	48	88	55	67	38	
	# of Restoration Crews (ex Tree/Dmg Assrs)	78	25	32	79	42	87	13	
	Wire Reattached/Replaced (ft)	12,980	Unknown	Unknown	Unknown	Unknown	Unknown	5,000	
	# of Transformers Replaced	29	Unknown	Unknown	Unknown	Unknown	Unknown	5	
	# of Poles Set	48	Unknown	Unknown	Unknown	Unknown	Unknown	10	
	# of Cross-arms Replaced	250	Unknown	Unknown	Unknown	Unknown	Unknown	25	
Total Cost	\$2,105,065.00	\$1,489,292.00	\$1,000,796.00	\$1,922,639.00	\$1,501,777.00	\$1,865,469	\$150,000.00		