

3rd 2010 Quarter Summary				
Todays Date 25-Oct-10				
Source Name	Emission Report Date (electronic)	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu
PT Tamworth	12-Oct-10	0.069	10-Jun-10	0.003
PT Bethlehem	1-Oct-10	0.071	18-May-10	0.001
PSNH SR5	25-Oct-10	0.066	6-May-10	0.0017
Indeck Energy	25-Oct-10	0.144 OVER 0.075	17-Jun-10	0.002
Springfield Power	18-Oct-10	0.074	3-Sep-09	0.022

h:testing and monitoring/RPS Verification-2010