



The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES



Thomas S. Burack, Commissioner

January 31, 2014

NHPUC 3FEB14PM12:44

Debra A. Howland, Executive Director and Secretary
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

**Re: 4th Quarter Emissions Verification Summary for Certified Renewable Energy Sources
(DE 08-024, DE 08-044, DE 08-051, DE 09-008, DE 09-104, DE 12-091, DE 13-265, and
DE 14-007)**

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Pinetree Power, Inc.
1241 Whitefield Rd
Bethlehem, NH 03574
GIS Unit ID #: MSS337

Pinetree Power-Tamworth, Inc.
469 Plains Rd
Tamworth, NH 03886
GIS Unit ID #: MSS592

Pinetree Power-Fitchburg, Inc.
2 Rowtier Drive
Westminster, MA 01473
GIS Unit ID #: MSS538

Indeck
151 Smith River Road
Alexandria, NH 03222
GIS Unit ID #: MSS14211

**Public Service Company
of New Hampshire (PSNH)
Schiller Station # 5**
400 Gosling Rd
Portsmouth, NH 03801
GIS Unit ID #: MSS557

Springfield Power, LLC
54 Fisher Corner Road
Springfield, NH 03284
GIS Unit ID #: MSS436

Please note that the following plants applied for conditional approval to generate RECs, but have not yet conducted an initial stack test to determine TSP emissions:

Berlin Station, LLC
One Community Street
Berlin, NH 03570
GIS Unit ID #:

DES Web Site: www.des.nh.gov

P.O. Box 95, 29 Hazen Drive, Concord, New Hampshire 03302-0095
Telephone: (603) 271-1370 Fax: (603) 271-1381 TDD Access: Relay NH 1-800-735-2964

Androscoggin Valley Hospital (AVH)

59 Page Hill Road
Berlin, NH 03570
GIS Unit ID #:

Please note that the following plant applied for conditional approval to generate RECs, but has not yet installed an SCR control device to reduce NOx emissions:

Ryegate Power Station

247 Weesner Drive
East Ryegate, VT 05042
GIS Unit ID #: MSS2433

If you have any questions regarding DES's recommendations, please contact me at joseph.fontaine@des.nh.gov or (603) 271-6794.

Sincerely,



Joseph T. Fontaine
Trading Programs Manager
Air Resources Division

cc: Barbara Bernstein, NH PUC