



The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES



Thomas S. Burack, Commissioner

May 6, 2015

NHPUC 7MAY15AM8:50

Debra A. Howland, Executive Director and Secretary
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

**Re: 1st Quarter Emissions Verification Summary for Certified Renewable Energy Sources
(DE 08-024, DE 08-044, DE 08-051, DE 09-008, DE 09-104, DE 12-091, DE 13-265, DE
14-007, and DE 14-209)**

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities meet average emission rates of 0.02 lb/MMBtu (or an alternative plan) and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NO_x), respectively:

Pinetree Power, Inc.

1241 Whitefield Rd
Bethlehem, NH 03574
GIS Unit ID #: MSS337

Pinetree Power-Tamworth, Inc.

469 Plains Rd
Tamworth, NH 03886
GIS Unit ID #: MSS592

Pinetree Power-Fitchburg, Inc.

2 Rowtier Drive
Westminster, MA 01473
GIS Unit ID #: MSS538

Indeck

151 Smith River Road
Alexandria, NH 03222
GIS Unit ID #: MSS14211

**Eversource (formerly Public
Service Company of New Hampshire
(PSNH)) Schiller Station # 5**

400 Gosling Rd
Portsmouth, NH 03801
GIS Unit ID #: MSS557

Springfield Power, LLC

54 Fisher Corner Road
Springfield, NH 03284
GIS Unit ID #: MSS436

Berlin Station, LLC

One Community Street
Berlin, NH 03570
GIS Unit ID #: MSS16653

Ryegate Power Station

247 Weesner Drive
East Ryegate, VT 05042
GIS Unit ID #: MSS2433

Bridgewater Power Company

Route 3
Bridgewater, NH 03222
GIS Unit ID #: MSS357

DES Web Site: www.des.nh.gov

P.O. Box 95, 29 Hazen Drive, Concord, New Hampshire 03302-0095

Telephone: (603) 271-1370 Fax: (603) 271-1381 TDD Access: Relay NH 1-800-735-2964

Based on the attached summary, DES recommends certification of the following wood-fired boilers as thermal renewable energy sources, because the facilities meet average emission rates of 0.10 lb/MMBtu for TSP and best management practices (BMP) for NOx, respectively:

Littleton Regional Healthcare (LRH)
600 Saint Johnsbury Road
Littleton, NH 03561


Androscoggin Valley Hospital (AVH)
59 Page Hill Road
Berlin, NH 03570

Warwick Mills
301 Turnpike Rd.
New Ipswich, NH

Please note that numerous small (<3 mmBtu/hr) thermal renewable energy sources, including but not limited to Mascoma Schools and Fall Mountain Regional School District, are only required to meet BMP. DES intends to communicate directly with PUC staff regarding case-by-case eligibility for these sources.

If you have any questions regarding DES's recommendations, please contact me at joseph.fontaine@des.nh.gov or (603) 271-6794.

Sincerely,



Joseph T. Fontaine
Trading Programs Manager
Air Resources Division

cc: Barbara Bernstein, NH PUC