

4th 2009 Quarter Summary
Date 26-Jan-10

Source Name	Emission Report Date (electronic)	NOx #MMBTU Quarter Average	TSP Test Date	TSP Emission Average
PT Tamworth	25-Jan-10	0.064	21-May-09	0.002
PT Bethlehem	4-Jan-10	0.072	20-May-09	0.004
PSNH SR5	26-Jan-10 (Clean Air Markets)	0.071 (calc)	13-May-09	0.001
Indeck Energy conditionally approved				
Springfield Power	23-Jan-10	0.064	3-Sep-09	0.022