

THE STATE OF NEW HAMPSHIRE



TDD Access: Relay NH
1-800-735-2964

Tel. (603) 271-2431

FAX (603) 271-3878

Website:
www.puc.nh.gov

CHAIRMAN
Amy L. Ignatius

COMMISSIONERS
Michael D. Harrington
Robert R. Scott

EXECUTIVE DIRECTOR
Debra A. Howland

PUBLIC UTILITIES COMMISSION
21 S. Fruit Street, Suite 10
Concord, N.H. 03301-2429

NHPUC 19AUG13AM9:58

August 16, 2013

James Webb
Registry Administrator
APX Environmental Markets
224 Airport Parkway, Suite 600
San Jose, CA 95110

Re: **Quarterly Emissions Verification Summary for Certified Renewable Energy Sources**
 DE 08-024 Pinetree - Bethlehem DE 08-044 Schiller Station #5
 DE 08-051 Pinetree Power - Tamworth DE 09-008 Indeck
 DE 09-104 Springfield Power (ineligible) DE 12-091 Berlin Station (under construction)

Dear Mr. Webb:

Pursuant to RSA 362-F:11, III, Renewable Portfolio Standard eligibility determinations of generation facilities that use biomass fuels are conditional. Within ten days of receiving the quarterly notice from the New Hampshire Department of Environmental Services (DES) that a facility has met DES emissions standards, the Commission must designate the facility as eligible to produce Renewable Energy Certificates.

Based on the DES recommendation, received August 12, 2013, the Commission hereby certifies the following wood-fired power plants as renewable energy sources for the second quarter of 2013, as the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Facility Name	Class	Address	GIS Unit ID #
Pinetree Power, Inc.	III	1241 Whitefield Rd Bethlehem, NH 03574	MSS337
Pinetree Power-Tamworth, Inc.	III	469 Plains Rd Tamworth, NH 03886	MSS592
Public Service Company of New Hampshire (PSNH) Schiller Station # 5	I	400 Gosling Rd Portsmouth, NH 03801	MSS557
Indeck	I	151 Smith River Road Alexandria, NH 03222	MSS14211

The following plant tested as required pursuant to RSA 362-F on May 16, 2013 and DES has recommended recertification for the third quarter of 2013; however, it continues to be ineligible for the second quarter of 2013:

Facility Name	Class	Address	GIS Unit ID #
Springfield Power, LLC	I/III	54 Fisher Corner Road Springfield, NH 03284	MSS436

The following plant applied for conditional approval to generate RECs, but has not yet begun operation:

Facility Name	Class	Address	GIS Unit ID #
Berlin Station, LLC	I	One Community Street Berlin, NH 03570	(not yet issued)

If you have any questions regarding DES's recommendations, please contact Joe Fontaine at joseph.fontaine@des.nh.gov or 603-271-6794. Other questions should be directed to Barbara Bernstein at barbara.bernstein@puc.nh.gov or 603-271-6011.

Sincerely,



Debra A. Howland
Executive Director

cc: Joe Fontaine, NHDES