

THE STATE OF NEW HAMPSHIRE

CHAIRMAN
Amy L. Ignatius

COMMISSIONERS
Michael D. Harrington
Robert R. Scott

EXECUTIVE DIRECTOR
Debra A. Howland



PUBLIC UTILITIES COMMISSION
21 S. Fruit Street, Suite 10
Concord, N.H. 03301-2429

TDD Access: Relay NH
1-800-735-2954

Tel. (603) 271-2431

FAX (603) 271-3878

Website:
www.puc.nh.gov

November 8, 2013

James Webb
Registry Administrator
APX Environmental Markets
224 Airport Parkway, Suite 600
San Jose, CA 95110

Re: **Quarterly Emissions Verification Summary for Certified Renewable Energy Sources**
 DE 08-024 Pinetree - Bethlehem DE 08-044 Schiller Station #5
 DE 08-051 Pinetree Power - Tamworth DE 09-008 Indeck
 DE 09-104 Springfield Power DE 12-091 Berlin Station (under construction)

Dear Mr. Webb:

Pursuant to RSA 362-F:11, III, Renewable Portfolio Standard eligibility determinations of generation facilities that use biomass fuels are conditional. Within ten days of receiving the quarterly notice from the New Hampshire Department of Environmental Services (DES) that a facility has met DES emissions standards, the Commission must designate the facility as eligible to produce Renewable Energy Certificates.

Based on the DES recommendation received October 31, 2013, the Commission hereby certifies the following wood-fired power plants as renewable energy sources for the third quarter of 2013, as the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

| Facility Name | Class | Address | GIS Unit ID # |
|---|-------|--|---------------|
| Pinetree Power, Inc. | III | 1241 Whitefield Rd Bethlehem, NH 03574 | MSS337 |
| Pinetree Power-Tamworth, Inc. | III | 469 Plains Rd Tamworth, NH 03886 | MSS592 |
| Public Service Company of New Hampshire (PSNH) Schiller Station # 5 | I | 400 Gosling Rd Portsmouth, NH 03801 | MSS557 |
| Indeck | I | 151 Smith River Road Alexandria, NH 03222 | MSS14211 |
| Springfield Power, LLC ¹ | I/III | 54 Fisher Corner Road Springfield, NH 03284 | MSS436 |

¹ The Springfield Power biomass facility tested as required pursuant to RSA 362-F on May 16, 2013 and DES has recommended recertification for the third quarter of 2013; it is now eligible to generate RECs for the third quarter of 2013.

The following plant applied for, and was granted conditional approval to generate RECs, but has not yet begun operation:

| Facility Name | Class | Address | GIS Unit ID # |
|---------------------|-------|--|------------------|
| Berlin Station, LLC | I | One Community Street Berlin, NH 03570 | (not yet issued) |

If you have any questions regarding DES's recommendations, please contact Joe Fontaine at joseph.fontaine@des.nh.gov or 603-271-6794. Other questions should be directed to Barbara Bernstein at barbara.bernstein@puc.nh.gov or 603-271-6011.

Sincerely,



Debra A. Howland
Executive Director

cc: Robert Olson, Esq. on behalf of Springfield Power
Joe Fontaine, NHDES