

THE STATE OF NEW HAMPSHIRE

CHAIRMAN
Amy L. Ignatius

COMMISSIONERS
Robert R. Scott
Martin P. Honigberg

EXECUTIVE DIRECTOR
Debra A. Howland



PUBLIC UTILITIES COMMISSION
21 S. Fruit Street, Suite 10
Concord, N.H. 03301-2429

TDD Access: Relay NH
1-800-735-2964

Tel. (603) 271-2431

FAX (603) 271-3878

Website:
www.puc.nh.gov

February 7, 2014

James Webb
Registry Administrator
APX Environmental Markets
224 Airport Parkway, Suite 600
San Jose, CA 95110

Re: **Quarterly Emissions Verification Summary for Certified Renewable Energy Sources**

DE 08-024	Pinetree - Bethlehem	DE 09-104	Springfield Power
DE 08-044	Schiller Station #5	DE 12-091	Berlin Station
DE 08-051	Pinetree Power - Tamworth	DE 13-265	Pinetree - Fitchburg
DE 09-008	Indeck		

Dear Mr. Webb:

Pursuant to RSA 362-F:11, III, Renewable Portfolio Standard eligibility determinations of generation facilities that use biomass fuels are conditional. Within ten days of receiving the quarterly notice from the New Hampshire Department of Environmental Services (DES) that a facility has met DES emissions standards, the Commission must designate the facility as eligible to produce Renewable Energy Certificates.

Based on the DES recommendation received January 31, 2014, the Commission hereby certifies the following wood-fired power plants as renewable energy sources for the fourth quarter of 2013, as the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Facility Name	Class	Address	NH Facility Code #	GIS Unit ID #
Pinetree Power, Inc.	III	1241 Whitefield Rd., Bethlehem, NH 03574	NH-III-08-004	MSS337
Pinetree Power-Tamworth, Inc.	III	469 Plains Rd., Tamworth, NH 03886	NH-III-08-005	MSS592
PSNH Schiller Station # 5	I	400 Gosling Rd., Portsmouth, NH 03801	NH-I-08-006	MSS557
Indeck	I	151 Smith River Rd., Alexandria, NH 03222	NH-I-10-033	MSS14211
Springfield Power, LLC	I/III	54 Fisher Corner Rd., Springfield, NH 03284	NH-I-10-030	MSS436
			NH-III-10-029	
Pinetree Power-Fitchburg, Inc. ¹	III	4 Rowtier Dr., Westminster, MA 01473	NH-III-13-133	MSS538


¹ Pinetree Power-Fitchburg, was conditionally approved for Class III NH RECs December 16, 2013.

The following plant applied for, and was granted conditional approval to generate RECs, but has not yet conducted an initial stack test to determine TSP emissions and is, therefore, not eligible for 4th quarter, 2013 RECs:

Facility Name	Class	Address	NH Facility Code #	GIS Unit ID #
Berlin Station, LLC	I	One Community S., Berlin, NH 03570	NH-I-12-019	(not yet issued)

If you have any questions regarding the DES recommendations, please contact Joe Fontaine at joseph.fontaine@des.nh.gov or 603-271-6794. Other questions should be directed to Barbara Bernstein at barbara.bernstein@puc.nh.gov or 603-271-6011.

Sincerely,



Debra A. Howland
Executive Director

cc: Joe Fontaine, NHDES