


THE STATE OF NEW HAMPSHIRE

CHAIRMAN
Thomas B. Getz

COMMISSIONERS
Clifton C. Below
Amy L. Ignatius

EXECUTIVE DIRECTOR
AND SECRETARY
Debra A. Howland



PUBLIC UTILITIES COMMISSION

21 S. Fruit Street, Suite 10
Concord, N.H. 03301-2429

Tel. (603) 271-2431


FAX (603) 271-3878

TDD Access: Relay NH
1-800-735-2964

Website:
www.puc.nh.gov

June 10, 2010

Stephanie Lovejoy Hamilton
Conservation Services Group
40 Washington Street
Westborough, MA 01581



Re: DE 10-156, Conservation Services Group's Certification Application
Pursuant to RSA 362-F on behalf of Princeton Crossing L. P.
Request for Additional Information

Dear Ms. Hamilton:

On June 2, 2010, the New Hampshire Public Utilities Commission (Commission) received an application from Conservation Services Group on behalf of Princeton Crossing L. P. (Princeton Crossing) requesting certification for the Princeton Properties photovoltaic facility as a Class II renewable energy source pursuant to RSA 362-F, New Hampshire's Renewable Portfolio Standard law. Staff has reviewed your application and has noted the following items that must be addressed before your application is considered complete:


- 1.) Section II of your application identifies one 3,524 kilowatt (kW) photovoltaic facility located at 12 Heritage Drive, Salem, Massachusetts. However, the interconnection agreement lists 17 facilities, one of which is a 3.84 kW facility that is also located at 12 Heritage Drive, Salem Massachusetts. Does Princeton Crossing wish to certify only one facility or all 17 facilities listed in the interconnection agreement? If Princeton Crossing wants to certify all of the facilities, does it also request aggregator status pursuant to N.H. Code of Administrative Rules Puc 2506?
- 2.) Attachment 1 of the interconnection agreement states that Massachusetts Electric Company (MEC) will install new bidirectional power flow meters at each

location. Has MEC installed all of these meters? If so, please provide each facility's meter installation date.

- 3.) Have these facilities and the resulting aggregation been certified to receive renewable energy certificates under another state's renewable portfolio standard program? If so, please provide support.
- 4.) Attachment 2 of the interconnection agreement states that MEC will temporarily shut down the facilities before June 1, 2010 to test the anti-islanding protection of the inverters. Has MEC completed such tests?

These items must be received by the Commission to complete your application. Until such time as your application is complete, it will not be processed. If the requested documentation is not provided within ten business days, your file will be closed without prejudice. Please refer to docket number DE 10-156 in all future correspondence with the Commission. Should you have any questions, please do not hesitate to contact me. My phone number is 603-271-2431 and my e-mail is maureen.reno@puc.nh.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Maureen L. Reno', with a stylized flourish at the end.

Maureen L. Reno
Utility Analyst III

cc: Suzanne Amidon
Staff Attorney