


THE STATE OF NEW HAMPSHIRE



Tel. (603) 271-2431

FAX (603) 271-3878

TDD Access: Relay NH
1-800-735-2964

Website:
www.puc.nh.gov

CHAIRMAN
Thomas B. Getz

COMMISSIONERS
Clifton C. Below
Amy L. Ignatius

EXECUTIVE DIRECTOR
AND SECRETARY
Debra A. Howland

PUBLIC UTILITIES COMMISSION
21 S. Fruit Street, Suite 10
Concord, N.H. 03301-2429

August 24, 2011

Scott C. McNeil
Field Administrator
New Hampshire Electric Cooperative, Inc.
579 Tenney Mountain Highway
Plymouth, NH 03264

Re: DE 11-172, and DE 11-173, New Hampshire Electric Cooperative, Inc.
Certification Applications for Class II Renewable Energy Certificate Eligibility
Pursuant to RSA 362-F on behalf of homeowners David V. Scerra and Robert
Dutton.

Dear Mr. McNeil:

On August 9, 2011 you submitted an application on behalf of homeowners David V. Scerra (Scerra) and Robert Dutton (Dutton) requesting certification of their customer-sited photovoltaic array as eligible to produce Class II renewable energy certificates (RECs) pursuant to RSA 362-F, New Hampshire's Electric Renewable Portfolio Standard law. Staff has reviewed these applications and has recommended approval of both the Scerra and Dutton facilities as eligible for Class II RECs effective August 9, 2011.


Since the facilities are both customer-sited sources, the output is not recorded in the New England Power Pool Market Settlement System and, as a result, the output must be monitored and verified by an independent monitor. Your application states that NHEC will monitor the facilities' output as required by N.H. Code of Administrative Rules Puc 2505.08 and 2505.09. Both facilities' total output will also be included in the *NHEC Class II Aggregation's* total output reported to the NEPOOL Generation Information System as approved by the Commission on April 9, 2010.

The details for each facility are listed in the following table.

Docket #	Facility Owner	Facility Location	Operation Date ¹	Total kW listed in application (DC Arrays)	Effective Date to Produce RECs ²	NH Certification Code
DE 11-172	David V. Scerra	Campton, NH	07/18/11	4.140	08/09/11	NH-II-11-026
DE 11-173	Robert Dutton	North Conway, NH	07/22/11	8.4	08/09/11	NH-II-11-027

The Commission has determined that NHEC has provided all the information necessary to demonstrate these facilities' eligibility for certification and hereby certifies the Scerra and Dutton photovoltaic arrays as eligible to receive Class II RECs effective August 9, 2011.

Sincerely,



Debra A. Howland
Executive Director

¹ NHEC considers the operation date listed in the table above, and in Exhibit E of each application, to be the date on which NHEC inspected each facility and installed a revenue quality meter to record the electricity that will be eligible for Class II RECs. The date listed in each interconnection application pertains to the installation and interconnection of the facility and may be different than the operation date listed in the above table.

² This is the effective date to produce RECs if the Commission approves this facility eligible to produce Class II RECs.