



Spanmaster ® Release 3.1 Sag / Tension Computations


						E*A LOAD	MAX.
	X-SECT	EFF	NOMINAL	EFF.EXP.	CABLE	BEARING	RATED
	AREA	MODULUS	DIAM	COEFF.	WEIGHT	CAPACITY	LOAD
Selected Cables	(sq.in)	(psi)	(in)	(1/F)	(lb/ft)	(lbs)	(lbs)
1/4"6.6mEHS	0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	6650
ORF-O-288-LN	0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	651
Rundle			1 100		0.2170		

River and Rail Crossings

NESC RESULTS

Loading Condition	Temp. (F)	lce Load lb/ft	fce Thick in	Wind Constant lb/ft	Wind Load lb/sq ft	Load + Const Ib/ft	Sag ft	Tension Ib	% Len Chg From Input Conditions	Sag (b) Point 115.5 ft	Sag Comp ft	Vert Sag Comp ft	Vector Angle Deg	
Rule 251 - Heavy	0.0	1.000	.50	.3	4.0	1.793	5.23	2279	0.11	5.25	2.46	4.62	28.1	
232A1	120.0	0.000	.00	.0	0.0	0.317	2.77	764	0.01	2.77	0.00	2.77	0.0	

		Temp	Midspan	Tension	% Length	Clearance	
Span L	ength = 231.00 ft	(F)	Sag (ft)	(lb)	Change		
	ag = 2.31 ft (27.7 in)						
	ension = 915 lb	-40.0	1.57	1,345	-0.01	N/A	
M	ax Load = 6,650 lb	-30.0	1.62	1,301	-0.01	N/A	
	Usable load (60%) = 3,990 lb	-20.0	1.68	1,258	-0.01	N/A	
	ry Length = 231.062 ft	-10.0	1.73	1,216	-0.01	N/A	
	Free Length @	.0	1.80	1,175	-0.01	N/A	
Installed Temperature = 230.831 ft		10.0	1.86	1,135	-0.01	N/A	
		20.0	1.93	1,095	-0.01	N/A	
	ed Strand	30.0	2.00	1,057	-0.01	N/A	
Sag = 1.11 ft (13.3 in)		40.0	2.07	1,019	-0.01	N/A	
Tens	ion = 727 lb	50.0	2.15	983	0.00	N/A	
		60.0	2.23	948	0.00	N/A	
		70.0	2.31	914	0.00	N/A	
		80.0	2.40	881	0.00	N/A	
		90.0	2.48	850	0.00	N/A	
		100.0	2.58	820	0.01	N/A	
		110.0	2.67	791	0.01	N/A	
		120.0	2.77	764	0.01	N/A	
		130.0	2.86	738	0.01	N/A	
		140.0	2.96	713	0.02	N/A	



Construction Notes:

NHOS proposes to install a ¼ inch metal supporting strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole



<u>E-318/29 - T-149/16</u>

New Hampshire Optical Systems
New Hampshire Optical Systems, Inc.

99 Pine Hill Rd.

Nashua, NH 03063 (603-821-6467)

> Proposed River Crossing Lee, NH

Notes:

- The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on 10/06/11.
- The horizontal distance between the nearest bridge edge and the existing overhead wires ranges from 5' to 6'.
- The smallest vertical distance from the top of existing bridge deck to the lowest existing overhead wires is 19'.
- 4. Because of the close horizontal proximity to the existing bridge structure, the simplified drawing is submitted with vertical distances measured to the structure. This process simplifies the preparation and review of the crossing without jeopardizing its intent to protect the safe usage of the waterway.
- The vertical distance between the top of water and bridge deck is approximately 8'.
- Vertical distances are representative of attachment heights after utility make ready moves are completed.

Project # TID-192 - Lateral 15 Drawing # AC-LEE-RIV-1

Date: 5/15/13

Proposed River Crossing Lee. NH

<u>Location:</u> Lee Rd., Lee, NH Nearest cross street- Randall Rd.

Sheet 2 of 2

E-318/28 - T-149/17

 $\wgf-fs1\cad\Projects\USNH\dwgs\Lee\River-xing\tid-192\TID-192.dwg$