


January 3, 2013



Ms. Debra Howland
Executive Director and Secretary
State of New Hampshire
Public Utilities Commission
21 S. Fruit Street Suite 10
Concord, NH 03301-2429

Ms. Howland,

Solar Farm Bank LLC (SFB) would like to have this cover letter included in the application docket number DE 12-343 for certification by the New Hampshire Public Utilities Commission (Commission) for Class II REC of the photovoltaic array for our account:

Applecrest Farm Orchards, LLC (Applecrest Farm Orchards)

Peter Wagner

133 Exeter Road

Hampton, NH 03844

603-926-3721 pbwags@comcast.net

SFB is also interest in being an aggregator of sources that generate RECs, we are including a request in this cover letter asking to be approved as an aggregator of NH RECs.

Barbara Bernstein correctly pointed out that there is a difference between what was submitted by Mr. George Horrocks calculation of the system's output at 39.78 kilowatts (kW), and the amount on the Interconnection Agreement provided by Unitil Energy Systems which lists the nameplate capacity as 42 kW.

After careful review both are in fact correct:

- Output is calculated by taking the number of panels (156) and multiplying the Watts rating of each panel (255) = output of 39.78kW
- The Nameplate capacity of 42kW There are 6 SMA SB7000US 7KW inverters (6 x 7KW = 42KW)

Both calculations seem to be stated in the appropriate lines in the Attachments and the Application. I have talked to Mr. Horrocks, and he is willing to speak directly with Barbara to sort out any confusion as he has a greater intimate knowledge of the system.

The GIS administrator has assigned the Applecrest Orchard Asset Identification Number NON35889.

I am hopeful that this cover letter addresses the concerns and comments raised by the attached follow up letter. If you have additional questions, please feel free to contact me at solarfarmbank@verizon.net 508-259-2419.

Thank you,


Stephen Hirsh,
President