



780 N. Commercial Street  
P. O. Box 330  
Manchester, NH 03105-0330

**Christopher J. Allwarden**  
Senior Counsel

603-634-2459  
christopher.allwarden@eversource.com

May 10, 2019

NHPUC 10MAY19PM4:08

VIA HAND DELIVERY AND ELECTRONIC MAIL

Debra A. Howland, Executive Director & Secretary  
New Hampshire Public Utilities Commission  
21 South Fruit Street, Suite 10  
Concord, NH 03301

**Re: Docket DE 19-004 - Public Service Company of New Hampshire d/b/a  
Eversource Energy – Petition For License to Construct and Maintain Electric Lines  
Over and Across Dudley Brook in the Town of Brentwood, New Hampshire**

Dear Ms. Howland:


I write to inform the Commission of Eversource's need to make certain revisions to its petition and certain exhibits filed in the above Docket. After submittal of the original petition on January 7, 2019, Eversource has determined that soil conditions at the location of the set areas of certain of the proposed new crossing structures are not satisfactory. As a result, certain of the proposed new crossing structures have been shifted in design to more stable ground locations. This has involved not only an adjustment in certain pole locations, but also results in changes in span length over Dudley Brook, and increases in certain pole heights to maintain required sag clearances.

Accordingly, I enclose for filing with the Commission an original and six copies of REVISED page 1 and REVISED page 2 of the petition, and a REVISED Exhibit 2 plan and profile drawing for each line crossing. We have underlined within the revised petition pages the changes from the original pages. In summary, structure 222 of the A126 Line is moving from 15 feet east to 5 feet west of current location; structure 198 of the H141 Line is moving from 10 feet west to 25 feet west of current location; both structures 198 and 222 are changing in height from 70 feet AGH to 75 feet AGH; the span lengths for the crossing spans are increasing for each line; and, design clearances at maximum sag are slightly increasing for each crossing while still exceeding the minimums required.

We apologize in advance for any inconvenience or delays resulting from the need to make these revisions, and appreciate the understanding of the Commission and its Staff.

As required by the Commission's rules, an electronic filing of this letter and associated enclosures is being made with the Commission on this date. If there are any technical questions concerning this filing, they may be directed to Jeremy Fennell, Senior Environmental Specialist, who can be reached at 603-634-3396, or to the undersigned. Thank you for your assistance.

Very truly yours,

A handwritten signature in black ink, appearing to read "C. J. Allwarden", written in a cursive style.

Christopher J. Allwarden  
Senior Counsel

cc: J. Fennell  
P. Kasper, PUC Safety Division  
OCA