

STATE OF NEW HAMPSHIRE

Inter-Department Communication

NHPUC 1JUL'19PM4:19

DATE: July1, 2019

AT (OFFICE): NHPUC

FROM: Randy Knepper
Director, Safety Division

RSK

SUBJECT: Docket No. DE 19-004 Public Service New Hampshire d/b/a
Eversource Energy Revised Petition for a License to Construct and
Maintain Electric Lines Over and Across the Dudley Brook in the
Town of Brentwood, New Hampshire
REVISED Staff Recommendation

TO: Debra Howland, Executive Director
Thomas Frantz, Director, Electric Division
Rich Chagnon, Assistant Director, Electric Division
Mary Schwarzer, Staff Attorney

CC: Paul Kasper, Assistant Director, Safety Division

The Safety Division reviewed Eversource's changes to the two circuits A126 and H141 115 kV Circuits. Eversource filed revisions to its petition on May 10, 2019 after Staff's previous recommendation filed April 22, 2019.

The revisions were as follows:

- Structure 222 of the A126 Line is moving from 15 feet east to 5 feet west of current location, a net difference of 20 feet.
- Structure 198 of the H141 Line is moving from 10 feet west to 25 feet west of current location, a net difference of 15 feet.
- Both structures 198 and 222 are changing in height from 70 feet AGH to 75 feet above ground, a net difference of 5 feet vertical at one end of each span.
- The span lengths for the crossing spans are increasing for each line from 586.92 linear feet (H147 structure 197 to structure 198) to 601.92 feet; a net difference of 15 feet horizontal.
- The span lengths for the crossing spans are increasing for each line from 511 linear feet (A126 structure 221 to structure 222) to 531 feet; a net difference of 20 feet horizontal.

All clearances are greater than those in the initial petition, thus Staff determined the revised petition does not change Staff's previous recommendations.

Attachments




Figure 1: 115kV line, designated as the A126 Transmission Line, is a span of approximately 531 feet between structures #221 and # 222, across the Dudley Brook in Brentwood, NH.





Figure 1: 115kV line, designated as the H141 Transmission Line, is a span of approximately 601.92 feet between structures # 197 and #198, across the Dudley Brook in Brentwood, NH.



View Service Lists

Home (../Regulatory/regulatory.htm)	Search (../ServiceLists/ViewServiceList.aspx)	A A A
---	---	-------

Service List - Docket Related

Docket# : 19-004

Printed: 7/1/2019

Email Addresses

ExecutiveDirector@puc.nh.gov
 robert.bersak@eversource.com
 paul.dexter@puc.nh.gov
 tom.frantz@puc.nh.gov
 Paul.Kasper@puc.nh.gov
 randy.knepper@puc.nh.gov
 amanda.noonan@puc.nh.gov
 ocalitigation@oca.nh.gov
 Mary.Schwarzer@puc.nh.gov
 leszek.stachow@puc.nh.gov

Without Email Addresses

All

ExecutiveDirector@puc.nh.gov
 Robert Bersak
 Eversource Energy
 780 N Commercial St.
 Manchester NH 03105-0330
 robert.bersak@eversource.com
 Paul Dexter
 New Hampshire Public Utilities Commission
 21 South Fruit St Ste 10
 Concord NH 03301
 paul.dexter@puc.nh.gov

Thomas Frantz
NH Public Utilities Commission
21 South Fruit St Ste 10
Concord NH 03301
tom.frantz@puc.nh.gov

Paul Kasper
New Hampshire Public Utilities Commission
Paul.Kasper@puc.nh.gov

Randy Knepper
New Hampshire Public Utilities Commission
21 South Fruit St Ste 10
Concord NH 03301
randy.knepper@puc.nh.gov

Amanda Noonan
NH Public Utilities Commission
21 South Fruit St Ste 10
Concord NH 03301
amanda.noonan@puc.nh.gov

OCA Litigation
OCA Litigation
21 South Fruit St Ste 18
Concord NH 03301
ocalitigation@oca.nh.gov

Mary Schwarzer
New Hampshire Public Utilities Commission
Mary.Schwarzer@puc.nh.gov

Leszek Stachow
New Hampshire Public Utilities Commission
21 South Fruit St Ste 10
Concord NH 03301
leszek.stachow@puc.nh.gov