

STATE OF NEW HAMPSHIRE

CHAIRMAN
Martin P. Honigberg

COMMISSIONERS
Kathryn M. Bailey
Michael S. Giarmo

EXECUTIVE DIRECTOR
Debra A. Howland



TDD Access: Relay NH
1-800-735-2964

Tel. (603) 271-2431

FAX No. 271-3878

Website:
www.puc.nh.gov

PUBLIC UTILITIES COMMISSION
21 S. Fruit St., Suite 10
Concord, N.H. 03301-2429

June 6, 2019

Eric Kingsley
Innovative Natural Resource Solutions LLC
63 Federal Street, Suite 5
Portland, Maine 04101

Re: REC-19-103 and RREC 18-0492 North Conway Memorial Hospital
Use of an Alternative Metering Method (Puc 2506.06(c) and Puc 2506.04(f)(3)) and
Preliminary Designation (Puc 2505.03)

Dear Mr. Kingsley:

On May 31, 2018, you filed a request for preliminary designation under N.H. Code Admin. Rules Puc 2505.03 for the thermal facility at North Conway Memorial Hospital (Memorial Hospital) as a Class I Thermal renewable energy source. As part of the request for preliminary designation, you requested review and approval of a proposed alternative metering method under Puc 2506.06(c) for metering of useful thermal energy produced by the Memorial Hospital thermal facility.

Commission Staff reviewed your filing and supplemental materials related to the alternative metering method that were subsequently provided. Staff analyzed the proposed alternative metering method and recommended that the Commission approve that alternative metering method, as set forth in its memorandum filed on June 5, 2019.

The Commission has reviewed Staff's recommendation regarding the proposed alternative metering method, and has approved that alternative metering method, having found that the method meets the provisions of Puc 2506.06(c). Final facility authorization will be conditioned upon submission, after meter installation, of all required meter information, including a Professional Engineer certification that meters were installed and will be operated to the manufacturer's specifications, and, as installed, meet the accuracy requirements of Puc 2506.04(f)(3). In addition, the applicant must include a description of the method and frequency of reporting production to NEPOOL GIS and any changes to the facility, or preliminary designation application, and all other application materials, which may affect the eligibility of the source.

Sincerely,

A handwritten signature in black ink that reads "Debra A. Howland" with a stylized flourish at the end.

Debra A. Howland
Executive Director

cc: Service List
Docket File

Executive.Director@puc.nh.gov

amanda.noonan@puc.nh.gov

david.wiesner@puc.nh.gov

karen.cramton@puc.nh.gov

kingsley@inrslc.com