

Public Service of New Hampshire d/b/a Eversource Energy
Docket No. DE 20-005

Date Request Received: 05/28/2020

Date of Response: 06/12/2020

Request No. STAFF 1-010

Page 1 of 2

Request from: New Hampshire Public Utilities Commission Staff

Witness: Catherine Finneran

Request:

Please provide for each week of the project the total amount of mercury emitted from containment venting or through stacks to the ambient environment. Please explain how the amounts were calculated.

Response:

Daily emissions were calculated during the specified periods below utilizing the three compliance methods described. Documentation of daily emissions for these three compliance methods are provided in the following attachments. Attachment Staff 1-010 A contains the Adjusted In-Stack Emissions during the period 01-18-17 through 04-24-17. Attachment Staff 1-010 B contains Mercury Air Dispersion Emissions during the 04-25-17 through 06-16-17 time period. Attachment Staff 1-010 C, Attachment Staff 1-010 D, and Attachment Staff 1-010 E contain weekly reporting on mercury air emissions under the alternative method during the 2017, 2018, and 2019 time periods, respectively.

Adjusted In-Stack Period (01-18-17 thru 04-24-17)

Initially, the exhaust of each of the individual work containment area was monitored to remain under the exemption of Env-A 1403.03(a)(2) using the adjusted in-stack concentration method and calculation described in Env-A 1405.05 (utilized from January 18, 2017 through April 24, 2017). The requirements resulted in the temporary installation of up to 97 individual exhaust fans with their associated exhaust flows. Fans were combined as necessary to a series of temporary, vertical and unobstructed stacks. Work was confined to removal of smaller components and the remaining mercury released from the torch cutting was closely monitored and remained well below the exemption requirements. Where possible, areas suspected of still containing some remaining mercury were inspected and further drained of liquid mercury to the extent possible prior to operations that might cause the mercury to vaporize (e.g. torch cutting). TRC utilized Jerome Meters or other methods to determine the mercury concentration exiting the respective containment exhaust. This monitoring was performed approximately every three to four hours during active work and all data was recorded to demonstrate compliance with the Ambient Air Limit (AAL) using the adjusted in-stack concentration method described in Env-A 1405.05(c) and exemption from permitting of Env-A 1403.3(a)(2). In order to facilitate direct monitoring of exhaust concentrations for compliance, a project-specific in-stack compliance value of 0.105 mg/m³ was derived from the mercury AALs as follows:

$$\text{Adjusted In-stack Concentration } \left(\frac{\mu\text{g}}{\text{m}^3} \right) = \frac{\text{In-stack Concentration } \left(\frac{\mu\text{g}}{\text{m}^3} \right)}{700}$$

$$\therefore \text{In-stack Concentration } \left(\frac{\mu\text{g}}{\text{m}^3} \right) = \text{Adjusted In-stack Concentration } \left(\frac{\mu\text{g}}{\text{m}^3} \right) \times 700$$

Using the AAL for Mercury of $0.30 \mu\text{g}/\text{m}^3$, and limiting the adjusted in-stack concentration to 50% of the AAL (or $0.15 \mu\text{g}/\text{m}^3$), the above equation yields:

$$\text{Project – Specific Compliance Value} \left(\frac{\mu\text{g}}{\text{m}^3} \right) = \text{Hg AAL} \times 50\% \times 700 = 0.15 \frac{\mu\text{g}}{\text{m}^3} \times 700$$

$$\therefore 105 \frac{\mu\text{g}}{\text{m}^3} \times \frac{1 \text{ mg}}{1000 \mu\text{g}} = 0.105 \frac{\text{mg}}{\text{m}^3}$$

Air Dispersion Model Modified Period – 50% of AAL (04-25-17 thru 06-14-17)

From April 25, 2017 to June 14, 2017, the containment area exhausts were combined to a single discharge through a temporary constructed common plenum and exhausting to atmosphere utilizing an existing abandoned 226' high stack (STSR5). Additionally, an in-situ mercury monitor and pitot tube (for exhaust flow measurement) were installed in the plenum. The method of compliance was modified to the use of the Air Dispersion Modeling Analysis method described in Env-A 1405.02 and exemption from permitting of Env-A 1403.3(a)(3). This exemption allows for a compliance demonstration that mercury air emissions remain less than 50 percent of the annual and 24-hour AAL for mercury using the air dispersion modeling analysis method described in Env-A 1405.02.

Alternative Method Period – >50% of AAL (06-15-17 thru 02-13-19)

In anticipation of increased work intensity and the potential for short term increases in mercury emissions, a request was made to the NHDES and the approval granted on October 10, 2017 of an Alternative Method for Determining Compliance to allow for short term increases in mercury emissions beyond 50% of the AAL. Prior to NHDES issuance of approval of the alternative method on October 10, 2017, compliance was based upon the same methodology as cited in the June 2017 request, except the maximum emission rate allowed was 50% of the AAL for mercury. Therefore, compliance with limits requested in that application were documented by monitoring air flows and mercury emissions on a continuous basis at the temporary common breaching to the existing stack for the duration of the remainder of the demolition project. The project experienced a shutdown from mid-June, 2017 to the project restart in late August, 2017. During the project shutdown period MBI worked with TRC and Eversource to assess work practices, equipment and project challenges to limit mercury emissions to the extent practical and reduce potential worker exposure. Following the shutdown, routine review of individual demolition activities that might contribute to higher mercury emissions were performed. Operations were assessed in more detail and adjustments made as needed to reduce mercury emissions and maintain compliance.

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-18-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.006	7.75	0.006	7.75	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,511			
0.00	0.008	7.75	0.008	7.75	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	671			
0.00	0.008	7.75	0.008	7.75	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,007			
0.00	0.005	7.75	0.005	7.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	420			
0.00	0.008	7.75	0.008	7.75	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,343			
0.00	0.007	7.75	0.007	7.75	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	734			
0.00	0.004	7.75	0.004	7.75	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	504			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	6,189	0.0066	300,807	0.1520
7.75	0.006	9.75	0.017	9.75	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	747			
7.75	0.008	9.75	0.015	9.75	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	249			
7.75	0.008	9.75	0.012	9.75	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	325			
7.75	0.005	9.75	0.012	9.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	184			
7.75	0.008	9.75	0.011	9.75	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	411			
7.75	0.007	9.75	0.009	9.75	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	217			
7.75	0.004	9.75	0.009	9.75	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	211			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	2,344	0.0096	298,463	0.1719
9.75	0.017	11.25	0.032	11.25	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,194			
9.75	0.015	11.25	0.027	11.25	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	341			
9.75	0.012	11.25	0.028	11.25	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	487			
9.75	0.012	11.25	0.032	11.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	357			
9.75	0.011	11.25	0.024	11.25	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	569			
9.75	0.009	11.25	0.022	11.25	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	315			
9.75	0.009	11.25	0.024	11.25	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	402			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	3,665	0.0201	294,798	0.1898
11.25	0.032	13.33	0.058	13.33	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,041			
11.25	0.027	13.33	0.039	13.33	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	676			
11.25	0.028	13.33	0.033	13.33	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,030			
11.25	0.032	13.33	0.046	13.33	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	878			
11.25	0.024	13.33	0.049	13.33	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,644			
11.25	0.022	13.33	0.033	13.33	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	774			
11.25	0.024	13.33	0.051	13.33	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,267			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	9,311	0.0367	285,487	0.2196
13.33	0.058	23.99	0.058	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	20,086			
13.33	0.033	23.99	0.033	23.99	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,809			
13.33	0.033	23.99	0.033	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	5,714			
13.33	0.046	23.99	0.046	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	5,310			
13.33	0.049	23.99	0.049	23.99	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	11,313			
13.33	0.033	23.99	0.033	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	4,762			
13.33	0.051	23.99	0.051	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	8,831			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	59,824	0.0461	225,663	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0278		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-19-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.058	8.08	0.076	8.08	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	17,587			
0.00	0.033	8.08	0.049	8.08	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,587			
0.00	0.033	8.08	0.046	8.08	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	5,184			
0.00	0.046	8.08	0.048	8.08	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	4,112			
0.00	0.049	8.08	0.067	8.08	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	10,150			
0.00	0.033	8.08	0.059	8.08	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	5,031			
0.00	0.051	8.08	0.075	8.08	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	8,268			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	53,920	0.0548	253,077	0.1305
8.08	0.076	10.50	0.064	10.50	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	5,503			
8.08	0.049	10.50	0.064	10.50	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,481			
8.08	0.046	10.50	0.059	10.50	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,064			
8.08	0.048	10.50	0.048	10.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,258			
8.08	0.067	10.50	0.05	10.50	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,066			
8.08	0.059	10.50	0.049	10.50	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,769			
8.08	0.075	10.50	0.05	10.50	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,457			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	17,597	0.0597	235,480	0.1432
10.50	0.064	13.08	0.033	13.08	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	4,065			
10.50	0.064	13.08	0.046	13.08	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,537			
10.50	0.059	13.08	0.059	13.08	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,473			
10.50	0.048	13.08	0.026	13.08	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,034			
10.50	0.05	13.08	0.021	13.08	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,984			
10.50	0.049	13.08	0.021	13.08	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,222			
10.50	0.05	13.08	0.02	13.08	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,467			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	13,781	0.0438	221,699	0.1667
13.08	0.033	15.08	0.032	15.08	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,112			
13.08	0.046	15.08	0.029	15.08	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	812			
13.08	0.059	15.08	0.024	15.08	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,348			
13.08	0.026	15.08	0.025	15.08	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	552			
13.08	0.021	15.08	0.027	15.08	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,040			
13.08	0.021	15.08	0.027	15.08	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	650			
13.08	0.02	15.08	0.026	15.08	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	747			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	7,261	0.0298	214,438	0.1973
15.08	0.032	23.99	0.032	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	9,263			
15.08	0.029	23.99	0.029	23.99	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,798			
15.08	0.024	23.99	0.024	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,473			
15.08	0.025	23.99	0.025	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,412			
15.08	0.027	23.99	0.027	23.99	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	5,210			
15.08	0.027	23.99	0.027	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	3,256			
15.08	0.026	23.99	0.026	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,763			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										72,000	33.8400	30,176	0.0278	184,263	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0420		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STOCK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-20-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.018	7.92	0.018	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	4,631				
0.00	0.017	7.92	0.017	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,458				
0.00	0.017	7.92	0.017	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,187				
0.00	0.019	7.92	0.019	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,630				
0.00	0.037	7.92	0.037	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	6,347				
0.00	0.016	7.92	0.016	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,715				
0.00	0.057	7.92	0.057	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	7,333				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										72,000	33,8400	25,300	0.0262	281,696	0.1438
7.92	0.018	10.25	0.052	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,649				
7.92	0.017	10.25	0.044	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	770				
7.92	0.017	10.25	0.04	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,079				
7.92	0.019	10.25	0.048	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	845				
7.92	0.037	10.25	0.046	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,094				
7.92	0.016	10.25	0.047	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	993				
7.92	0.057	10.25	0.045	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,930				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										72,000	33,8400	10,361	0.0365	271,336	0.1620
10.25	0.052	13.08	0.072	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	5,700				
10.25	0.044	13.08	0.064	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,655				
10.25	0.04	13.08	0.056	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,206				
10.25	0.048	13.08	0.067	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,762				
10.25	0.046	13.08	0.059	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,218				
10.25	0.047	13.08	0.058	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,011				
10.25	0.045	13.08	0.06	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,413				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										72,000	33,8400	18,966	0.0550	252,370	0.1897
13.08	0.072	14.75	0.014	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,333				
13.08	0.064	14.75	0.02	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	760				
13.08	0.056	14.75	0.018	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,004				
13.08	0.067	14.75	0.013	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	723				
13.08	0.059	14.75	0.011	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,266				
13.08	0.058	14.75	0.018	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	859				
13.08	0.06	14.75	0.004	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	868				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										72,000	33,8400	7,812	0.0384	244,557	0.2170
14.75	0.014	23.99	0.014	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	4,202				
14.75	0.02	23.99	0.02	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,001				
14.75	0.018	23.99	0.018	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,702				
14.75	0.013	23.99	0.013	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,301				
14.75	0.011	23.99	0.011	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,201				
14.75	0.018	23.99	0.018	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,251				
14.75	0.004	23.99	0.004	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	600				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										72,000	33,8400	15,259	0.0136	229,299	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0266			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-23-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)								
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION																
0.00	0.008	8.50	0.008	8.50	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,209											
0.00	0.009	8.50	0.009	8.50	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	828											
0.00	0.005	8.50	0.005	8.50	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	690											
0.00	0.007	8.50	0.007	8.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	644											
0.00	0.006	8.50	0.006	8.50	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,105											
0.00	0.006	8.50	0.006	8.50	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	690											
0.00	0.006	8.50	0.006	8.50	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	828											
0.00	0.011	8.50	0.011	8.50	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	2,531											
0.00	0.011	8.50	0.011	8.50	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	1,519											
										0	0.0000	0											
										0	0.0000	0											
Time Period Totals										97,600	45.8720	11,045	0.0079	405,105	0.1583								
8.00	0.008	10.50	0.032	10.50	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,624											
8.00	0.009	10.50	0.037	10.50	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	623											
8.00	0.005	10.50	0.034	10.50	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	792											
8.00	0.007	10.50	0.026	10.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	447											
8.00	0.006	10.50	0.025	10.50	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	839											
8.00	0.006	10.50	0.027	10.50	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	558											
8.00	0.006	10.50	0.023	10.50	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	589											
8.50	0.011	10.50	0.018	10.50	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	785											
8.50	0.011	10.50	0.018	10.50	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	471											
										0	0.0000	0											
										0	0.0000	0											
Time Period Totals										97,600	45.8720	6,728	0.0163	398,377	0.1787								
10.50	0.032	13.75	0.07	13.75	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	5,385											
10.50	0.037	13.75	0.067	13.75	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,830											
10.50	0.034	13.75	0.068	13.75	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,692											
10.50	0.026	13.75	0.085	13.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,953											
10.50	0.025	13.75	0.06	13.75	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,991											
10.50	0.027	13.75	0.067	13.75	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,068											
10.50	0.023	13.75	0.054	13.75	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,032											
10.50	0.018	13.75	0.018	13.75	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	1,584											
10.50	0.018	13.75	0.018	13.75	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	950											
										0	0.0000	0											
										0	0.0000	0											
Time Period Totals										97,600	45.8720	21,486	0.0400	376,892	0.2227								
13.75	0.07	15.25	0.039	15.25	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,656											
13.75	0.067	15.25	0.038	15.25	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	853											
13.75	0.068	15.25	0.036	15.25	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,267											
13.75	0.085	15.25	0.041	15.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,023											
13.75	0.06	15.25	0.035	15.25	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,543											
13.75	0.067	15.25	0.033	15.25	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,015											
13.75	0.054	15.25	0.037	15.25	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,109											
13.75	0.018	15.25	0.074	15.25	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	1,868											
13.75	0.018	15.25	0.074	15.25	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	1,121											
										0	0.0000	0											
										0	0.0000	0											
Time Period Totals										97,600	45.8720	12,454	0.0503	364,437	0.2522								
15.25	0.039	23.99	0.039	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	11,073											
15.25	0.038	23.99	0.038	23.99	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,596											
15.25	0.036	23.99	0.036	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	5,111											
15.25	0.041	23.99	0.041	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	3,880											
15.25	0.035	23.99	0.035	23.99	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	6,625											
15.25	0.033	23.99	0.033	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	3,904											
15.25	0.037	23.99	0.037	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	5,253											
15.25	0.074	23.99	0.074	23.99	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	17,509											
15.25	0.074	23.99	0.074	23.99	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	10,505											
										0	0.0000	0											
										0	0.0000	0											
Time Period Totals										97,600	45.8720	67,457	0.0467	296,980									
24 HR. ACTUAL COMPLIANCE TOTAL													0.0301										
24 HR. COMPLIANCE STANDARD													0.105										
													IN COMPLIANCE										

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-24-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)							
0.00	0.005	8.33	0.005	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,353										
0.00	0.006	8.33	0.006	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	541										
0.00	0.005	8.33	0.005	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	677										
0.00	0.006	8.33	0.006	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	541										
0.00	0.009	8.33	0.009	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,624										
0.00	0.007	8.33	0.007	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	789										
0.00	0.01	8.33	0.01	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,353										
0.00	0.068	8.33	0.068	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	15,335										
0.00	0.02	8.33	0.02	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	2,706										
									0	0.0000	0										
									0	0.0000	0										
Time Period Totals									97,600	45.8720	24,919	0.0181	391,232	0.1512							
8.33	0.005	10.83	0.071	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,086										
8.33	0.006	10.83	0.059	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	880										
8.33	0.005	10.83	0.051	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,137										
8.33	0.006	10.83	0.052	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	785										
8.33	0.009	10.83	0.041	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,354										
8.33	0.007	10.83	0.037	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	744										
8.33	0.01	10.83	0.044	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,096										
8.33	0.068	10.83	0.14	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	7,039										
8.33	0.02	10.83	0.02	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	812										
									0	0.0000	0										
									0	0.0000	0										
Time Period Totals									97,600	45.8720	16,934	0.0410	374,298	0.1721							
10.83	0.071	14.33	0.042	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	6,424										
10.83	0.059	14.33	0.036	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,800										
10.83	0.051	14.33	0.03	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,302										
10.83	0.052	14.33	0.034	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,630										
10.83	0.041	14.33	0.034	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,843										
10.83	0.037	14.33	0.03	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,587										
10.83	0.044	14.33	0.038	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,331										
10.83	0.14	14.33	0.079	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	10,328										
10.83	0.02	14.33	0.015	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	995										
									0	0.0000	0										
									0	0.0000	0										
Time Period Totals									97,600	45.8720	30,240	0.0523	344,058	0.2155							
14.33	0.042	15.50	0.013	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,045										
14.33	0.036	15.50	0.015	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	323										
14.33	0.03	15.50	0.014	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	418										
14.33	0.034	15.50	0.012	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	291										
14.33	0.034	15.50	0.012	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	583										
14.33	0.03	15.50	0.01	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	317										
14.33	0.038	15.50	0.013	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	485										
14.33	0.078	15.50	0.084	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	2,566										
14.33	0.015	15.50	0.084	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	941										
									0	0.0000	0										
									0	0.0000	0										
Time Period Totals									97,600	45.8720	6,968	0.0361	337,090	0.2401							
15.50	0.013	23.99	0.039	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	7,171										
15.50	0.015	23.99	0.038	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,436										
15.50	0.014	23.99	0.036	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,448										
15.50	0.012	23.99	0.041	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,436										
15.50	0.012	23.99	0.035	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	4,321										
15.50	0.01	23.99	0.033	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,471										
15.50	0.013	23.99	0.037	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,448										
15.50	0.084	23.99	0.074	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	18,157										
15.50	0.084	23.99	0.074	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	10,894										
									0	0.0000	0										
									0	0.0000	0										
Time Period Totals									97,600	45.8720	54,783	0.0391	282,307								
24 HR. ACTUAL COMPLIANCE TOTAL												0.0338									
24 HR. COMPLIANCE STANDARD												0.105									
												IN COMPLIANCE									

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-25-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.023	8.25	0.023	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	6,164					
0.00	0.023	8.25	0.023	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,055					
0.00	0.021	8.25	0.021	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,814					
0.00	0.022	8.25	0.022	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,965					
0.00	0.019	8.25	0.019	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,395					
0.00	0.015	8.25	0.015	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,675					
0.00	0.023	8.25	0.023	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,082					
0.00	0.065	8.25	0.065	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	14,517					
0.00	0.062	8.25	0.062	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	8,308					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	43,976	0.0323	372,174	0.1431	
8.25	0.023	10.83	0.043	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,766					
8.25	0.023	10.83	0.045	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	950					
8.25	0.021	10.83	0.038	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,236					
8.25	0.022	10.83	0.049	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	992					
8.25	0.019	10.83	0.056	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,095					
8.25	0.015	10.83	0.048	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,100					
8.25	0.023	10.83	0.064	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,823					
8.25	0.065	10.83	0.112	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	6,181					
8.25	0.062	10.83	0.039	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	2,116					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	19,260	0.0452	352,914	0.1623	
10.83	0.043	13.50	0.14	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	7,937					
10.83	0.045	13.50	0.126	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,472					
10.83	0.038	13.50	0.092	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,819					
10.83	0.049	13.50	0.094	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,067					
10.83	0.056	13.50	0.092	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	4,279					
10.83	0.048	13.50	0.082	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,349					
10.83	0.064	13.50	0.101	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,578					
10.83	0.112	13.50	0.051	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	5,891					
10.83	0.039	13.50	0.052	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	1,973					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	33,365	0.0757	319,549	0.1843	
13.50	0.14	15.25	0.06	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	5,685					
13.50	0.126	15.25	0.05	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,668					
13.50	0.092	15.25	0.041	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,890					
13.50	0.094	15.25	0.043	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,298					
13.50	0.092	15.25	0.041	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,520					
13.50	0.082	15.25	0.033	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,362					
13.50	0.101	15.25	0.049	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,132					
13.50	0.051	15.25	0.073	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	2,937					
13.50	0.052	15.25	0.063	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	1,634					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	21,127	0.0731	298,422	0.2065	
15.25	0.06	23.99	0.06	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	17,036					
15.25	0.05	23.99	0.05	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	4,732					
15.25	0.041	23.99	0.041	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	5,821					
15.25	0.043	23.99	0.043	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	4,070					
15.25	0.041	23.99	0.041	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	7,761					
15.25	0.033	23.99	0.033	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	3,904					
15.25	0.049	23.99	0.049	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	6,956					
15.25	0.073	23.99	0.073	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	17,272					
15.25	0.063	23.99	0.063	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	8,944					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	76,496	0.0530	221,926		
24 HR. ACTUAL COMPLIANCE TOTAL												0.0490				
24 HR. COMPLIANCE STANDARD												0.105				
												IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADI, IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-26-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.015	8.00	0.015	8.00	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,898			
0.00	0.015	8.00	0.015	8.00	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,299			
0.00	0.012	8.00	0.012	8.00	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,559			
0.00	0.015	8.00	0.015	8.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,299			
0.00	0.016	8.00	0.016	8.00	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,772			
0.00	0.016	8.00	0.016	8.00	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,733			
0.00	0.016	8.00	0.016	8.00	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,079			
0.00	0.055	8.00	0.055	8.00	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	11,912			
0.00	0.094	8.00	0.094	8.00	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	12,215			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										97,600	45.8720	38,767	0.0293	377,384	0.1428
8.00	0.015	10.50	0.039	10.50	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,193			
8.00	0.015	10.50	0.048	10.50	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	853			
8.00	0.012	10.50	0.047	10.50	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,198			
8.00	0.015	10.50	0.041	10.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	758			
8.00	0.016	10.50	0.041	10.50	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,543			
8.00	0.016	10.50	0.041	10.50	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	964			
8.00	0.016	10.50	0.04	10.50	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,137			
8.00	0.055	10.50	0.074	10.50	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	4,365			
8.00	0.094	10.50	0.105	10.50	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	4,040			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										97,600	45.8720	17,052	0.0413	360,332	0.1616
10.50	0.039	13.75	0.044	13.75	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	4,382			
10.50	0.048	13.75	0.045	13.75	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,637			
10.50	0.047	13.75	0.043	13.75	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,376			
10.50	0.041	13.75	0.043	13.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,478			
10.50	0.041	13.75	0.045	13.75	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,027			
10.50	0.041	13.75	0.045	13.75	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,892			
10.50	0.04	13.75	0.044	13.75	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,217			
10.50	0.074	13.75	0.12	13.75	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	8,534			
10.50	0.105	13.75	0.21	13.75	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	8,314			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										97,600	45.8720	33,856	0.0631	326,475	0.1929
13.75	0.044	15.25	0.027	15.25	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,730			
13.75	0.045	15.25	0.025	15.25	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	569			
13.75	0.043	15.25	0.024	15.25	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	816			
13.75	0.043	15.25	0.027	15.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	569			
13.75	0.045	15.25	0.023	15.25	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,105			
13.75	0.045	15.25	0.023	15.25	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	690			
13.75	0.044	15.25	0.023	15.25	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	816			
13.75	0.12	15.25	0.085	15.25	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	4,162			
13.75	0.21	15.25	0.103	15.25	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	3,813			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										97,600	45.8720	14,270	0.0576	312,206	0.2161
15.25	0.027	23.99	0.027	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	7,666			
15.25	0.025	23.99	0.025	23.99	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,366			
15.25	0.024	23.99	0.024	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,407			
15.25	0.027	23.99	0.027	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,555			
15.25	0.023	23.99	0.023	23.99	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	4,354			
15.25	0.023	23.99	0.023	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,721			
15.25	0.023	23.99	0.023	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,265			
15.25	0.085	23.99	0.085	23.99	Turbine #1 - El. 38 to El. 24	38	N	10	1,600	16,000	7.5200	20,112			
15.25	0.103	23.99	0.103	23.99	Turbine #1 - El. 38 to El. 24	24	N	6	1,600	9,600	4.5120	14,622			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										97,600	45.8720	61,069	0.0423	251,137	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0416		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-27-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.053	8.25	0.053	8.25	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	14,205				
0.00	0.063	8.25	0.063	8.25	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	5,628				
0.00	0.052	8.25	0.052	8.25	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	6,968				
0.00	0.053	8.25	0.053	8.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	4,735				
0.00	0.056	8.25	0.056	8.25	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	10,006				
0.00	0.052	8.25	0.052	8.25	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	5,807				
0.00	0.06	8.25	0.06	8.25	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	8,040				
0.00	0.045	8.25	0.045	8.25	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	10,050				
0.00	0.153	8.25	0.153	8.25	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	20,503				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	85,943	0.0631	330,208	0.1270
8.25	0.053	10.75	0.044	10.75	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,939				
8.25	0.063	10.75	0.047	10.75	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,489				
8.25	0.052	10.75	0.035	10.75	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,766				
8.25	0.053	10.75	0.031	10.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,137				
8.25	0.056	10.75	0.029	10.75	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,301				
8.25	0.052	10.75	0.027	10.75	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,337				
8.25	0.06	10.75	0.031	10.75	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,848				
8.25	0.045	10.75	0.064	10.75	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	3,689				
8.25	0.153	10.75	0.305	10.75	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	9,299				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	26,805	0.0649	303,403	0.1387
10.75	0.044	14.00	0.041	14.00	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	4,487				
10.75	0.047	14.00	0.039	14.00	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,513				
10.75	0.035	14.00	0.027	14.00	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,637				
10.75	0.031	14.00	0.028	14.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,038				
10.75	0.029	14.00	0.04	14.00	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,428				
10.75	0.027	14.00	0.048	14.00	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,650				
10.75	0.031	14.00	0.031	14.00	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,637				
10.75	0.064	14.00	0.071	14.00	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	5,939				
10.75	0.305	14.00	0.148	14.00	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	11,957				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	32,286	0.0602	271,118	0.1642
14.00	0.041	15.00	0.035	15.00	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,234				
14.00	0.039	15.00	0.031	15.00	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	379				
14.00	0.027	15.00	0.024	15.00	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	414				
14.00	0.028	15.00	0.02	15.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	260				
14.00	0.04	15.00	0.029	15.00	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	747				
14.00	0.048	15.00	0.038	15.00	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	582				
14.00	0.031	15.00	0.021	15.00	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	422				
14.00	0.071	15.00	0.051	15.00	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	1,651				
14.00	0.148	15.00	0.08	15.00	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	1,852				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	7,542	0.0457	263,575	0.1773
15.00	0.035	23.99	0.035	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	10,222				
15.00	0.031	23.99	0.031	23.99	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,018				
15.00	0.024	23.99	0.024	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,505				
15.00	0.02	23.99	0.02	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,947				
15.00	0.029	23.99	0.029	23.99	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	5,646				
15.00	0.038	23.99	0.038	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	4,624				
15.00	0.021	23.99	0.021	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,067				
15.00	0.051	23.99	0.051	23.99	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	12,412				
15.00	0.08	23.99	0.08	23.99	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	11,682				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	56,123	0.0378	207,453	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0527			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-30-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
0.00	0.006	8.25	0.006	Boiler #1& #2 - El. 89 to El. 59		59 NE	12	1,600	19,200	9.0240	1,608			
0.00	0.01	8.25	0.01	Boiler #1& #2 - El. 89 to El. 59		59 N	4	1,600	6,400	3.0080	893			
0.00	0.008	8.25	0.008	Boiler #1& #2 - El. 89 to El. 59		59 W	6	1,600	9,600	4.5120	1,072			
0.00	0.013	8.25	0.013	Boiler #1& #2 - El. 89 to El. 59		59 SW	4	1,600	6,400	3.0080	1,161			
0.00	0.021	8.25	0.021	Boiler #1& #2 - El. 89 to El. 59		82 N	8	1,600	12,800	6.0160	3,752			
0.00	0.017	8.25	0.017	Boiler #1& #2 - El. 89 to El. 59		82 SW	5	1,600	8,000	3.7600	1,898			
0.00	0.013	8.25	0.013	Boiler #1& #2 - El. 89 to El. 59		82 SE	6	1,600	9,600	4.5120	1,742			
0.00	0.03	8.25	0.03	Turbine #1 - El. 36 to El. 24		36 N	10	1,600	16,000	7.5200	6,700			
0.00	0.22	8.25	0.22	Turbine #1 - El. 36 to El. 24		24 N	6	1,600	9,600	4.5120	29,481			
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									97,600	45.8720	48,309	0.0355	367,841	0.1414
8.25	0.006	10.75	0.032	Boiler #1& #2 - El. 89 to El. 59		59 NE	12	1,600	19,200	9.0240	1,543			
8.25	0.01	10.75	0.037	Boiler #1& #2 - El. 89 to El. 59		59 N	4	1,600	6,400	3.0080	636			
8.25	0.008	10.75	0.031	Boiler #1& #2 - El. 89 to El. 59		59 W	6	1,600	9,600	4.5120	792			
8.25	0.013	10.75	0.034	Boiler #1& #2 - El. 89 to El. 59		59 SW	4	1,600	6,400	3.0080	636			
8.25	0.021	10.75	0.029	Boiler #1& #2 - El. 89 to El. 59		82 N	8	1,600	12,800	6.0160	1,354			
8.25	0.017	10.75	0.034	Boiler #1& #2 - El. 89 to El. 59		82 SW	5	1,600	8,000	3.7600	863			
8.25	0.013	10.75	0.038	Boiler #1& #2 - El. 89 to El. 59		82 SE	6	1,600	9,600	4.5120	1,036			
8.25	0.03	10.75	0.075	Turbine #1 - El. 36 to El. 24		36 N	10	1,600	16,000	7.5200	3,553			
8.25	0.22	10.75	0.267	Turbine #1 - El. 36 to El. 24		24 N	6	1,600	9,600	4.5120	9,888			
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									97,600	45.8720	20,301	0.0492	347,541	0.1588
10.75	0.032	13.25	0.025	Boiler #1& #2 - El. 89 to El. 59		59 NE	12	1,600	19,200	9.0240	2,315			
10.75	0.037	13.25	0.023	Boiler #1& #2 - El. 89 to El. 59		59 N	4	1,600	6,400	3.0080	812			
10.75	0.031	13.25	0.027	Boiler #1& #2 - El. 89 to El. 59		59 W	6	1,600	9,600	4.5120	1,178			
10.75	0.034	13.25	0.031	Boiler #1& #2 - El. 89 to El. 59		59 SW	4	1,600	6,400	3.0080	880			
10.75	0.029	13.25	0.03	Boiler #1& #2 - El. 89 to El. 59		82 N	8	1,600	12,800	6.0160	1,597			
10.75	0.034	13.25	0.024	Boiler #1& #2 - El. 89 to El. 59		82 SW	5	1,600	8,000	3.7600	981			
10.75	0.038	13.25	0.017	Boiler #1& #2 - El. 89 to El. 59		82 SE	6	1,600	9,600	4.5120	1,117			
10.75	0.075	13.25	0.084	Turbine #1 - El. 36 to El. 24		36 N	10	1,600	16,000	7.5200	5,381			
10.75	0.267	13.25	0.024	Turbine #1 - El. 36 to El. 24		24 N	6	1,600	9,600	4.5120	5,908			
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									97,600	45.8720	20,169	0.0489	327,372	0.1844
13.25	0.025	15.00	0.021	Boiler #1& #2 - El. 89 to El. 59		59 NE	12	1,600	19,200	9.0240	1,308			
13.25	0.023	15.00	0.02	Boiler #1& #2 - El. 89 to El. 59		59 N	4	1,600	6,400	3.0080	407			
13.25	0.027	15.00	0.017	Boiler #1& #2 - El. 89 to El. 59		59 W	6	1,600	9,600	4.5120	625			
13.25	0.031	15.00	0.025	Boiler #1& #2 - El. 89 to El. 59		59 SW	4	1,600	6,400	3.0080	531			
13.25	0.03	15.00	0.04	Boiler #1& #2 - El. 89 to El. 59		82 N	8	1,600	12,800	6.0160	1,327			
13.25	0.024	15.00	0.016	Boiler #1& #2 - El. 89 to El. 59		82 SW	5	1,600	8,000	3.7600	474			
13.25	0.017	15.00	0.028	Boiler #1& #2 - El. 89 to El. 59		82 SE	6	1,600	9,600	4.5120	640			
13.25	0.084	15.00	0.084	Turbine #1 - El. 36 to El. 24		36 N	10	1,600	16,000	7.5200	3,980			
13.25	0.024	15.00	0.24	Turbine #1 - El. 36 to El. 24		24 N	6	1,600	9,600	4.5120	3,752			
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									97,600	45.8720	13,043	0.0451	314,330	0.2115
15.00	0.021	23.99	0.021	Boiler #1& #2 - El. 89 to El. 59		59 NE	12	1,600	19,200	9.0240	6,133			
15.00	0.02	23.99	0.02	Boiler #1& #2 - El. 89 to El. 59		59 N	4	1,600	6,400	3.0080	1,947			
15.00	0.017	23.99	0.017	Boiler #1& #2 - El. 89 to El. 59		59 W	6	1,600	9,600	4.5120	2,482			
15.00	0.025	23.99	0.025	Boiler #1& #2 - El. 89 to El. 59		59 SW	4	1,600	6,400	3.0080	2,434			
15.00	0.04	23.99	0.04	Boiler #1& #2 - El. 89 to El. 59		82 N	8	1,600	12,800	6.0160	7,788			
15.00	0.016	23.99	0.016	Boiler #1& #2 - El. 89 to El. 59		82 SW	5	1,600	8,000	3.7600	1,947			
15.00	0.028	23.99	0.028	Boiler #1& #2 - El. 89 to El. 59		82 SE	6	1,600	9,600	4.5120	4,089			
15.00	0.084	23.99	0.084	Turbine #1 - El. 36 to El. 24		36 N	10	1,600	16,000	7.5200	20,444			
15.00	0.24	23.99	0.24	Turbine #1 - El. 36 to El. 24		24 N	6	1,600	9,600	4.5120	35,046			
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									97,600	45.8720	82,310	0.0554	232,019	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0465		
24 HR. COMPLIANCE STANDARD												0.105		
												IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 01-31-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0	7.50	0	0 Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	0				
0.00	0.003	7.50	0.003	0.003 Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	244				
0.00	0	7.50	0	0 Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	0				
0.00	0.005	7.50	0.005	0.005 Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	406				
0.00	0.003	7.50	0.003	0.003 Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	487				
0.00	0.003	7.50	0.003	0.003 Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	305				
0.00	0.003	7.50	0.003	0.003 Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	365				
0.00	0.024	7.50	0.024	0.024 Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	4,873				
0.00	0.073	7.50	0.073	0.073 Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	8,893				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	15,573	0.0126	400,578	0.1470
7.50	0	10.25	0.029	0.029 Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,295				
7.50	0.003	10.25	0.032	0.032 Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	521				
7.50	0	10.25	0.026	0.026 Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	581				
7.50	0.005	10.25	0.021	0.021 Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	387				
7.50	0.003	10.25	0.027	0.027 Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	893				
7.50	0.003	10.25	0.024	0.024 Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	503				
7.50	0.003	10.25	0.021	0.021 Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	536				
7.50	0.024	10.25	0.072	0.072 Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	3,574				
7.50	0.073	10.25	0.164	0.164 Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	5,293				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	13,583	0.0299	386,995	0.1704
10.25	0.029	13.25	0.024	0.024 Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,583				
10.25	0.032	13.25	0.031	0.031 Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,023				
10.25	0.026	13.25	0.021	0.021 Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,145				
10.25	0.021	13.25	0.02	0.02 Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	666				
10.25	0.027	13.25	0.028	0.028 Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,787				
10.25	0.024	13.25	0.028	0.028 Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,056				
10.25	0.021	13.25	0.028	0.028 Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,194				
10.25	0.072	13.25	0.042	0.042 Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	4,629				
10.25	0.164	13.25	0.158	0.158 Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	7,845				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	21,928	0.0443	365,066	0.2056
13.25	0.024	15.00	0.023	0.023 Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,336				
13.25	0.031	15.00	0.023	0.023 Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	512				
13.25	0.021	15.00	0.021	0.021 Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	597				
13.25	0.02	15.00	0.021	0.021 Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	388				
13.25	0.028	15.00	0.018	0.018 Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	872				
13.25	0.028	15.00	0.016	0.016 Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	521				
13.25	0.028	15.00	0.014	0.014 Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	597				
13.25	0.042	15.00	0.063	0.063 Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	2,487				
13.25	0.158	15.00	0.124	0.124 Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	4,008				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	11,318	0.0392	353,748	0.2380
15.00	0.023	23.99	0.023	0.023 Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	6,717				
15.00	0.023	23.99	0.023	0.023 Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,239				
15.00	0.021	23.99	0.021	0.021 Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,067				
15.00	0.021	23.99	0.021	0.021 Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,044				
15.00	0.018	23.99	0.018	0.018 Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,505				
15.00	0.016	23.99	0.016	0.016 Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,947				
15.00	0.014	23.99	0.014	0.014 Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,044				
15.00	0.063	23.99	0.063	0.063 Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	15,333				
15.00	0.124	23.99	0.124	0.124 Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	18,107				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	55,003	0.0370	298,745	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0296			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-01-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.01	7.75	0.01	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,518					
0.00	0.007	7.75	0.007	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	587					
0.00	0.01	7.75	0.01	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,259					
0.00	0.012	7.75	0.012	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,007					
0.00	0.005	7.75	0.005	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	839					
0.00	0.003	7.75	0.003	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	315					
0.00	0.003	7.75	0.003	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	378					
0.00	0.073	7.75	0.073	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	15,316					
0.00	0.046	7.75	0.046	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	5,791					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	28,009	0.0219	388,141	0.1446	
7.75	0.01	10.25	0.044	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,193					
7.75	0.007	10.25	0.034	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	555					
7.75	0.01	10.25	0.032	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	859					
7.75	0.012	10.25	0.031	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	582					
7.75	0.005	10.25	0.034	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,056					
7.75	0.003	10.25	0.032	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	592					
7.75	0.003	10.25	0.03	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	670					
7.75	0.073	10.25	0.097	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	5,753					
7.75	0.046	10.25	0.257	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	6,152					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	18,406	0.0446	369,736	0.1628	
10.25	0.044	13.50	0.024	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,590					
10.25	0.034	13.50	0.023	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,003					
10.25	0.032	13.50	0.026	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,531					
10.25	0.031	13.50	0.024	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	968					
10.25	0.034	13.50	0.026	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,112					
10.25	0.032	13.50	0.026	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,276					
10.25	0.03	13.50	0.026	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,478					
10.25	0.097	13.50	0.083	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	7,919					
10.25	0.257	13.50	0.255	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	13,514					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	33,390	0.0622	336,346	0.1940	
13.50	0.024	15.00	0.039	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,535					
13.50	0.023	15.00	0.036	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	479					
13.50	0.026	15.00	0.026	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	633					
13.50	0.024	15.00	0.036	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	487					
13.50	0.026	15.00	0.037	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,023					
13.50	0.026	15.00	0.034	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	609					
13.50	0.026	15.00	0.038	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	780					
13.50	0.083	15.00	0.124	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	4,203					
13.50	0.255	15.00	0.196	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	5,494					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	15,244	0.0615	321,102	0.2160	
15.00	0.039	23.99	0.039	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	11,390					
15.00	0.036	23.99	0.036	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,505					
15.00	0.026	23.99	0.026	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,797					
15.00	0.036	23.99	0.036	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	3,505					
15.00	0.037	23.99	0.037	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	7,204					
15.00	0.034	23.99	0.034	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	4,137					
15.00	0.038	23.99	0.038	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	5,549					
15.00	0.124	23.99	0.124	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	30,179					
15.00	0.196	23.99	0.196	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	28,621					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	97,886	0.0659	223,215		
24 HR. ACTUAL COMPLIANCE TOTAL												0.0487				
24 HR. COMPLIANCE STANDARD												0.105				
												IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-02-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.004	7.75	0.004	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,007				
0.00	0.003	7.75	0.003	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	252				
0.00	0.005	7.75	0.005	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	629				
0.00	0.004	7.75	0.004	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	336				
0.00	0.005	7.75	0.005	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	839				
0.00	0.005	7.75	0.005	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	525				
0.00	0.005	7.75	0.005	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	629				
0.00	0.209	7.75	0.209	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	43,850				
0.00	0.299	7.75	0.299	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	37,640				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	85,707	0.0670	330,444	0.1231
7.75	0.004	11.00	0.034	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,006				
7.75	0.003	11.00	0.023	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	458				
7.75	0.005	11.00	0.035	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,056				
7.75	0.004	11.00	0.022	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	458				
7.75	0.005	11.00	0.027	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,126				
7.75	0.005	11.00	0.025	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	660				
7.75	0.005	11.00	0.022	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	713				
7.75	0.209	11.00	0.547	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	33,258				
7.75	0.299	11.00	0.38	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	17,922				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	57,656	0.1074	272,788	0.1271
11.00	0.034	13.50	0.178	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	8,609				
11.00	0.023	13.50	0.133	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,112				
11.00	0.035	13.50	0.148	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,716				
11.00	0.022	13.50	0.122	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,949				
11.00	0.027	13.50	0.13	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	4,250				
11.00	0.025	13.50	0.13	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,623				
11.00	0.022	13.50	0.13	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,086				
11.00	0.547	13.50	0.144	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	23,383				
11.00	0.38	13.50	0.368	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	15,187				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	64,915	0.1572	207,873	0.1199
13.50	0.178	15.00	0.027	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	4,995				
13.50	0.133	15.00	0.033	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,348				
13.50	0.148	15.00	0.024	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,095				
13.50	0.122	15.00	0.027	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,210				
13.50	0.13	15.00	0.044	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,826				
13.50	0.13	15.00	0.03	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,624				
13.50	0.13	15.00	0.017	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,791				
13.50	0.144	15.00	0.124	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	5,441				
13.50	0.368	15.00	0.196	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	6,871				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	28,202	0.1139	179,671	0.1209
15.00	0.027	23.99	0.027	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	7,885				
15.00	0.033	23.99	0.033	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,213				
15.00	0.024	23.99	0.024	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,505				
15.00	0.027	23.99	0.027	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,628				
15.00	0.044	23.99	0.044	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	8,567				
15.00	0.03	23.99	0.03	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	3,651				
15.00	0.017	23.99	0.017	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,482				
15.00	0.124	23.99	0.124	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	30,179				
15.00	0.196	23.99	0.196	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	28,621				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	90,731	0.0611	88,940	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0826			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-03-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.007	7.50	0.007	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,706				
0.00	0.006	7.50	0.006	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	487				
0.00	0.006	7.50	0.006	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	731				
0.00	0.01	7.50	0.01	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	812				
0.00	0.011	7.50	0.011	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	1,787				
0.00	0.008	7.50	0.008	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	812				
0.00	0.005	7.50	0.005	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	609				
0.00	0.037	7.50	0.037	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	7,512				
0.00	0.053	7.50	0.053	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	6,457				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	20,913	0.0169	395,238	0.1451
7.50	0.007	10.50	0.478	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	23,634				
7.50	0.006	10.50	0.632	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	10,363				
7.50	0.006	10.50	0.803	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	19,711				
7.50	0.01	10.50	0.625	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	10,314				
7.50	0.011	10.50	0.58	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	19,199				
7.50	0.008	10.50	0.477	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	9,847				
7.50	0.005	10.50	0.374	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	9,234				
7.50	0.037	10.50	0.104	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	5,726				
7.50	0.053	10.50	0.096	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	3,630				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	111,660	0.2254	283,578	0.1272
10.50	0.478	12.33	0.038	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	15,338				
10.50	0.632	12.33	0.052	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	6,777				
10.50	0.803	12.33	0.044	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	12,589				
10.50	0.625	12.33	0.046	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	6,649				
10.50	0.58	12.33	0.063	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	12,742				
10.50	0.477	12.33	0.043	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	6,440				
10.50	0.374	12.33	0.023	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	5,900				
10.50	0.104	12.33	0.104	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	5,152				
10.50	0.096	12.33	0.096	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	2,854				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	74,441	0.2463	209,136	0.1085
12.33	0.038	15.00	0.036	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,209				
12.33	0.052	15.00	0.059	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,605				
12.33	0.044	15.00	0.039	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,800				
12.33	0.046	15.00	0.032	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,128				
12.33	0.063	15.00	0.033	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,776				
12.33	0.043	15.00	0.031	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,337				
12.33	0.023	15.00	0.029	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,128				
12.33	0.104	15.00	0.028	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	4,771				
12.33	0.096	15.00	0.099	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	4,229				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	21,981	0.0499	187,155	0.1259
15.00	0.036	23.99	0.036	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	10,514				
15.00	0.059	23.99	0.059	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	5,744				
15.00	0.039	23.99	0.039	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	5,695				
15.00	0.032	23.99	0.032	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	3,115				
15.00	0.033	23.99	0.033	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	6,425				
15.00	0.031	23.99	0.031	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	3,772				
15.00	0.029	23.99	0.029	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	4,235				
15.00	0.028	23.99	0.028	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	6,815				
15.00	0.099	23.99	0.099	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	14,457				
									0	0.0000	0				
									0	0.0000	0				
Time Period Totals										97,600	45.8720	60,771	0.0409	126,384	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0731			
24 HR. COMPLIANCE STANDARD												0.105 IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-06-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.007	7.00	0.007	7.00	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,592				
0.00	0.005	7.00	0.005	7.00	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	379				
0.00	0.008	7.00	0.008	7.00	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	910				
0.00	0.007	7.00	0.007	7.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	531				
0.00	0.015	7.00	0.015	7.00	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	2,274				
0.00	0.013	7.00	0.013	7.00	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,232				
0.00	0.003	7.00	0.003	7.00	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	341				
0.00	0.012	7.00	0.012	7.00	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	2,274				
0.00	0.03	7.00	0.03	7.00	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	3,411				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	12,943	0.0112	403,208	0.1436
7.00	0.007	9.33	0.148	9.33	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	5,866				
7.00	0.005	9.33	0.163	9.33	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,119				
7.00	0.008	9.33	0.133	9.33	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,668				
7.00	0.007	9.33	0.091	9.33	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,236				
7.00	0.015	9.33	0.128	9.33	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,608				
7.00	0.013	9.33	0.113	9.33	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,987				
7.00	0.003	9.33	0.128	9.33	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,479				
7.00	0.012	9.33	0.054	9.33	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	2,082				
7.00	0.03	9.33	0.073	9.33	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	1,949				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	23,995	0.0624	379,213	0.1565
9.33	0.148	12.83	0.06	12.83	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	11,825				
9.33	0.163	12.83	0.018	12.83	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,430				
9.33	0.133	12.83	0.042	12.83	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	4,974				
9.33	0.091	12.83	0.08	12.83	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	3,241				
9.33	0.128	12.83	0.04	12.83	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	6,367				
9.33	0.113	12.83	0.055	12.83	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	3,980				
9.33	0.128	12.83	0.016	12.83	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	4,093				
9.33	0.054	12.83	0.02	12.83	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	3,506				
9.33	0.073	12.83	0.057	12.83	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	3,695				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	45,111	0.0780	334,101	0.1811
12.83	0.06	15.75	0.115	15.75	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	8,300				
12.83	0.018	15.75	0.123	15.75	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,229				
12.83	0.042	15.75	0.106	15.75	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	3,510				
12.83	0.08	15.75	0.108	15.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,972				
12.83	0.04	15.75	0.177	15.75	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	6,862				
12.83	0.055	15.75	0.156	15.75	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	4,170				
12.83	0.016	15.75	0.122	15.75	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	3,273				
12.83	0.02	15.75	0.056	15.75	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	3,004				
12.83	0.057	15.75	0.075	15.75	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	3,130				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	37,450	0.0777	296,651	0.2177
15.75	0.115	23.99	0.115	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	30,784				
15.75	0.123	23.99	0.123	23.99	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	10,975				
15.75	0.106	23.99	0.106	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	14,187				
15.75	0.108	23.99	0.108	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	9,637				
15.75	0.177	23.99	0.177	23.99	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	31,587				
15.75	0.156	23.99	0.156	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	17,400				
15.75	0.122	23.99	0.122	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	16,329				
15.75	0.056	23.99	0.056	23.99	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	12,492				
15.75	0.075	23.99	0.075	23.99	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	10,038				
										0	0.0000	0				
										0	0.0000	0				
Time Period Totals											97,600	45.8720	153,430	0.1128	143,222	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0689			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-07-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.018	7.00	0.018	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	4,093					
0.00	0.012	7.00	0.012	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	910					
0.00	0.02	7.00	0.02	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,274					
0.00	0.015	7.00	0.015	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,137					
0.00	0.038	7.00	0.038	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	5,761					
0.00	0.027	7.00	0.027	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,558					
0.00	0.008	7.00	0.008	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	910					
0.00	0.011	7.00	0.011	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	2,085					
0.00	0.054	7.00	0.054	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	6,140					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals											97,600	45.8720	25,967	0.0224	390,283	0.1390
7.00	0.018	10.75	0.525	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	33,075					
7.00	0.012	10.75	0.54	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	11,208					
7.00	0.02	10.75	0.512	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	16,203					
7.00	0.015	10.75	0.489	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	10,233					
7.00	0.038	10.75	0.517	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	22,537					
7.00	0.027	10.75	0.429	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	11,573					
7.00	0.008	10.75	0.36	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	11,208					
7.00	0.011	10.75	0.081	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	4,670					
7.00	0.054	10.75	0.123	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	5,391					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals											97,600	45.8720	126,098	0.2036	264,185	0.1207
10.75	0.525	11.25	0.093	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	5,019					
10.75	0.54	11.25	0.105	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	1,746					
10.75	0.512	11.25	0.081	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,408					
10.75	0.489	11.25	0.071	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,516					
10.75	0.517	11.25	0.151	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,617					
10.75	0.429	11.25	0.087	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,746					
10.75	0.36	11.25	0.058	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,697					
10.75	0.081	11.25	0.031	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	758					
10.75	0.123	11.25	0.074	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	800					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals											97,600	45.8720	19,308	0.2338	244,878	0.1163
11.25	0.093	15.25	0.123	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	14,034					
11.25	0.105	15.25	0.124	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	4,960					
11.25	0.081	15.25	0.122	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	6,585					
11.25	0.071	15.25	0.119	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	4,115					
11.25	0.151	15.25	0.203	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	15,334					
11.25	0.087	15.25	0.119	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	5,577					
11.25	0.058	15.25	0.08	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	4,483					
11.25	0.031	15.25	0.043	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	4,007					
11.25	0.074	15.25	0.065	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	4,516					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals											97,600	45.8720	63,619	0.0963	181,259	0.1254
15.25	0.123	17.00	0.089	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	6,026					
15.25	0.124	17.00	0.089	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	2,018					
15.25	0.122	17.00	0.089	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	2,999					
15.25	0.119	17.00	0.075	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,838					
15.25	0.203	17.00	0.12	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	6,121					
15.25	0.119	17.00	0.087	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	2,440					
15.25	0.08	17.00	0.068	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,103					
15.25	0.043	17.00	0.043	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	2,037					
15.25	0.065	17.00	0.065	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	1,848					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals											97,600	45.8720	27,431	0.0949	153,828	0.1331
17.00	0.089	23.99	0.089	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	20,210					
17.00	0.089	23.99	0.089	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	6,737					
17.00	0.089	23.99	0.089	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	10,105					
17.00	0.075	23.99	0.075	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	5,677					
17.00	0.12	23.99	0.12	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	18,166					
17.00	0.087	23.99	0.087	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	8,232					
17.00	0.068	23.99	0.068	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	7,721					
17.00	0.043	23.99	0.043	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	8,137					
17.00	0.065	23.99	0.065	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	7,380					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals											97,600	45.8720	92,365	0.0800	87,330	

24 HR. ACTUAL COMPLIANCE TOTAL 0.0895
24 HR. COMPLIANCE STANDARD 0.105
IN COMPLIANCE

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-08-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.037	8.75	0.037	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	10,517					
0.00	0.039	8.75	0.039	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,695					
0.00	0.038	8.75	0.038	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	5,401					
0.00	0.041	8.75	0.041	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	3,885					
0.00	0.073	8.75	0.073	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	13,834					
0.00	0.041	8.75	0.041	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	4,856					
0.00	0.017	8.75	0.017	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	2,416					
0.00	0.016	8.75	0.016	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	3,790					
0.00	0.034	8.75	0.034	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	4,832					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	53,227	0.0368	362,924	0.1441	
8.75	0.037	11.00	0.031	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,485					
8.75	0.039	11.00	0.026	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	792					
8.75	0.038	11.00	0.039	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,407					
8.75	0.041	11.00	0.043	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,023					
8.75	0.073	11.00	0.053	Boiler #1& #2 - El. 89 to El. 59	82	N	8	1,600	12,800	6.0160	3,070					
8.75	0.041	11.00	0.031	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,096					
8.75	0.017	11.00	0.021	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	694					
8.75	0.016	11.00	0.017	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	1,005					
8.75	0.034	11.00	0.047	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	1,480					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										97,600	45.8720	13,053	0.0351	349,870	0.1630	
11.00	0.031	13.50	0.033	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	2,599					
11.00	0.026	13.50	0.034	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	812					
11.00	0.039	13.50	0.048	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,766					
11.00	0.043	13.50	0.05	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,259					
11.00	0.053	13.50	0	Boiler #1& #2 - El. 89 to El. 59	82	N	0	1,600	0	0.0000	0					
11.00	0.031	13.50	0.051	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,387					
11.00	0.021	13.50	0.029	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	1,015					
11.00	0.017	13.50	0.02	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	1,252					
11.00	0.047	13.50	0.057	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	2,112					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										84,800	39.8560	12,203	0.0340	283,091	0.1879	
13.50	0.033	15.00	0.028	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	1,486					
13.50	0.034	15.00	0.035	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	560					
13.50	0.048	15.00	0.042	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,096					
13.50	0.05	15.00	0.046	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	780					
13.50	0	15.00	0	Boiler #1& #2 - El. 89 to El. 59	82	N	0	1,600	0	0.0000	0					
13.50	0.051	15.00	0.054	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	1,066					
13.50	0.029	15.00	0.041	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	853					
13.50	0.02	15.00	0.013	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	670					
13.50	0.057	15.00	0.021	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	950					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										84,800	39.8560	7,462	0.0347	275,629	0.2134	
15.00	0.028	23.99	0.028	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	8,177					
15.00	0.035	23.99	0.035	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,407					
15.00	0.042	23.99	0.042	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	6,133					
15.00	0.046	23.99	0.046	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	4,478					
15.00	0	23.99	0	Boiler #1& #2 - El. 89 to El. 59	82	N	0	1,600	0	0.0000	0					
15.00	0.054	23.99	0.054	Boiler #1& #2 - El. 89 to El. 59	82	SW	5	1,600	8,000	3.7600	6,571					
15.00	0.041	23.99	0.041	Boiler #1& #2 - El. 89 to El. 59	82	SE	6	1,600	9,600	4.5120	5,987					
15.00	0.013	23.99	0.013	Turbine #1 - El. 36 to El. 24	36	N	10	1,600	16,000	7.5200	3,164					
15.00	0.021	23.99	0.021	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	3,067					
									0	0.0000	0					
									0	0.0000	0					
Time Period Totals										84,800	39.8560	40,985	0.0318	234,644		
24 HR. ACTUAL COMPLIANCE TOTAL												0.0369				
24 HR. COMPLIANCE STANDARD												0.105				
												IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-09-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.038	8.00	0.038	8.00	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	9,876			
0.00	0.046	8.00	0.046	8.00	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	3,985			
0.00	0.046	8.00	0.046	8.00	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	5,977			
0.00	0.045	8.00	0.045	8.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	3,898			
0.00	0.039	8.00	0.039	8.00	Boiler #1& #2 - El. 89 to El. 59	82	NE	7	1,600	11,200	5.2640	5,913			
0.00	0	8.00	0	8.00	Boiler #1& #2 - El. 89 to El. 59	82	SW	0	1,600	0	0.0000	0			
0.00	0.037	8.00	0.037	8.00	Boiler #1& #2 - El. 89 to El. 59	82	SE	11	1,600	17,600	8.2720	8,815			
0.00	0.006	8.00	0.006	8.00	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	260			
0.00	0.022	8.00	0.022	8.00	Turbine #1 - El. 36 to El. 24	24	N	6	1,600	9,600	4.5120	2,859			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										83,200	39.1040	41,583	0.0369	313,169	0.1390
8.00	0.038	10.25	0.052	10.25	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,289			
8.00	0.046	10.25	0.036	10.25	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	999			
8.00	0.046	10.25	0.036	10.25	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,498			
8.00	0.045	10.25	0.038	10.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,011			
8.00	0.039	10.25	0.033	10.25	Boiler #1& #2 - El. 89 to El. 59	82	NE	7	1,600	11,200	5.2640	1,535			
8.00	0	10.25	0.000	10.25	Boiler #1& #2 - El. 89 to El. 59	82	SW	0	1,600	0	0.0000	0			
8.00	0.037	10.25	0.023	10.25	Boiler #1& #2 - El. 89 to El. 59	82	SE	11	1,600	17,600	8.2720	2,010			
8.00	0.006	10.25	0.012	10.25	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	110			
8.00	0.022	10.25	0.034	10.25	Turbine #1 - El. 36 to El. 24	24	N	3	1,600	4,800	2.2560	512			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										78,400	36.8480	10,954	0.0367	281,738	0.1545
10.25	0.052	12.80	0.031	12.80	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	3,438			
10.25	0.036	12.80	0.036	12.80	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	994			
10.25	0.036	12.80	0.036	12.80	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	1,491			
10.25	0.038	12.80	0.036	12.80	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,022			
10.25	0.033	12.80	0.019	12.80	Boiler #1& #2 - El. 89 to El. 59	82	NE	7	1,600	11,200	5.2640	1,256			
10.25	0.000	12.80	0	12.80	Boiler #1& #2 - El. 89 to El. 59	82	SW	0	1,600	0	0.0000	0			
10.25	0.023	12.80	0.033	12.80	Boiler #1& #2 - El. 89 to El. 59	82	SE	11	1,600	17,600	8.2720	2,126			
10.25	0.012	12.80	0.018	12.80	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	207			
10.25	0.034	12.80	0.012	12.80	Turbine #1 - El. 36 to El. 24	24	N	3	1,600	4,800	2.2560	476			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										78,400	36.8480	11,011	0.0326	270,727	0.1822
12.80	0.031	12.81	0.031	12.81	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	10			
12.80	0.036	12.81	0.036	12.81	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	4			
12.80	0.036	12.81	0.036	12.81	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	6			
12.80	0.036	12.81	0.036	12.81	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	4			
12.80	0.019	12.81	0.019	12.81	Boiler #1& #2 - El. 89 to El. 59	82	NE	7	1,600	11,200	5.2640	4			
12.80	0	12.81	0	12.81	Boiler #1& #2 - El. 89 to El. 59	82	SW	0	1,600	0	0.0000	0			
12.80	0.033	12.81	0.033	12.81	Boiler #1& #2 - El. 89 to El. 59	82	SE	11	1,600	17,600	8.2720	10			
12.80	0.018	12.81	0.018	12.81	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	1			
12.80	0.012	12.81	0.012	12.81	Turbine #1 - El. 36 to El. 24	24	N	3	1,600	4,800	2.2560	1			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										78,400	36.8480	39	0.0295	270,688	0.1824
12.81	0.031	23.99	0.031	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NE	12	1,600	19,200	9.0240	11,259			
12.81	0.036	23.99	0.036	23.99	Boiler #1& #2 - El. 89 to El. 59	59	N	4	1,600	6,400	3.0080	4,358			
12.81	0.036	23.99	0.036	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	6	1,600	9,600	4.5120	6,538			
12.81	0.036	23.99	0.036	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	4,358			
12.81	0.019	23.99	0.019	23.99	Boiler #1& #2 - El. 89 to El. 59	82	NE	7	1,600	11,200	5.2640	4,025			
12.81	0	23.99	0	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SW	0	1,600	0	0.0000	0			
12.81	0.033	23.99	0.033	23.99	Boiler #1& #2 - El. 89 to El. 59	82	SE	11	1,600	17,600	8.2720	10,987			
12.81	0.018	23.99	0.018	23.99	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	1,090			
12.81	0.012	23.99	0.012	23.99	Turbine #1 - El. 36 to El. 24	24	N	3	1,600	4,800	2.2560	1,090			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										78,400	36.8480	43,705	0.0295	226,984	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0337		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-10-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.017	7.25	0.017	7.25	Boiler #1& #2 - El. 89 to El. 59	59	NW	13	1,600	20,800	9.7760	4,338			
0.00	0.005	7.25	0.005	7.25	Boiler #1& #2 - El. 89 to El. 59	59	W	10	1,600	16,000	7.5200	981			
0.00	0.018	7.25	0.018	7.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	1,413			
0.00	0.006	7.25	0.006	7.25	Boiler #1& #2 - El. 89 to El. 59	82	E	18	1,600	28,800	13.5360	2,120			
0.00	0.004	7.25	0.004	7.25	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	157			
0.00	0.008	7.25	0.008	7.25	Turbine #1 - El. 36 to El. 24	24	N	1	1,600	1,600	0.7520	157			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										76,800	36.0960	9,166	0.0097	318,297	0.1462
7.25	0.017	10.00	0.021	10.00	Boiler #1& #2 - El. 89 to El. 59	59	NW	13	1,600	20,800	9.7760	1,839			
7.25	0.005	10.00	0.027	10.00	Boiler #1& #2 - El. 89 to El. 59	59	W	10	1,600	16,000	7.5200	1,191			
7.25	0.018	10.00	0.023	10.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	610			
7.25	0.006	10.00	0.02	10.00	Boiler #1& #2 - El. 89 to El. 59	82	E	18	1,600	28,800	13.5360	1,742			
7.25	0.004	10.00	0.012	10.00	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	119			
7.25	0.008	10.00	0.015	10.00	Turbine #1 - El. 36 to El. 24	24	N	1	1,600	1,600	0.7520	86			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										76,800	36.0960	5,587	0.0156	312,710	0.1719
10.00	0.021	13.00	0.017	13.00	Boiler #1& #2 - El. 89 to El. 59	59	NW	13	1,600	20,800	9.7760	2,006			
10.00	0.027	13.00	0.029	13.00	Boiler #1& #2 - El. 89 to El. 59	59	W	10	1,600	16,000	7.5200	2,274			
10.00	0.023	13.00	0.018	13.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	666			
10.00	0.02	13.00	0.014	13.00	Boiler #1& #2 - El. 89 to El. 59	82	E	18	1,600	28,800	13.5360	2,485			
10.00	0.012	13.00	0.014	13.00	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	211			
10.00	0.015	13.00	0.021	13.00	Turbine #1 - El. 36 to El. 24	24	N	1	1,600	1,600	0.7520	146			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										76,800	36.0960	7,789	0.0200	304,921	0.2133
13.00	0.017	13.01	0.017	13.01	Boiler #1& #2 - El. 89 to El. 59	59	NW	13	1,600	20,800	9.7760	6			
13.00	0.029	13.01	0.029	13.01	Boiler #1& #2 - El. 89 to El. 59	59	W	10	1,600	16,000	7.5200	8			
13.00	0.018	13.01	0.018	13.01	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2			
13.00	0.014	13.01	0.014	13.01	Boiler #1& #2 - El. 89 to El. 59	82	E	18	1,600	28,800	13.5360	7			
13.00	0.014	13.01	0.014	13.01	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	1			
13.00	0.021	13.01	0.021	13.01	Turbine #1 - El. 36 to El. 24	24	N	1	1,600	1,600	0.7520	1			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										76,800	36.0960	24	0.0184	304,897	0.2135
13.01	0.017	23.99	0.017	23.99	Boiler #1& #2 - El. 89 to El. 59	59	NW	13	1,600	20,800	9.7760	6,569			
13.01	0.029	23.99	0.029	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	10	1,600	16,000	7.5200	8,620			
13.01	0.018	23.99	0.018	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	4	1,600	6,400	3.0080	2,140			
13.01	0.014	23.99	0.014	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	18	1,600	28,800	13.5360	7,491			
13.01	0.014	23.99	0.014	23.99	Turbine #1 - El. 36 to El. 24	36	N	2	1,600	3,200	1.5040	832			
13.01	0.021	23.99	0.021	23.99	Turbine #1 - El. 36 to El. 24	24	N	1	1,600	1,600	0.7520	624			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										76,800	36.0960	26,277	0.0184	278,620	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0157		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-15-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.015	7.33	0.015	7.33	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,084				
0.00	0.017	7.33	0.017	7.33	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,385				
0.00	0.022	7.33	0.022	7.33	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,929				
0.00	0.008	7.33	0.008	7.33	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	3,175				
0.00	0.009	7.33	0.009	7.33	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,607				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
Time Period																
Totals											92,800	43.6160	15,180	0.0132	380,504	0.1454
7.33	0.015	10.66	0.045	10.66	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,893				
7.25	0.017	10.66	0.047	10.66	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,840				
7.25	0.022	10.66	0.06	10.66	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,406				
7.25	0.008	10.66	0.037	10.66	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,154				
7.25	0.009	10.66	0.044	10.66	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,202				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
Time Period																
Totals											92,800	43.6160	15,496	0.0296	365,008	0.1743
10.66	0.045	13.50	0.051	13.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,583				
10.66	0.047	13.50	0.056	13.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,147				
10.66	0.06	13.50	0.041	13.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,494				
10.66	0.037	13.50	0.04	13.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	5,920				
10.66	0.044	13.50	0.023	13.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,318				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
Time Period																
Totals											92,800	43.6160	19,463	0.0436	345,545	0.2096
13.50	0.051	16.60	0.044	16.60	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,790				
13.50	0.056	16.60	0.042	16.60	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,346				
13.50	0.041	16.60	0.048	16.60	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,361				
13.50	0.04	16.60	0.032	16.60	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,042				
13.50	0.023	16.60	0.011	16.60	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,284				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
Time Period																
Totals											92,800	43.6160	18,824	0.0387	326,721	0.2812
16.60	0.044	23.99	0.044	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	6,162				
16.60	0.042	23.99	0.042	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	10,923				
16.60	0.048	23.99	0.048	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	8,643				
16.60	0.032	23.99	0.032	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	12,804				
16.60	0.011	23.99	0.011	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,981				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
										0	0.0000	0				
Time Period																
Totals											92,800	43.6160	40,513	0.0349	286,208	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0291			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-16-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
0.00	0.03	7.90	0.03	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	4,491			
0.00	0.031	7.90	0.031	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	8,619			
0.00	0.04	7.90	0.04	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,699			
0.00	0.024	7.90	0.024	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	10,266			
0.00	0.013	7.90	0.013	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,502			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
Time Period									92,800	43.6160	33,577	0.0271	362,107	0.1432
Totals														
7.90	0.03	10.75	0.038	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,836			
7.90	0.031	10.75	0.049	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,012			
7.90	0.04	10.75	0.045	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,951			
7.90	0.024	10.75	0.035	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,552			
7.90	0.013	10.75	0.021	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,180			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
Time Period									92,800	43.6160	14,532	0.0325	347,575	0.1671
Totals														
10.75	0.038	13.50	0.039	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,006			
10.75	0.049	13.50	0.037	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,162			
10.75	0.045	13.50	0.044	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,982			
10.75	0.035	13.50	0.046	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,030			
10.75	0.021	13.50	0.024	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,508			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
Time Period									92,800	43.6160	16,688	0.0386	330,887	0.2007
Totals														
13.50	0.039	16.75	0.044	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,556			
13.50	0.037	16.75	0.046	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,747			
13.50	0.044	16.75	0.052	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,801			
13.50	0.046	16.75	0.042	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	7,743			
13.50	0.024	16.75	0.011	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,386			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
Time Period									92,800	43.6160	20,232	0.0396	310,655	0.2729
Totals														
16.75	0.044	23.99	0.044	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	6,037			
16.75	0.046	23.99	0.046	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	11,721			
16.75	0.052	23.99	0.052	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	9,173			
16.75	0.042	23.99	0.042	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	16,464			
16.75	0.011	23.99	0.011	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,940			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
									0	0.0000	0			
Time Period									92,800	43.6160	45,335	0.0399	265,320	
Totals														
24 HR. ACTUAL COMPLIANCE TOTAL												0.0346		
24 HR. COMPLIANCE STANDARD												0.105		IN COMPLIANCE

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-17-2017

TIME START	CONC. START	TIME END	CONC. END	CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER	TOTAL FLOWRATE	TOTAL FLOWRATE	EMISSIONS (MG)	AVG. CONC.	BAL. EMISSIONS	AVG. CONC. TO FINISH			
	(MG/M ³)		(MG/M ³)		FLOOR ELEV.	LOCATION		UNIT	(CFM)	(M ³ /SEC)		(MG/M ³)	(MG)	(MG/M ³)			
0.00	0.017	7.25	0.017	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,336						
0.00	0.018	7.25	0.018	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,593						
0.00	0.003	7.25	0.003	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	530						
0.00	0.01	7.25	0.01	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	3,925						
0.00	0	7.25	0	Coal Bunker Containmentment		59 N	9	1,600	14,400	6.7680	0						
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												92,800	43.6160	11,384	0.0100	384,301	0.1461
7.25	0.017	10.50	0.045	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,909						
7.25	0.018	10.50	0.052	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,003						
7.25	0.003	10.50	0.051	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,138						
7.25	0.01	10.50	0.032	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	3,695						
7.25	0	10.50	0.019	Coal Bunker Containmentment		59 N	9	1,600	14,400	6.7680	752						
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												92,800	43.6160	12,498	0.0245	371,802	0.1754
10.50	0.045	13.50	0.048	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,644						
10.50	0.052	13.50	0.044	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,068						
10.50	0.051	13.50	0.041	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,362						
10.50	0.032	13.50	0.042	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	6,010						
10.50	0.019	13.50	0.005	Coal Bunker Containmentment		59 N	9	1,600	14,400	6.7680	877						
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												92,800	43.6160	17,961	0.0381	353,842	0.2146
13.50	0.048	15	0.032	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,137						
13.50	0.044	15	0.03	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	1,953						
13.50	0.041	15	0.033	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,352						
13.50	0.042	15	0.02	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	2,518						
13.50	0.005	15	0.007	Coal Bunker Containmentment		59 N	9	1,600	14,400	6.7680	219						
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												92,800	43.6160	7,179	0.0305	346,662	0.2453
15	0.032	23.99	0.032	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	5,452						
15	0.03	23.99	0.03	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	9,492						
15	0.033	23.99	0.033	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,228						
15	0.02	23.99	0.02	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	9,735						
15	0.007	23.99	0.007	Coal Bunker Containmentment		59 N	9	1,600	14,400	6.7680	1,533						
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												92,800	43.6160	33,440	0.0237	313,222	
24 HR. ACTUAL COMPLIANCE TOTAL															0.0219		
24 HR. COMPLIANCE STANDARD															0.105		
															IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-21-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.039	7.50	0.039	7.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	5,543				
0.00	0.011	7.50	0.011	7.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,903				
0.00	0.019	7.50	0.019	7.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,472				
0.00	0.026	7.50	0.026	7.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	10,558				
0.00	0.013	7.50	0.013	7.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,376				
0.00	0.027	7.50	0.027	7.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	6,578				
0.00	0.027	7.50	0.027	7.50	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	4,386				
0.00	0.132	7.50	0.132	7.50	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	5,360				
											0	0.0000	0			
											0	0.0000	0			
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											128,000	60.1600	41,177	0.0254	504,595	0.1412
7.50	0.039	11.00	0.05	11.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,952				
7.50	0.011	11.00	0.037	11.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,956				
7.50	0.019	11.00	0.041	11.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,558				
7.50	0.026	11.00	0.029	11.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	5,211				
7.50	0.013	11.00	0.021	11.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,450				
7.50	0.027	11.00	0.007	11.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,933				
7.50	0.027	11.00	0.194	11.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	8,376				
7.50	0.132	11.00	0.202	11.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	3,165				
											0	0.0000	0			
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											128,000	60.1600	28,601	0.0377	475,994	0.1691
11.00	0.05	14.00	0.076	14.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,582				
11.00	0.037	14.00	0.088	14.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,599				
11.00	0.041	14.00	0.105	14.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,336				
11.00	0.029	14.00	0.084	14.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	9,177				
11.00	0.021	14.00	0.011	14.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,170				
11.00	0.007	14.00	0.003	14.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	487				
11.00	0.194	14.00	0.939	14.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	36,807				
11.00	0.202	14.00	0.734	14.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	7,602				
											0	0.0000	0			
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											128,000	60.1600	70,759	0.1089	405,235	0.1871
14.00	0.076	16.5	0.064	16.5	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,316				
14.00	0.088	16.5	0.065	16.5	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,731				
14.00	0.105	16.5	0.061	16.5	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,056				
14.00	0.084	16.5	0.036	16.5	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,122				
14.00	0.011	16.5	0.018	16.5	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	883				
14.00	0.003	16.5	0.013	16.5	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	650				
14.00	0.939	16.5	0.202	16.5	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	30,889				
14.00	0.734	16.5	0.315	16.5	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	7,100				
											0	0.0000	0			
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											128,000	60.1600	62,746	0.1159	342,489	0.2109
16.5	0.064	23.99	0.064	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	9,084				
16.5	0.065	23.99	0.065	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	17,134				
16.5	0.061	23.99	0.061	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	11,132				
16.5	0.036	23.99	0.036	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	14,599				
16.5	0.018	23.99	0.018	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	3,285				
16.5	0.013	23.99	0.013	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	3,163				
16.5	0.202	23.99	0.202	23.99	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	32,768				
16.5	0.315	23.99	0.315	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	12,774				
											0	0.0000	0			
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											128,000	60.1600	103,940	0.0641	238,549	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0591			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADI. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-22-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE		EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION			(CFM)	(M ³ /SEC)				
0.00	0.02	7.75	0.02	7.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,937			
0.00	0.024	7.75	0.024	7.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,546			
0.00	0.049	7.75	0.049	7.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	9,253			
0.00	0.015	7.75	0.015	7.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,294			
0.00	0	7.75	0	7.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0			
0.00	0.006	7.75	0.006	7.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,511			
0.00	0.134	7.75	0.134	7.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	22,491			
0.00	0.276	7.75	0.276	7.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	11,581			
0.00	0.007	7.75	0.007	7.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,957			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										182,000	85.5400	65,570	0.0275	710,449	0.1420
7.75	0.02	11.00	0.037	11.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,755			
7.75	0.024	11.00	0.031	11.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,145			
7.75	0.049	11.00	0.038	11.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,445			
7.75	0.015	11.00	0.021	11.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	3,167			
7.75	0	11.00	0.06	11.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,376			
7.75	0.006	11.00	0.01	11.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	845			
7.75	0.134	11.00	0.144	11.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	9,784			
7.75	0.276	11.00	0.254	11.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	4,663			
7.75	0.007	11.00	0.007	11.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,079			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										182,000	85.5400	31,259	0.0312	679,190	0.1697
11.00	0.037	14.00	0.241	14.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	7,902			
11.00	0.031	14.00	0.115	14.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,707			
11.00	0.038	14.00	0.124	14.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,921			
11.00	0.021	14.00	0.182	14.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	16,487			
11.00	0.06	14.00	0.028	14.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	3,216			
11.00	0.01	14.00	0.021	14.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,511			
11.00	0.144	14.00	0.216	14.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	11,695			
11.00	0.254	14.00	0.604	14.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	6,968			
11.00	0.007	14.00	0.007	14.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,919			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										182,000	85.5400	63,326	0.0685	615,864	0.2000
14.00	0.241	16.15	0.078	16.15	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	6,499			
14.00	0.115	16.15	0.084	16.15	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,529			
14.00	0.124	16.15	0.071	16.15	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,107			
14.00	0.182	16.15	0.083	16.15	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	15,424			
14.00	0.028	16.15	0.018	16.15	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,205			
14.00	0.021	16.15	0.01	16.15	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,083			
14.00	0.216	16.15	0.106	16.15	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	7,497			
14.00	0.604	16.15	0.382	16.15	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	5,739			
14.00	0.007	16.15	0.004	16.15	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,080			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										182,000	85.5400	51,163	0.0773	564,701	0.2336
16.15	0.078	23.99	0.084	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	11,589			
16.15	0.084	23.99	0.071	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	23,177			
16.15	0.071	23.99	0.071	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	13,562			
16.15	0.083	23.99	0.083	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	35,233			
16.15	0.018	23.99	0.018	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	3,438			
16.15	0.01	23.99	0.01	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	2,547			
16.15	0.106	23.99	0.106	23.99	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	17,998			
16.15	0.382	23.99	0.382	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	16,215			
16.15	0.004	23.99	0.004	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,865			
										0	0.0000	0			
										0	0.0000	0			
Time Period Totals										182,000	85.5400	126,625	0.0524	438,076	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0457		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-23-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
0.00	0.035	7.75	0.035	Boiler #1& #2 - El. 89 to El. 59	59	5W	7	1,600	11,200	5.2640	5,140			
0.00	0.055	7.75	0.055	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	15,001			
0.00	0.052	7.75	0.052	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	9,819			
0.00	0.038	7.75	0.038	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	15,945			
0.00	0.01	7.75	0.01	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,888			
0.00	0.005	7.75	0.005	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,259			
0.00	0.188	7.75	0.188	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	31,555			
0.00	0.39	7.75	0.39	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	16,365			
0.00	0.004	7.75	0.004	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	2,832		
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									182,000	85.5400	99,806	0.0418	676,213	0.1351
7.75	0.035	10.75	0.049	Boiler #1& #2 - El. 89 to El. 59	59	5W	7	1,600	11,200	5.2640	2,388			
7.75	0.055	10.75	0.063	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,229			
7.75	0.052	10.75	0.051	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,764			
7.75	0.038	10.75	0.047	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,903			
7.75	0.01	10.75	0.032	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,535			
7.75	0.005	10.75	0.008	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	633			
7.75	0.188	10.75	0.52	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	23,000			
7.75	0.39	10.75	0.399	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	6,408			
7.75	0.004	10.75	0.006	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	1,371		
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									182,000	85.5400	52,232	0.0565	623,981	0.1529
10.75	0.049	13.75	0.049	Boiler #1& #2 - El. 89 to El. 59	59	5W	7	1,600	11,200	5.2640	2,786			
10.75	0.063	13.75	0.063	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,652			
10.75	0.051	13.75	0.051	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,728			
10.75	0.047	13.75	0.047	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	7,634			
10.75	0.032	13.75	0.019	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,864			
10.75	0.008	13.75	0.016	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,170			
10.75	0.52	13.75	0.137	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	21,344			
10.75	0.399	13.75	0.429	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	6,725			
10.75	0.006	13.75	0.014	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	2,741		
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									182,000	85.5400	54,642	0.0591	569,339	0.1804
13.75	0.049	16.75	0.06	Boiler #1& #2 - El. 89 to El. 59	59	5W	7	1,600	11,200	5.2640	3,098			
13.75	0.063	16.75	0.072	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,127			
13.75	0.051	16.75	0.072	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,495			
13.75	0.047	16.75	0.057	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,446			
13.75	0.019	16.75	0.015	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,243			
13.75	0.016	16.75	0.019	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,706			
13.75	0.137	16.75	0.097	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	7,602			
13.75	0.429	16.75	0.355	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	6,367			
13.75	0.014	16.75	0.005	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	2,604		
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									182,000	85.5400	42,688	0.0462	526,651	0.2359
16.75	0.06	23.99	0.06	Boiler #1& #2 - El. 89 to El. 59	59	5W	7	1,600	11,200	5.2640	8,232			
16.75	0.072	23.99	0.072	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	18,346			
16.75	0.072	23.99	0.072	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	12,701			
16.75	0.057	23.99	0.057	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	22,344			
16.75	0.015	23.99	0.015	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,646			
16.75	0.019	23.99	0.019	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	4,469			
16.75	0.097	23.99	0.097	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	15,210			
16.75	0.355	23.99	0.355	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	13,916			
16.75	0.005	23.99	0.005	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	3,308		
											0	0.0000	0	
											0	0.0000	0	
Time Period Totals									182,000	85.5400	101,171	0.0454	425,480	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0474		
24 HR. COMPLIANCE STANDARD												0.105		
												IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-24-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)			
0.00	0.037	8.00	0.037	Boiler #1& #2 - El. 89 to El. 59	59 SW		7	1,600	11,200	5.2640	5,609						
0.00	0.073	8.00	0.073	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	20,553						
0.00	0.052	8.00	0.052	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	10,136						
0.00	0.052	8.00	0.052	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	22,524						
0.00	0.004	8.00	0.004	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	780						
0.00	0.008	8.00	0.008	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	2,079						
0.00	0.064	8.00	0.064	Turbine #2 - El. 36	36 W		8	1,600	12,800	6.0160	11,089						
0.00	0.328	8.00	0.328	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	14,207						
0.00	0.004	8.00	0.004	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,924						
0.00	0.064	8.00	0.064	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	5,544						
											0	0.0000	0				
Time Period Totals											188,400	88.5480	95,445	0.0374	707,862	0.1388	
8.00	0.037	10.50	0.065	Boiler #1& #2 - El. 89 to El. 59	59 SW		7	1,600	11,200	5.2640	2,416						
8.00	0.073	10.50	0.056	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	5,675						
8.00	0.052	10.50	0.056	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,289						
8.00	0.052	10.50	0.07	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	8,257						
8.00	0.004	10.50	0.022	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	792						
8.00	0.008	10.50	0.01	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	731						
8.00	0.064	10.50	0.382	Turbine #2 - El. 36	36 W		8	1,600	12,800	6.0160	12,074						
8.00	0.328	10.50	0.527	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	5,787						
8.00	0.004	10.50	0.006	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,142						
8.00	0.064	10.50	0.064	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,733						
											0	0.0000	0				
Time Period Totals											188,400	88.5480	41,896	0.0526	665,967	0.1548	
10.50	0.065	13.00	0.028	Boiler #1& #2 - El. 89 to El. 59	59 SW		7	1,600	11,200	5.2640	2,203						
10.50	0.056	13.00	0.049	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	4,619						
10.50	0.056	13.00	0.048	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,167						
10.50	0.07	13.00	0.047	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	7,919						
10.50	0.022	13.00	0.014	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	1,096						
10.50	0.01	13.00	0.011	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	853						
10.50	0.382	13.00	0.168	Turbine #2 - El. 36	36 W		8	1,600	12,800	6.0160	14,890						
10.50	0.527	13.00	0.344	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	5,895						
10.50	0.006	13.00	0.006	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,371						
10.50	0.064	13.00	0.072	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,841						
											0	0.0000	0				
Time Period Totals											188,400	88.5480	43,853	0.0550	622,114	0.1774	
13.00	0.028	15.00	0.034	Boiler #1& #2 - El. 89 to El. 59	59 SW		7	1,600	11,200	5.2640	1,175						
13.00	0.049	15.00	0.036	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	2,991						
13.00	0.048	15.00	0.032	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,949						
13.00	0.047	15.00	0.034	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	4,386						
13.00	0.014	15.00	0.01	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	585						
13.00	0.011	15.00	0.005	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	520						
13.00	0.168	15.00	0.181	Turbine #2 - El. 36	36 W		8	1,600	12,800	6.0160	7,559						
13.00	0.344	15.00	0.441	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	4,250						
13.00	0.006	15.00	0.01	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,462						
13.00	0.072	15.00	0.061	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,440						
											0	0.0000	0				
Time Period Totals											188,400	88.5480	26,317	0.0413	595,797	0.2077	
15.00	0.034	23.99	0.034	Boiler #1& #2 - El. 89 to El. 59	59 SW		7	1,600	11,200	5.2640	5,792						
15.00	0.036	23.99	0.036	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	11,390						
15.00	0.032	23.99	0.032	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,009						
15.00	0.034	23.99	0.034	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	16,550						
15.00	0.01	23.99	0.01	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	2,190						
15.00	0.005	23.99	0.005	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	1,460						
15.00	0.181	23.99	0.181	Turbine #2 - El. 36	36 W		8	1,600	12,800	6.0160	35,241						
15.00	0.441	23.99	0.441	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	21,466						
15.00	0.01	23.99	0.01	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	8,214						
15.00	0.061	23.99	0.061	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	5,938						
											0	0.0000	0				
Time Period Totals											188,400	88.5480	115,251	0.0402	480,546		
24 HR. ACTUAL COMPLIANCE TOTAL															0.0422		
24 HR. COMPLIANCE STANDARD															0.105		IN COMPLIANCE

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADI. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-27-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.026	7.75	0.026	7.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,819				
0.00	0.029	7.75	0.029	7.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,910				
0.00	0.031	7.75	0.031	7.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,854				
0.00	0.032	7.75	0.032	7.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	13,428				
0.00	0.012	7.75	0.012	7.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,266				
0.00	0.012	7.75	0.012	7.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	3,021				
0.00	0.127	7.75	0.127	7.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	21,316				
0.00	0.266	7.75	0.266	7.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	11,162				
0.00	0.006	7.75	0.006	7.75	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	4,249				
0.00	0.036	7.75	0.036	7.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,021				
Time Period																
Totals											188,400	88.5480	76,045	0.0308	727,263	0.1404
7.75	0.026	10.75	0.053	10.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,246				
7.75	0.029	10.75	0.067	10.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,068				
7.75	0.031	10.75	0.071	10.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,728				
7.75	0.032	10.75	0.052	10.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,822				
7.75	0.012	10.75	0.011	10.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	841				
7.75	0.012	10.75	0.012	10.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,170				
7.75	0.127	10.75	0.212	10.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	11,013				
7.75	0.266	10.75	0.252	10.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	4,207				
7.75	0.006	10.75	0.008	10.75	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,919				
7.75	0.036	10.75	0.042	10.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,267				
Time Period																
Totals											188,400	88.5480	38,279	0.0400	688,983	0.1631
10.75	0.053	14.00	0.031	14.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,587				
10.75	0.067	14.00	0.039	14.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,062				
10.75	0.071	14.00	0.054	14.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,949				
10.75	0.052	14.00	0.039	14.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,007				
10.75	0.011	14.00	0.022	14.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,307				
10.75	0.012	14.00	0.01	14.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,161				
10.75	0.127	14.00	0.175	14.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	13,620				
10.75	0.252	14.00	0.2	14.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	3,977				
10.75	0.008	14.00	0.02	14.00	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	4,157				
10.75	0.042	14.00	0.037	14.00	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,390				
Time Period																
Totals											188,400	88.5480	47,217	0.0456	641,767	0.2013
14.00	0.031	16.25	0.043	16.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,578				
14.00	0.039	16.25	0.037	16.25	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,009				
14.00	0.054	16.25	0.03	16.25	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,302				
14.00	0.039	16.25	0.04	16.25	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,812				
14.00	0.022	16.25	0.006	16.25	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	767				
14.00	0.01	16.25	0.004	16.25	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	512				
14.00	0.175	16.25	0.112	16.25	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	6,993				
14.00	0.2	16.25	0.262	16.25	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	2,814				
14.00	0.02	16.25	0.005	16.25	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	2,570				
14.00	0.037	16.25	0.033	16.25	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	853				
Time Period																
Totals											188,400	88.5480	26,210	0.0365	615,557	0.2492
16.25	0.043	23.99	0.043	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	6,307				
16.25	0.037	23.99	0.037	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	10,079				
16.25	0.03	23.99	0.03	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,658				
16.25	0.04	23.99	0.04	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	16,763				
16.25	0.006	23.99	0.006	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,132				
16.25	0.004	23.99	0.004	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,006				
16.25	0.112	23.99	0.112	23.99	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	18,775				
16.25	0.262	23.99	0.262	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	10,980				
16.25	0.005	23.99	0.005	23.99	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	3,536				
16.25	0.033	23.99	0.033	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,766				
Time Period																
Totals											188,400	88.5480	77,000	0.0312	538,557	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0346			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADL IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 02-28-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE [CFM]	TOTAL FLOWRATE [M ³ /SEC]	EMISSIONS (MG)	AVG. CONC [MG/M ³]	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH [MG/M ³]		
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION										
0.00	0.013	7.75	0.013	7.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,909					
0.00	0.019	7.75	0.019	7.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,182					
0.00	0.027	7.75	0.027	7.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,098					
0.00	0.02	7.75	0.02	7.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,392					
0.00	0.013	7.75	0.013	7.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,455					
0.00	0.02	7.75	0.02	7.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	5,035					
0.00	0.083	7.75	0.083	7.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	13,931					
0.00	0.24	7.75	0.24	7.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	10,071					
0.00	0.005	7.75	0.005	7.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,541					
0.00	0.029	7.75	0.029	7.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,434					
Time Period																	
Totals												188,400	88.5480	58,049	0.0235	745,259	0.1439
7.75	0.013	10.50	0.029	10.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,094					
7.75	0.019	10.50	0.035	10.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,613					
7.75	0.027	10.50	0.043	10.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,345					
7.75	0.02	10.50	0.028	10.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	3,574					
7.75	0.013	10.50	0.031	10.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,474					
7.75	0.02	10.50	0.01	10.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,340					
7.75	0.083	10.50	0.239	10.50	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	9,589					
7.75	0.24	10.50	0.229	10.50	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	3,492					
7.75	0.005	10.50	0.01	10.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,884					
7.75	0.029	10.50	0.028	10.50	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	849					
Time Period																	
Totals												188,400	88.5480	28,254	0.0322	717,005	0.1666
10.50	0.029	14.00	0.044	14.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,421					
10.50	0.035	14.00	0.039	14.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,558					
10.50	0.043	14.00	0.046	14.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,795					
10.50	0.028	14.00	0.033	14.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	5,780					
10.50	0.031	14.00	0.035	14.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,814					
10.50	0.01	14.00	0.011	14.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,194					
10.50	0.239	14.00	0.185	14.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	16,070					
10.50	0.229	14.00	0.324	14.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	5,240					
10.50	0.01	14.00	0.008	14.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,878					
10.50	0.028	14.00	0.035	14.00	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,194					
Time Period																	
Totals												188,400	88.5480	45,943	0.0412	671,062	0.2105
14.00	0.044	16.75	0.03	16.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,928					
14.00	0.039	16.75	0.072	16.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,371					
14.00	0.046	16.75	0.084	16.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,355					
14.00	0.033	16.75	0.041	16.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	5,509					
14.00	0.035	16.75	0.007	16.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,407					
14.00	0.011	16.75	0.01	16.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	938					
14.00	0.185	16.75	0.239	16.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	12,626					
14.00	0.324	16.75	0.451	16.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	5,770					
14.00	0.008	16.75	0.006	16.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,759					
14.00	0.035	16.75	0.033	16.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,012					
Time Period																	
Totals												188,400	88.5480	40,677	0.0464	630,385	0.2728
16.75	0.03	23.99	0.03	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	4,116					
16.75	0.072	23.99	0.072	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	18,346					
16.75	0.084	23.99	0.084	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	14,818					
16.75	0.041	23.99	0.041	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	16,072					
16.75	0.007	23.99	0.007	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,235					
16.75	0.01	23.99	0.01	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	2,352					
16.75	0.239	23.99	0.239	23.99	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	37,475					
16.75	0.451	23.99	0.451	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	17,679					
16.75	0.006	23.99	0.006	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,969					
16.75	0.033	23.99	0.033	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,587					
Time Period																	
Totals												188,400	88.5480	118,649	0.0514	511,736	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0381				
24 HR. COMPLIANCE STANDARD													0.105		IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-01-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.011	7.75	0.011	7.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,616				
0.00	0.021	7.75	0.021	7.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,728				
0.00	0.034	7.75	0.034	7.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	6,420				
0.00	0.018	7.75	0.018	7.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	7,553				
0.00	0.013	7.75	0.013	7.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,455				
0.00	0.003	7.75	0.003	7.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	755				
0.00	0.34	7.75	0.34	7.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	57,068				
0.00	0.347	7.75	0.347	7.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	14,561				
0.00	0.007	7.75	0.007	7.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,957				
0.00	0.023	7.75	0.023	7.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,930				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	103,042	0.0417	700,266	0.1352
7.75	0.011	11.00	0.052	11.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,940				
7.75	0.021	11.00	0.061	11.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,690				
7.75	0.034	11.00	0.068	11.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,038				
7.75	0.018	11.00	0.062	11.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	7,039				
7.75	0.013	11.00	0.013	11.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,029				
7.75	0.003	11.00	0.011	11.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	739				
7.75	0.34	11.00	0.26	11.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	21,116				
7.75	0.347	11.00	0.367	11.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	6,282				
7.75	0.007	11.00	0.007	11.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,079				
7.75	0.023	11.00	0.027	11.00	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	880				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	49,832	0.0481	650,434	0.1570
11.00	0.052	13.75	0.035	13.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,267				
11.00	0.061	13.75	0.044	13.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,081				
11.00	0.068	13.75	0.052	13.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,020				
11.00	0.062	13.75	0.045	13.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	7,966				
11.00	0.013	13.75	0.024	13.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,240				
11.00	0.011	13.75	0.014	13.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,117				
11.00	0.26	13.75	0.353	13.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	18,255				
11.00	0.367	13.75	0.395	13.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	5,673				
11.00	0.007	13.75	0.011	13.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,261				
11.00	0.027	13.75	0.117	13.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,144				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	50,023	0.0571	600,410	0.1838
13.75	0.035	16.50	0.027	16.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,616				
13.75	0.044	16.50	0.046	16.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,355				
13.75	0.052	16.50	0.043	16.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,183				
13.75	0.045	16.50	0.037	16.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,105				
13.75	0.024	16.50	0.01	16.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,139				
13.75	0.014	16.50	0.007	16.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	938				
13.75	0.353	16.50	0.119	16.50	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	14,056				
13.75	0.395	16.50	0.228	16.50	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	4,638				
13.75	0.011	16.50	0.011	16.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,764				
13.75	0.117	16.50	0.358	16.50	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	7,073				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	45,866	0.0523	554,545	0.2319
16.50	0.027	23.99	0.027	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,832				
16.50	0.046	23.99	0.046	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	12,126				
16.50	0.043	23.99	0.043	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,847				
16.50	0.037	23.99	0.037	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	15,005				
16.50	0.01	23.99	0.01	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,825				
16.50	0.007	23.99	0.007	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,703				
16.50	0.119	23.99	0.119	23.99	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	19,304				
16.50	0.228	23.99	0.228	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	9,246				
16.50	0.011	23.99	0.011	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	7,528				
16.50	0.358	23.99	0.358	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	29,037				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	107,453	0.0450	447,092	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0466			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-02-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.023	7.75	0.023	7.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,378				
0.00	0.028	7.75	0.028	7.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,637				
0.00	0.035	7.75	0.035	7.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	6,609				
0.00	0.032	7.75	0.032	7.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	13,428				
0.00	0.015	7.75	0.015	7.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,832				
0.00	0.013	7.75	0.013	7.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	3,273				
0.00	0.201	7.75	0.201	7.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	33,737				
0.00	0.394	7.75	0.394	7.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	16,533				
0.00	0.006	7.75	0.006	7.75	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	4,249				
0.00	0.134	7.75	0.134	7.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	11,246				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	102,921	0.0417	700,386	0.1352
7.75	0.023	10.75	0.037	10.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,706				
7.75	0.028	10.75	0.058	10.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,540				
7.75	0.035	10.75	0.058	10.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,399				
7.75	0.032	10.75	0.078	10.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,934				
7.75	0.015	10.75	0	10.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	548				
7.75	0.013	10.75	0.014	10.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,316				
7.75	0.201	10.75	0.026	10.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	7,374				
7.75	0.394	10.75	0.361	10.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	6,132				
7.75	0.006	10.75	0.014	10.75	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	2,741				
7.75	0.134	10.75	0.313	10.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	7,261				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	43,950	0.0460	656,436	0.1554
10.75	0.037	13.75	0.037	13.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,103				
10.75	0.058	13.75	0.05	13.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,701				
10.75	0.058	13.75	0.065	13.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,495				
10.75	0.078	13.75	0.062	13.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	11,370				
10.75	0	13.75	0.019	13.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	694				
10.75	0.014	13.75	0.018	13.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,559				
10.75	0.026	13.75	0.226	13.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	8,187				
10.75	0.361	13.75	0.328	13.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	5,596				
10.75	0.014	13.75	0.012	13.75	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	3,563				
10.75	0.313	13.75	0.189	13.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	8,154				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	51,424	0.0538	605,012	0.1852
13.75	0.037	16.00	0.022	16.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,258				
13.75	0.05	16.00	0.032	16.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,247				
13.75	0.065	16.00	0.032	16.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,659				
13.75	0.062	16.00	0.038	16.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,091				
13.75	0.019	16.00	0.017	16.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	987				
13.75	0.018	16.00	0.016	16.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,243				
13.75	0.226	16.00	0.114	16.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	8,284				
13.75	0.328	16.00	0.317	16.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	3,929				
13.75	0.012	16.00	0.032	16.00	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	4,523				
13.75	0.189	16.00	0.36	16.00	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	6,688				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	38,908	0.0542	566,105	0.2220
16.00	0.022	23.99	0.022	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,331				
16.00	0.032	23.99	0.032	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	8,998				
16.00	0.032	23.99	0.032	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	6,230				
16.00	0.038	23.99	0.038	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	16,439				
16.00	0.017	23.99	0.017	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	3,309				
16.00	0.016	23.99	0.016	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	4,153				
16.00	0.114	23.99	0.114	23.99	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	19,727				
16.00	0.317	23.99	0.317	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	13,714				
16.00	0.032	23.99	0.032	23.99	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	23,361				
16.00	0.36	23.99	0.36	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	31,148				
											0	0.0000	0			
Time Period Totals											188,400	88.5480	130,410	0.0512	435,694	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0481			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-03-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.014	8.00	0.014	8.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,122				
0.00	0.016	8.00	0.016	8.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,505				
0.00	0.014	8.00	0.014	8.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,729				
0.00	0.011	8.00	0.011	8.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,765				
0.00	0.017	8.00	0.017	8.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	3,314				
0.00	0.006	8.00	0.006	8.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,559				
0.00	0.123	8.00	0.123	8.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	21,311				
0.00	0.189	8.00	0.189	8.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	8,187				
0.00	0.01	8.00	0.01	8.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	7,309				
0.00	0.038	8.00	0.038	8.00	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,292				
										0	0.0000	0				
Time Period Totals										188,400	88.5480	59,093	0.0232	744,215	0.1459	
8.00	0.014	10.75	0.044	10.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,511				
8.00	0.016	10.75	0.08	10.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,646				
8.00	0.014	10.75	0.083	10.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,250				
8.00	0.011	10.75	0.063	10.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	5,509				
8.00	0.017	10.75	0.01	10.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	905				
8.00	0.006	10.75	0.01	10.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	715				
8.00	0.123	10.75	0.316	10.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	13,073				
8.00	0.189	10.75	0.547	10.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	5,479				
8.00	0.01	10.75	0.017	10.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,392				
8.00	0.038	10.75	0.206	10.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,633				
										0	0.0000	0				
Time Period Totals										188,400	88.5480	42,112	0.0480	702,102	0.1662	
10.75	0.044	13.75	0.035	13.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,246				
10.75	0.08	13.75	0.061	13.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,443				
10.75	0.083	13.75	0.054	13.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,007				
10.75	0.063	13.75	0.047	13.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,934				
10.75	0.01	13.75	0.018	13.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,023				
10.75	0.01	13.75	0.008	13.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	877				
10.75	0.316	13.75	0.204	13.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	16,893				
10.75	0.547	13.75	0.344	13.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	7,236				
10.75	0.017	13.75	0.009	13.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,563				
10.75	0.206	13.75	0.319	13.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	8,528				
										0	0.0000	0				
Time Period Totals										188,400	88.5480	61,751	0.0646	640,352	0.1960	
13.75	0.035	14.75	0.032	14.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	635				
13.75	0.061	14.75	0.091	14.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,675				
13.75	0.054	14.75	0.11	14.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,998				
13.75	0.047	14.75	0.058	14.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,843				
13.75	0.018	14.75	0.018	14.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	439				
13.75	0.008	14.75	0.008	14.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	260				
13.75	0.204	14.75	0.204	14.75	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	4,418				
13.75	0.344	14.75	0.344	14.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	1,863				
13.75	0.009	14.75	0.009	14.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	822				
13.75	0.319	14.75	0.319	14.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,454				
										0	0.0000	0				
Time Period Totals										188,400	88.5480	19,406	0.0609	620,946	0.2106	
14.75	0.032	23.99	0.032	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	5,603				
14.75	0.091	23.99	0.091	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	29,592				
14.75	0.11	23.99	0.11	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	24,764				
14.75	0.058	23.99	0.058	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	29,017				
14.75	0.018	23.99	0.018	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	4,052				
14.75	0.008	23.99	0.008	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	2,401				
14.75	0.204	23.99	0.204	23.99	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	40,824				
14.75	0.344	23.99	0.344	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	17,210				
14.75	0.009	23.99	0.009	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	7,598				
14.75	0.319	23.99	0.319	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	31,919				
										0	0.0000	0				
Time Period Totals										188,400	88.5480	192,981	0.0655	427,965		
24 HR. ACTUAL COMPLIANCE TOTAL												0.0491				
24 HR. COMPLIANCE STANDARD												0.105	IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-06-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE		EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)			FLOOR ELEV.	LOCATION			(CFM)	(M ³ /SEC)				
0.00	0.01	8.00	0.01	Boiler #1& #2 - El. 89 to El. 59		59 SW	7	1,600	11,200	5.2640	1,516				
0.00	0.012	8.00	0.012	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	3,379				
0.00	0.014	8.00	0.014	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,729				
0.00	0.013	8.00	0.013	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	5,631				
0.00	0.005	8.00	0.005	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	975				
0.00	0.006	8.00	0.006	Precipitator - El. 24		24 W	12	1,600	19,200	9.0240	1,559				
0.00	0.016	8.00	0.016	Turbine #2 - El. 36		36 W	8	1,600	12,800	6.0160	2,772				
0.00	0.163	8.00	0.163	Turbine #2 - El. 24		24 W	2	1,600	3,200	1.5040	7,060				
0.00	0.005	8.00	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,655				
0.00	0.014	8.00	0.014	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,213				
										0	0.0000	0			
Time Period Totals										188,400	88.5480	30,488	0.0120	772,819	0.1515
8.00	0.01	10.75	0.032	Boiler #1& #2 - El. 89 to El. 59		59 SW	7	1,600	11,200	5.2640	1,094				
8.00	0.012	10.75	0.029	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	1,984				
8.00	0.014	10.75	0.028	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,407				
8.00	0.013	10.75	0.025	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	2,829				
8.00	0.005	10.75	0.014	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	637				
8.00	0.006	10.75	0.011	Precipitator - El. 24		24 W	12	1,600	19,200	9.0240	759				
8.00	0.016	10.75	0.287	Turbine #2 - El. 36		36 W	8	1,600	12,800	6.0160	9,023				
8.00	0.163	10.75	0.548	Turbine #2 - El. 24		24 W	2	1,600	3,200	1.5040	5,293				
8.00	0.005	10.75	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,256				
8.00	0.014	10.75	0.071	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,266				
										0	0.0000	0			
Time Period Totals										188,400	88.5480	25,549	0.0291	747,270	0.1769
10.75	0.032	13.75	0.007	Boiler #1& #2 - El. 89 to El. 59		59 SW	7	1,600	11,200	5.2640	1,109				
10.75	0.029	13.75	0.045	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	3,906				
10.75	0.028	13.75	0.057	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,107				
10.75	0.025	13.75	0.042	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	5,441				
10.75	0.014	13.75	0.02	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	1,243				
10.75	0.011	13.75	0.009	Precipitator - El. 24		24 W	12	1,600	19,200	9.0240	975				
10.75	0.287	13.75	0.238	Turbine #2 - El. 36		36 W	8	1,600	12,800	6.0160	17,055				
10.75	0.548	13.75	0.319	Turbine #2 - El. 24		24 W	2	1,600	3,200	1.5040	7,041				
10.75	0.005	13.75	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,371				
10.75	0.071	13.75	0.075	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	2,372				
										0	0.0000	0			
Time Period Totals										188,400	88.5480	43,619	0.0456	703,651	0.2154
13.75	0.007	15.75	0.007	Boiler #1& #2 - El. 89 to El. 59		59 SW	7	1,600	11,200	5.2640	265				
13.75	0.045	15.75	0.045	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	3,167				
13.75	0.057	15.75	0.057	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,778				
13.75	0.042	15.75	0.042	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	4,548				
13.75	0.02	15.75	0.012	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	780				
13.75	0.009	15.75	0.009	Precipitator - El. 24		24 W	12	1,600	19,200	9.0240	585				
13.75	0.238	15.75	0.137	Turbine #2 - El. 36		36 W	8	1,600	12,800	6.0160	8,122				
13.75	0.319	15.75	0.147	Turbine #2 - El. 24		24 W	2	1,600	3,200	1.5040	2,523				
13.75	0.005	15.75	0.006	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,005				
13.75	0.075	15.75	0.075	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,624				
										0	0.0000	0			
Time Period Totals										188,400	88.5480	25,397	0.0398	678,254	0.2579
15.75	0.007	23.99	0.007	Boiler #1& #2 - El. 89 to El. 59		59 SW	7	1,600	11,200	5.2640	1,093				
15.75	0.045	23.99	0.045	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	13,050				
15.75	0.057	23.99	0.057	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	11,444				
15.75	0.042	23.99	0.042	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	18,738				
15.75	0.012	23.99	0.012	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	2,409				
15.75	0.009	23.99	0.009	Precipitator - El. 24		24 W	12	1,600	19,200	9.0240	2,409				
15.75	0.137	23.99	0.137	Turbine #2 - El. 36		36 W	8	1,600	12,800	6.0160	24,449				
15.75	0.147	23.99	0.147	Turbine #2 - El. 24		24 W	2	1,600	3,200	1.5040	6,558				
15.75	0.006	23.99	0.006	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,517				
15.75	0.075	23.99	0.075	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	6,692				
										0	0.0000	0			
Time Period Totals										188,400	88.5480	91,360	0.0348	586,895	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0283			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-07-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.008	8.00	0.008	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,213					
0.00	0.009	8.00	0.009	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,534					
0.00	0.011	8.00	0.011	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,144					
0.00	0.008	8.00	0.008	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	3,465					
0.00	0.008	8.00	0.008	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,559					
0.00	0.004	8.00	0.004	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,040					
0.00	0.055	8.00	0.055	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	9,529					
0.00	0.159	8.00	0.159	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	6,887					
0.00	0.009	8.00	0.009	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	6,578				
0.00	0.124	8.00	0.124	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	10,742					
Time Period																
Totals											188,400	88.5480	45,692	0.0179	757,615	0.1485
8.00	0.008	11.00	0.025	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	938					
8.00	0.009	11.00	0.02	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	1,531					
8.00	0.011	11.00	0.025	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,316					
8.00	0.008	11.00	0.021	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,355					
8.00	0.008	11.00	0.008	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	585					
8.00	0.004	11.00	0.012	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	780					
8.00	0.055	11.00	0.031	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	2,794					
8.00	0.159	11.00	0.169	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	2,664					
8.00	0.009	11.00	0.005	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	1,919				
8.00	0.124	11.00	0.216	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	5,523					
Time Period																
Totals											188,400	88.5480	20,403	0.0213	737,212	0.1779
11.00	0.025	13.50	0.018	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,019					
11.00	0.02	13.50	0.037	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,508					
11.00	0.025	13.50	0.062	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,650					
11.00	0.021	13.50	0.023	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,978					
11.00	0.008	13.50	0.015	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	700					
11.00	0.012	13.50	0.004	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	650					
11.00	0.031	13.50	0.039	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	1,895					
11.00	0.169	13.50	0.219	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	2,626					
11.00	0.005	13.50	0.002	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	799				
11.00	0.216	13.50	0.01	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,059					
Time Period																
Totals											188,400	88.5480	18,884	0.0237	718,328	0.2146
13.50	0.018	16.25	0.029	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,225					
13.50	0.037	16.25	0.028	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,145					
13.50	0.062	16.25	0.016	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,613					
13.50	0.023	16.25	0.035	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,318					
13.50	0.015	16.25	0.015	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,005					
13.50	0.004	16.25	0.004	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	357					
13.50	0.039	16.25	0.021	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	1,787					
13.50	0.219	16.25	0.196	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	3,090					
13.50	0.002	16.25	0	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	251				
13.50	0.01	16.25	0.109	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,772					
Time Period																
Totals											188,400	88.5480	19,563	0.0223	698,765	0.2828
16.25	0.029	23.99	0.029	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	4,254					
16.25	0.028	23.99	0.028	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,627					
16.25	0.016	23.99	0.016	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,017					
16.25	0.035	23.99	0.035	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	14,668					
16.25	0.015	23.99	0.015	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,829					
16.25	0.004	23.99	0.004	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,006					
16.25	0.021	23.99	0.021	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	3,520					
16.25	0.196	23.99	0.196	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	8,214					
16.25	0	23.99	0	Turbine Area Roof Fans	El. 82	Roof	E	2	27,000	54,000	25.3800	0				
16.25	0.109	23.99	0.109	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	9,136					
Time Period																
Totals											188,400	88.5480	54,270	0.0220	644,495	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0208				
24 HR. COMPLIANCE STANDARD												0.105				
												IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-08-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE		EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION			(CFM)	(M ³ /SEC)				
0.00	0.031	8.25	0.031	8.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	4,847			
0.00	0.05	8.25	0.05	8.25	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	14,517			
0.00	0.051	8.25	0.051	8.25	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	10,251			
0.00	0.048	8.25	0.048	8.25	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	21,441			
0.00	0.014	8.25	0.014	8.25	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,814			
0.00	0.011	8.25	0.011	8.25	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	2,948			
0.00	0.11	8.25	0.11	8.25	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	19,654			
0.00	0.337	8.25	0.337	8.25	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	15,053			
0.00	0.014	8.25	0.014	8.25	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	10,553			
0.00	0.244	8.25	0.244	8.25	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	21,798			
										0	0.0000	0			
Time Period Totals										188,400	88.5480	123,878	0.0471	679,430	0.1353
8.25	0.031	11.00	0.038	11.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,798			
8.25	0.05	11.00	0.06	11.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,323			
8.25	0.051	11.00	0.068	11.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,987			
8.25	0.048	11.00	0.055	11.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	7,668			
8.25	0.014	11.00	0.006	11.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	670			
8.25	0.011	11.00	0.004	11.00	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	670			
8.25	0.11	11.00	0.021	11.00	Turbine #2 - El. 36	36	W	8	1,600	12,800	6.0160	3,901			
8.25	0.337	11.00	0.161	11.00	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	3,708			
8.25	0.014	11.00	0.005	11.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,387			
8.25	0.244	11.00	0.161	11.00	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	6,030			
										0	0.0000	0			
Time Period Totals										188,400	88.5480	36,142	0.0412	643,288	0.1552
11.00	0.038	14.50	0.074	14.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,714			
11.00	0.06	14.50	0.224	14.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	17,491			
11.00	0.068	14.50	0.179	14.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	10,532			
11.00	0.055	14.50	0.165	14.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	20,845			
11.00	0.006	14.50	0.017	14.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	981			
11.00	0.004	14.50	0	14.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	227			
11.00	0.021	14.50	0	14.50	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
11.00	0.161	14.50	0.144	14.50	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	4,335			
11.00	0.005	14.50	0.015	14.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,198			
11.00	0.161	14.50	0.238	14.50	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	7,561			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	68,885	0.0656	526,648	0.1849
14.50	0.074	16.50	0.122	16.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,714			
14.50	0.224	16.50	0.197	16.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	14,817			
14.50	0.179	16.50	0.202	16.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	9,283			
14.50	0.165	16.50	0.144	16.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	16,730			
14.50	0.017	16.50	0.043	16.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,462			
14.50	0	16.50	0.013	16.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	422			
14.50	0	16.50	0	16.50	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
14.50	0.144	16.50	0.104	16.50	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	2,014			
14.50	0.015	16.50	0.01	16.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,284			
14.50	0.238	16.50	0.147	16.50	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	4,169			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	54,896	0.0915	471,752	0.2098
16.50	0.122	23.99	0.122	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	17,316			
16.50	0.197	23.99	0.197	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	51,929			
16.50	0.202	23.99	0.202	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	36,863			
16.50	0.144	23.99	0.144	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	58,398			
16.50	0.043	23.99	0.043	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	7,847			
16.50	0.013	23.99	0.013	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	3,163			
16.50	0	23.99	0	23.99	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
16.50	0.104	23.99	0.104	23.99	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	6,326			
16.50	0.01	23.99	0.01	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	6,843			
16.50	0.147	23.99	0.147	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	11,923			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	200,610	0.0893	271,143	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0673		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-09-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.035	7.75	0.035	7.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	5,140			
0.00	0.065	7.75	0.065	7.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	17,729			
0.00	0.067	7.75	0.067	7.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	12,651			
0.00	0.059	7.75	0.059	7.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	24,757			
0.00	0.028	7.75	0.028	7.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	5,287			
0.00	0.005	7.75	0.005	7.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,259			
0.00	0	7.75	0	7.75	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
0.00	0	7.75	0	7.75	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0			
0.00	0.003	7.75	0.003	7.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,124			
0.00	0.076	7.75	0.076	7.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	6,378			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	75,326	0.0324	680,226	0.1396
7.75	0.035	10.50	0.053	10.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,293			
7.75	0.065	10.50	0.074	10.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,726			
7.75	0.067	10.50	0.08	10.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,925			
7.75	0.059	10.50	0.084	10.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	10,646			
7.75	0.028	10.50	0.009	10.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,240			
7.75	0.005	10.50	0	10.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	223			
7.75	0	10.50	0	10.50	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
7.75	0	10.50	0	10.50	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0			
7.75	0.003	10.50	0.019	10.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,764			
7.75	0.076	10.50	0.5	10.50	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	8,576			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	37,393	0.0454	642,833	0.1588
10.50	0.053	13.75	0.071	13.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	3,819			
10.50	0.074	13.75	0.076	13.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	8,578			
10.50	0.08	13.75	0.079	13.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	6,295			
10.50	0.084	13.75	0.074	13.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	13,901			
10.50	0.009	13.75	0.046	13.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,178			
10.50	0	13.75	0.009	13.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	475			
10.50	0	13.75	0	13.75	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
10.50	0	13.75	0	13.75	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0			
10.50	0.019	13.75	0.022	13.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	6,087			
10.50	0.5	13.75	0.376	13.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	15,415			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	56,749	0.0582	586,084	0.1907
13.75	0.071	16.50	0.031	16.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,658			
13.75	0.076	16.50	0.069	16.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,017			
13.75	0.079	16.50	0.063	16.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,757			
13.75	0.074	16.50	0.064	16.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	10,274			
13.75	0.046	16.50	0.014	16.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,010			
13.75	0.009	16.50	0.012	16.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	938			
13.75	0	16.50	0	16.50	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
13.75	0	16.50	0	16.50	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0			
13.75	0.022	16.50	0.007	16.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,643			
13.75	0.376	16.50	0.081	16.50	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	6,805			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	38,102	0.0462	547,983	0.2437
16.50	0.031	23.99	0.031	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	4,400			
16.50	0.069	23.99	0.069	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	18,188			
16.50	0.063	23.99	0.063	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	11,497			
16.50	0.064	23.99	0.064	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	25,954			
16.50	0.014	23.99	0.014	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,555			
16.50	0.012	23.99	0.012	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	2,920			
16.50	0	23.99	0	23.99	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
16.50	0	23.99	0	23.99	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0			
16.50	0.007	23.99	0.007	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,790			
16.50	0.081	23.99	0.081	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	6,570			
										0	0.0000	0			
Time Period Totals										177,200	83.2840	76,875	0.0342	471,108	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0395		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-10-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.018	7.75	0.018	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,644				
0.00	0.021	7.75	0.021	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,728				
0.00	0.027	7.75	0.027	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,098				
0.00	0.025	7.75	0.025	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	10,490				
0.00	0.016	7.75	0.016	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	3,021				
0.00	0.01	7.75	0.01	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	2,518				
0.00	0	7.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
0.00	0	7.75	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
0.00	0.008	7.75	0.008	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	5,665				
0.00	0.037	7.75	0.037	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,105				
Time Period Totals										177,200	83.2840	38,269	0.0165	717,283	0.1472
7.75	0.018	10.75	0.16	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	5,060				
7.75	0.021	10.75	0.222	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	12,828				
7.75	0.027	10.75	0.186	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,785				
7.75	0.025	10.75	0.221	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	19,979				
7.75	0.016	10.75	0.114	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	4,751				
7.75	0.01	10.75	0.012	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,072				
7.75	0	10.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
7.75	0	10.75	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
7.75	0.008	10.75	0.018	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,563				
7.75	0.037	10.75	0.344	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	6,189				
Time Period Totals										177,200	83.2840	61,227	0.0681	656,057	0.1651
10.75	0.16	13.50	0.074	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	6,097				
10.75	0.222	13.50	0.158	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	18,389				
10.75	0.186	13.50	0.139	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	10,888				
10.75	0.221	13.50	0.135	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	26,503				
10.75	0.114	13.50	0.053	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	5,595				
10.75	0.012	13.50	0.005	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	759				
10.75	0	13.50	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
10.75	0	13.50	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
10.75	0.018	13.50	0.007	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,141				
10.75	0.344	13.50	0.202	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	8,130				
Time Period Totals										177,200	83.2840	79,502	0.0964	576,555	0.1831
13.50	0.074	15.00	0.063	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	1,947				
13.50	0.158	15.00	0.092	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,599				
13.50	0.139	15.00	0.087	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,130				
13.50	0.135	15.00	0.082	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,812				
13.50	0.053	15.00	0.024	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,407				
13.50	0.005	15.00	0.004	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	219				
13.50	0	15.00	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
13.50	0	15.00	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
13.50	0.007	15.00	0.014	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,439				
13.50	0.202	15.00	0.135	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,737				
Time Period Totals										177,200	83.2840	27,290	0.0607	549,265	0.2036
15.00	0.063	23.99	0.063	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	10,733				
15.00	0.092	23.99	0.092	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	29,108				
15.00	0.087	23.99	0.087	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	19,056				
15.00	0.082	23.99	0.082	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	39,914				
15.00	0.024	23.99	0.024	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	5,257				
15.00	0.004	23.99	0.004	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	1,168				
15.00	0	23.99	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
15.00	0	23.99	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
15.00	0.014	23.99	0.014	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	11,500				
15.00	0.135	23.99	0.135	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	13,142				
Time Period Totals										177,200	83.2840	129,878	0.0482	419,386	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0467			
24 HR. COMPLIANCE STANDARD												0.105 IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-13-2017

CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL.	AVG. CONC.	
TIME START	(MG/M ³)	TIME END	(MG/M ³)		FLOOR ELEV.	LOCATION							EMISSIONS	TO FINISH	
0.00	0.038	6.75	0.038	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	4,861				
0.00	0.048	6.75	0.048	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	11,403				
0.00	0.062	6.75	0.062	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	10,197				
0.00	0.04	6.75	0.04	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	14,619				
0.00	0	6.75	0	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0				
0.00	0	6.75	0	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	0				
0.00	0	6.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
0.00	0	6.75	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
0.00	0	6.75	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.005	6.75	0.005	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	365				
										0	0.0000	0			
Time Period Totals										177,200	83.2840	41,445	0.0205	714,108	0.1381
6.75	0.038	10.00	0.096	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	4,126				
6.75	0.048	10.00	0.149	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	11,266				
6.75	0.062	10.00	0.127	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,483				
6.75	0.04	10.00	0.119	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	13,989				
6.75	0	10.00	0.008	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	317				
6.75	0	10.00	0	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0				
6.75	0	10.00	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
6.75	0	10.00	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
6.75	0	10.00	0.004	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	594				
6.75	0.005	10.00	0.121	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,217				
										0	0.0000	0			
Time Period Totals										158,000	74.2600	39,993	0.0460	592,249	0.1582
10.00	0.096	13.75	0.06	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	5,543				
10.00	0.149	13.75	0.093	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	15,969				
10.00	0.127	13.75	0.096	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	10,188				
10.00	0.119	13.75	0.072	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	19,390				
10.00	0.008	13.75	0.011	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	868				
10.00	0	13.75	0	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0				
10.00	0	13.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
10.00	0	13.75	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
10.00	0.004	13.75	0.007	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,884				
10.00	0.121	13.75	0.056	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,594				
										0	0.0000	0			
Time Period Totals										158,000	74.2600	57,436	0.0573	534,813	0.1952
13.75	0.06	15.75	0.057	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	2,217				
13.75	0.093	15.75	0.088	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,370				
13.75	0.096	15.75	0.079	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,264				
13.75	0.072	15.75	0.086	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	8,555				
13.75	0.011	15.75	0	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	268				
13.75	0	15.75	0	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0				
13.75	0	15.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
13.75	0	15.75	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
13.75	0.007	15.75	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	640				
13.75	0.056	15.75	0.034	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	975				
										0	0.0000	0			
Time Period Totals										158,000	74.2600	23,288	0.0436	511,525	0.2319
15.75	0.057	23.99	0.057	Boiler #1& #2 - El. 89 to El. 59	59	SW	7	1,600	11,200	5.2640	8,901				
15.75	0.088	23.99	0.088	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	25,520				
15.75	0.079	23.99	0.079	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	15,861				
15.75	0.086	23.99	0.086	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	38,369				
15.75	0	23.99	0	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0				
15.75	0	23.99	0	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0				
15.75	0	23.99	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
15.75	0	23.99	0	Turbine #2 - El. 24	24	W	3	1,600	4,800	2.2560	0				
15.75	0	23.99	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
15.75	0.034	23.99	0.034	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,034				
										0	0.0000	0			
Time Period Totals										158,000	74.2600	91,683	0.0416	419,842	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0396			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-15-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.005	6.75	0.005	6.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	548				
0.00	0.027	6.75	0.027	6.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,414				
0.00	0.039	6.75	0.039	6.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	6,414				
0.00	0.007	6.75	0.007	6.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,558				
0.00	0	6.75	0	6.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0				
0.00	0	6.75	0	6.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	0				
0.00	0	6.75	0	6.75	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
0.00	0	6.75	0	6.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	0				
0.00	0	6.75	0	6.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.013	6.75	0.013	6.75	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	1,188				
Time Period Totals											175,600	82,5320	17,122	0.0085	731,608	0.1427
6.75	0.005	10.25	0.046	10.25	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,450				
6.75	0.027	10.25	0.078	10.25	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,467				
6.75	0.039	10.25	0.067	10.25	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,520				
6.75	0.007	10.25	0.063	10.25	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,633				
6.75	0	10.25	0.019	10.25	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	810				
6.75	0	10.25	0	10.25	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	0				
6.75	0	10.25	0	10.25	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
6.75	0	10.25	0.024	10.25	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	227				
6.75	0	10.25	0.008	10.25	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,279				
6.75	0.013	10.25	0.014	10.25	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	640				
Time Period Totals											175,600	82,5320	22,025	0.0212	709,583	0.1737
10.25	0.046	13.75	0.044	13.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	2,558				
10.25	0.078	13.75	0.089	13.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	10,285				
10.25	0.067	13.75	0.068	13.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,756				
10.25	0.063	13.75	0.061	13.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	11,749				
10.25	0.019	13.75	0.005	13.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,023				
10.25	0	13.75	0	13.75	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	0				
10.25	0	13.75	0	13.75	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
10.25	0.024	13.75	0.034	13.75	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	550				
10.25	0.008	13.75	0.003	13.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,759				
10.25	0.014	13.75	0.057	13.75	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	1,682				
Time Period Totals											175,600	82,5320	35,363	0.0340	674,220	0.2214
13.75	0.044	17.50	0.068	17.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	3,411				
13.75	0.089	17.50	0.133	17.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	14,649				
13.75	0.068	17.50	0.111	17.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	8,177				
13.75	0.061	17.50	0.084	17.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	14,720				
13.75	0.005	17.50	0.026	17.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,416				
13.75	0	17.50	0	17.50	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	0				
13.75	0	17.50	0	17.50	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
13.75	0.034	17.50	0.036	17.50	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	711				
13.75	0.003	17.50	0.006	17.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,542				
13.75	0.057	17.50	0.026	17.50	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	2,107				
Time Period Totals											175,600	82,5320	46,733	0.0419	627,487	0.3249
17.50	0.068	23.99	0.068	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	7,168				
17.50	0.133	23.99	0.133	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	30,378				
17.50	0.111	23.99	0.111	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	17,552				
17.50	0.084	23.99	0.084	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	29,517				
17.50	0.026	23.99	0.026	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	4,111				
17.50	0	23.99	0	23.99	Precipitator - El. 24	24	W	12	1,600	19,200	9.0240	0				
17.50	0	23.99	0	23.99	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0				
17.50	0.036	23.99	0.036	23.99	Turbine #2 - El. 24	24	W	2	1,600	3,200	1.5040	1,265				
17.50	0.006	23.99	0.006	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,558				
17.50	0.026	23.99	0.026	23.99	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	2,284				
Time Period Totals											175,600	82,5320	95,834	0.0497	531,653	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0304			
24 HR. COMPLIANCE STANDARD													0.105	IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-16-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)			
0.00	0.014	6.75	0.014	Boiler #1& #2 - El. 89 to El. 59	59 SW		6	1,600	9,600	4.5120	1,535						
0.00	0.012	6.75	0.012	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	2,851						
0.00	0.016	6.75	0.016	Boiler #1& #2 - El. 89 to El. 59	Mezzanine W		9	1,600	14,400	6.7680	2,631						
0.00	0.009	6.75	0.009	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	3,289						
0.00	0	6.75	0	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	0						
0.00	0	6.75	0	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	0						
0.00	0	6.75	0	Turbine #2 - El. 36	36 W		0	1,600	0	0.0000	0						
0.00	0.021	6.75	0.021	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	767						
0.00	0	6.75	0	Turbine Area Roof Fans	El. 82 Roof E		2	27,000	54,000	25.3800	0						
0.00	0.012	6.75	0.012	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,096						
Time Period Totals											175,600	82.5320	12,170	0.0061	736,560	0.1437	
6.75	0.014	9.75	0.041	Boiler #1& #2 - El. 89 to El. 59	59 SW		6	1,600	9,600	4.5120	1,340						
6.75	0.012	9.75	0.085	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	5,121						
6.75	0.016	9.75	0.086	Boiler #1& #2 - El. 89 to El. 59	Mezzanine W		9	1,600	14,400	6.7680	3,728						
6.75	0.009	9.75	0.083	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	7,472						
6.75	0	9.75	0.018	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	658						
6.75	0	9.75	0	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	0						
6.75	0	9.75	0	Turbine #2 - El. 36	36 W		0	1,600	0	0.0000	0						
6.75	0.021	9.75	0.023	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	357						
6.75	0	9.75	0.01	Turbine Area Roof Fans	El. 82 Roof E		2	27,000	54,000	25.3800	1,371						
6.75	0.012	9.75	0.098	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,233						
Time Period Totals											175,600	82.5320	22,280	0.0250	714,281	0.1687	
9.75	0.041	14.00	0.038	Boiler #1& #2 - El. 89 to El. 59	59 SW		6	1,600	9,600	4.5120	2,727						
9.75	0.085	14.00	0.062	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	10,994						
9.75	0.086	14.00	0.068	Boiler #1& #2 - El. 89 to El. 59	Mezzanine W		9	1,600	14,400	6.7680	7,973						
9.75	0.083	14.00	0.078	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	18,524						
9.75	0.018	14.00	0	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	932						
9.75	0	14.00	0	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	0						
9.75	0	14.00	0	Turbine #2 - El. 36	36 W		0	1,600	0	0.0000	0						
9.75	0.023	14.00	0.012	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	403						
9.75	0.01	14.00	0.003	Turbine Area Roof Fans	El. 82 Roof E		2	27,000	54,000	25.3800	2,524						
9.75	0.098	14.00	0.136	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	6,731						
Time Period Totals											175,600	82.5320	50,807	0.0402	663,473	0.2233	
14.00	0.038	17.75	0.067	Boiler #1& #2 - El. 89 to El. 59	59 SW		6	1,600	9,600	4.5120	3,198						
14.00	0.062	17.75	0.101	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	10,756						
14.00	0.068	17.75	0.109	Boiler #1& #2 - El. 89 to El. 59	Mezzanine W		9	1,600	14,400	6.7680	8,086						
14.00	0.078	17.75	0.066	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	14,619						
14.00	0	17.75	0.007	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	320						
14.00	0	17.75	0	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	0						
14.00	0	17.75	0	Turbine #2 - El. 36	36 W		0	1,600	0	0.0000	0						
14.00	0.012	17.75	0.015	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	274						
14.00	0.003	17.75	0.004	Turbine Area Roof Fans	El. 82 Roof E		2	27,000	54,000	25.3800	1,199						
14.00	0.136	17.75	0.014	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	3,807						
Time Period Totals											175,600	82.5320	42,259	0.0379	621,214	0.3345	
17.75	0.067	23.99	0.067	Boiler #1& #2 - El. 89 to El. 59	59 SW		6	1,600	9,600	4.5120	6,791						
17.75	0.101	23.99	0.101	Boiler #1& #2 - El. 89 to El. 59	59 W		13	1,600	20,800	9.7760	22,180						
17.75	0.109	23.99	0.109	Boiler #1& #2 - El. 89 to El. 59	Mezzanine W		9	1,600	14,400	6.7680	16,572						
17.75	0.066	23.99	0.066	Boiler #1& #2 - El. 89 to El. 59	82 E		20	1,600	32,000	15.0400	22,299						
17.75	0.007	23.99	0.007	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	1,064						
17.75	0	23.99	0	Precipitator - El. 24	24 W		12	1,600	19,200	9.0240	0						
17.75	0	23.99	0	Turbine #2 - El. 36	36 W		0	1,600	0	0.0000	0						
17.75	0.015	23.99	0.015	Turbine #2 - El. 24	24 W		2	1,600	3,200	1.5040	507						
17.75	0.004	23.99	0.004	Turbine Area Roof Fans	El. 82 Roof E		2	27,000	54,000	25.3800	2,281						
17.75	0.014	23.99	0.014	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,183						
Time Period Totals											175,600	82.5320	72,876	0.0393	548,338		
24 HR. ACTUAL COMPLIANCE TOTAL															0.0281		
24 HR. COMPLIANCE STANDARD															0.105		IN COMPLIANCE

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-17-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.01	6.75	0.01	6.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,096			
0.00	0.013	6.75	0.013	6.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,088			
0.00	0.016	6.75	0.016	6.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,631			
0.00	0.008	6.75	0.008	6.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,924			
0.00	0	6.75	0	6.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0			
0.00	0	6.75	0	6.75	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0			
0.00	0	6.75	0	6.75	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
0.00	0.006	6.75	0.006	6.75	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	219			
0.00	0	6.75	0	6.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0			
0.00	0.01	6.75	0.01	6.75	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	914			
										0	0.0000	0			
Time Period Totals										156,400	73.5080	10,873	0.0061	655,992	0.1437
6.75	0.01	9.50	0.055	9.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,452			
6.75	0.013	9.50	0.099	9.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,420			
6.75	0.016	9.50	0.078	9.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,149			
6.75	0.008	9.50	0.073	9.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,030			
6.75	0	9.50	0.016	9.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	536			
6.75	0	9.50	0	9.50	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0			
6.75	0	9.50	0	9.50	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
6.75	0.006	9.50	0.009	9.50	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	112			
6.75	0	9.50	0.011	9.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,382			
6.75	0.01	9.50	0.139	9.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,773			
										0	0.0000	0			
Time Period Totals										156,400	73.5080	20,854	0.0287	635,138	0.1655
9.50	0.055	12.50	0.018	12.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,779			
9.50	0.099	12.50	0.019	12.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,229			
9.50	0.078	12.50	0.018	12.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,509			
9.50	0.073	12.50	0.013	12.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,985			
9.50	0.016	12.50	0.003	12.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	694			
9.50	0	12.50	0	12.50	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0			
9.50	0	12.50	0	12.50	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
9.50	0.009	12.50	0.01	12.50	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	154			
9.50	0.011	12.50	0.005	12.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,193			
9.50	0.139	12.50	0.045	12.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	3,736			
										0	0.0000	0			
Time Period Totals										156,400	73.5080	25,278	0.0318	609,859	0.2004
12.50	0.018	14.00	0.032	14.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	609			
12.50	0.019	14.00	0.031	14.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	1,320			
12.50	0.018	14.00	0.034	14.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	950			
12.50	0.013	14.00	0	14.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	528			
12.50	0.003	14.00	0.011	14.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	256			
12.50	0	14.00	0	14.00	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0			
12.50	0	14.00	0	14.00	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
12.50	0.01	14.00	0.016	14.00	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	106			
12.50	0.005	14.00	0.008	14.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	891			
12.50	0.045	14.00	0.15	14.00	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,980			
										0	0.0000	0			
Time Period Totals										156,400	73.5080	6,639	0.0167	603,221	0.2279
14.00	0.032	23.99	0.032	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	5,193			
14.00	0.031	23.99	0.031	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	10,899			
14.00	0.034	23.99	0.034	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	8,276			
14.00	0	23.99	0	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	0			
14.00	0.011	23.99	0.011	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,677			
14.00	0	23.99	0	23.99	Precipitator - El. 24	24	W	0	1,600	0	0.0000	0			
14.00	0	23.99	0	23.99	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
14.00	0.016	23.99	0.016	23.99	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	865			
14.00	0.008	23.99	0.008	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	7,302			
14.00	0.15	23.99	0.15	23.99	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	20,284			
										0	0.0000	0			
Time Period Totals										156,400	73.5080	55,496	0.0210	547,724	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0188		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-20-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
0.00	0.037	6.75	0.037	Boiler #1& #2 - El. 89 to El. 59	59	5W	6	1,600	9,600	4.5120	4,057			
0.00	0.108	6.75	0.108	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	25,656			
0.00	0.169	6.75	0.169	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	27,794			
0.00	0.067	6.75	0.067	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	24,487			
0.00	0.011	6.75	0.011	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	12	1,600	19,200	9.0240	2,412			
0.00	0	6.75	0	Coal Bunker Containmentment	59	N	9	1,600	14,400	6.7680	0			
0.00	0	6.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
0.00	0	6.75	0	Pipe Insulation Containmentment - El. 24	24	W	2	1,600	3,200	1.5040	0			
0.00	0.003	6.75	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,850			
0.00	0.024	6.75	0.024	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,193			
										0	0.0000	0		
Time Period Totals									175,600	82.5320	88,449	0.0441	660,282	0.1288
6.75	0.037	9.75	0.061	Boiler #1& #2 - El. 89 to El. 59	59	5W	6	1,600	9,600	4.5120	2,388			
6.75	0.108	9.75	0.076	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	9,713			
6.75	0.169	9.75	0.067	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	8,625			
6.75	0.067	9.75	0.054	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	9,827			
6.75	0.011	9.75	0.036	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	14	1,600	22,400	10.5280	2,672			
6.75	0	9.75	0.053	Coal Bunker Containmentment	59	N	9	1,600	14,400	6.7680	1,937			
6.75	0	9.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
6.75	0	9.75	0.009	Pipe Insulation Containmentment - El. 24	24	W	2	1,600	3,200	1.5040	73			
6.75	0.003	9.75	0.011	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,919			
6.75	0.024	9.75	0.122	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,964			
										0	0.0000	0		
Time Period Totals									178,800	84.0360	40,119	0.0442	633,807	0.1470
9.75	0.061	13.75	0.036	Boiler #1& #2 - El. 89 to El. 59	59	5W	6	1,600	9,600	4.5120	3,151			
9.75	0.076	13.75	0.094	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	11,966			
9.75	0.067	13.75	0.089	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,602			
9.75	0.054	13.75	0.259	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	33,894			
9.75	0.036	13.75	0.043	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	6,844			
9.75	0.053	13.75	0.06	Coal Bunker Containmentment	59	N	9	1,600	14,400	6.7680	5,506			
9.75	0	13.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
9.75	0.009	13.75	0	Pipe Insulation Containmentment - El. 24	24	W	0	1,600	0	0.0000	0			
9.75	0.011	13.75	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,924			
9.75	0.122	13.75	0.114	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	6,389			
										0	0.0000	0		
Time Period Totals									178,800	84.0360	78,276	0.0647	555,531	0.1791
13.75	0.036	15.75	0.067	Boiler #1& #2 - El. 89 to El. 59	59	5W	6	1,600	9,600	4.5120	1,673			
13.75	0.094	15.75	0.003	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,414			
13.75	0.089	15.75	0.043	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,216			
13.75	0.259	15.75	0.042	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	16,297			
13.75	0.043	15.75	0.028	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	3,075			
13.75	0.06	15.75	0.022	Coal Bunker Containmentment	59	N	9	1,600	14,400	6.7680	1,998			
13.75	0	15.75	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
13.75	0	15.75	0	Pipe Insulation Containmentment - El. 24	24	W	0	1,600	0	0.0000	0			
13.75	0.005	15.75	0.013	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,645			
13.75	0.114	15.75	0.114	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	3,086			
										0	0.0000	0		
Time Period Totals									178,800	84.0360	34,404	0.0569	521,127	0.2088
15.75	0.067	23.99	0.067	Boiler #1& #2 - El. 89 to El. 59	59	5W	6	1,600	9,600	4.5120	8,968			
15.75	0.003	23.99	0.003	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	870			
15.75	0.043	23.99	0.043	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	8,633			
15.75	0.042	23.99	0.042	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	18,738			
15.75	0.028	23.99	0.028	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	9,994			
15.75	0.022	23.99	0.022	Coal Bunker Containmentment	59	N	9	1,600	14,400	6.7680	4,417			
15.75	0	23.99	0	Turbine #2 - El. 36	36	W	0	1,600	0	0.0000	0			
15.75	0	23.99	0	Pipe Insulation Containmentment - El. 24	24	W	2	1,600	3,200	1.5040	0			
15.75	0.013	23.99	0.013	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	9,787			
15.75	0.114	23.99	0.114	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	12,715			
										0	0.0000	0		
Time Period Totals									182,000	85.5400	74,122	0.0292	460,649	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0427		
24 HR. COMPLIANCE STANDARD												0.105		
												IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-21-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.016	6.75	0.016	Boiler #1& #2 - El. 89 to El. 59		59 SW	6	1,600	9,600	4.5120	1,754					
0.00	0.017	6.75	0.017	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	4,038					
0.00	0.014	6.75	0.014	Boiler #1& #2 - El. 89 to El. 59		Mezzanine W	9	1,600	14,400	6.7680	2,302					
0.00	0.014	6.75	0.014	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	5,117					
0.00	0.014	6.75	0.014	Boiler #1& #2 - El. 49 to El. 36		49 & 36 N	16	1,600	25,600	12.0320	4,093					
0.00	0.01	6.75	0.01	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	1,645					
0.00	0	6.75	0	South Flue Gas Duct - El 95		95 W	9	1,600	0	0.0000	0					
0.00	0.015	6.75	0.015	Pipe Insulation Containment - El. 24		24 W	2	1,600	3,200	1.5040	548					
0.00	0.004	6.75	0.004	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	2,467					
0.00	0.03	6.75	0.03	Turbine #1 - El. 36		36	5	1,600	8,000	3.7600	2,741					
Time Period Totals											0	0.0000	0			
Time Period Totals											182,000	85.5400	24,706	0.0119	751,313	0.1414
6.75	0.016	10.75	0.044	Boiler #1& #2 - El. 89 to El. 59		59 SW	6	1,600	9,600	4.5120	1,949					
6.75	0.017	10.75	0.071	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	6,194					
6.75	0.014	10.75	0.053	Boiler #1& #2 - El. 89 to El. 59		Mezzanine W	9	1,600	14,400	6.7680	3,265					
6.75	0.014	10.75	0.042	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	6,064					
6.75	0.014	10.75	0.055	Boiler #1& #2 - El. 49 to El. 36		49 & 36 N	16	1,600	25,600	12.0320	5,977					
6.75	0.01	10.75	0.058	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	3,314					
6.75	0	10.75	0.022	South Flue Gas Duct - El 95		95 W	6	1,600	9,600	4.5120	715					
6.75	0.015	10.75	0.045	Pipe Insulation Containment - El. 24		24 W	2	1,600	3,200	1.5040	650					
6.75	0.004	10.75	0.014	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	3,289					
6.75	0.03	10.75	0.241	Turbine #1 - El. 36		36	5	1,600	8,000	3.7600	7,337					
Time Period Totals											0	0.0000	0			
Time Period Totals											191,600	90.0520	38,754	0.0299	753,492	0.1754
10.75	0.044	14.75	0.047	Boiler #1& #2 - El. 89 to El. 59		59 SW	6	1,600	9,600	4.5120	2,956					
10.75	0.071	14.75	0.05	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	8,517					
10.75	0.053	14.75	0.065	Boiler #1& #2 - El. 89 to El. 59		Mezzanine W	9	1,600	14,400	6.7680	5,750					
10.75	0.042	14.75	0.04	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	8,880					
10.75	0.055	14.75	0.06	Boiler #1& #2 - El. 49 to El. 36		49 & 36 N	16	1,600	25,600	12.0320	9,962					
10.75	0.058	14.75	0.023	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	3,947					
10.75	0.022	14.75	0.007	South Flue Gas Duct - El 95		95 W	6	1,600	9,600	4.5120	942					
10.75	0.045	14.75	0.022	Pipe Insulation Containment - El. 24		24 W	4	1,600	6,400	3.0080	1,451					
10.75	0.014	14.75	0.017	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	5,665					
10.75	0.241	14.75	0.224	Turbine #1 - El. 36		36	5	1,600	8,000	3.7600	12,588					
Time Period Totals											0	0.0000	0			
Time Period Totals											194,800	91.5560	60,659	0.0460	706,478	0.2317
14.75	0.047	17.75	0.032	Boiler #1& #2 - El. 89 to El. 59		59 SW	6	1,600	9,600	4.5120	1,925					
14.75	0.05	17.75	0.021	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	3,748					
14.75	0.065	17.75	0.03	Boiler #1& #2 - El. 89 to El. 59		Mezzanine W	9	1,600	14,400	6.7680	3,472					
14.75	0.04	17.75	0.027	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	5,441					
14.75	0.06	17.75	0.043	Boiler #1& #2 - El. 49 to El. 36		49 & 36 N	16	1,600	25,600	12.0320	6,692					
14.75	0.023	17.75	0.029	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	1,900					
14.75	0.007	17.75	0.007	South Flue Gas Duct - El 95		95 W	6	1,600	9,600	4.5120	341					
14.75	0.022	17.75	0.014	Pipe Insulation Containment - El. 24		24 W	4	1,600	6,400	3.0080	585					
14.75	0.017	17.75	0.014	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	4,249					
14.75	0.224	17.75	0.067	Turbine #1 - El. 36		36	5	1,600	8,000	3.7600	5,908					
Time Period Totals											0	0.0000	0			
Time Period Totals											194,800	91.5560	34,262	0.0346	672,216	0.3263
17.75	0.032	23.99	0.032	Boiler #1& #2 - El. 89 to El. 59		59 SW	6	1,600	9,600	4.5120	3,243					
17.75	0.021	23.99	0.021	Boiler #1& #2 - El. 89 to El. 59		59 W	13	1,600	20,800	9.7760	4,612					
17.75	0.03	23.99	0.03	Boiler #1& #2 - El. 89 to El. 59		Mezzanine W	9	1,600	14,400	6.7680	4,561					
17.75	0.027	23.99	0.027	Boiler #1& #2 - El. 89 to El. 59		82 E	20	1,600	32,000	15.0400	9,122					
17.75	0.043	23.99	0.043	Boiler #1& #2 - El. 49 to El. 36		49 & 36 N	16	1,600	25,600	12.0320	11,622					
17.75	0.029	23.99	0.029	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	4,409					
17.75	0.007	23.99	0.007	South Flue Gas Duct - El 95		95 W	6	1,600	9,600	4.5120	710					
17.75	0.014	23.99	0.014	Pipe Insulation Containment - El. 24		24 W	4	1,600	6,400	3.0080	946					
17.75	0.014	23.99	0.014	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	7,982					
17.75	0.067	23.99	0.067	Turbine #1 - El. 36		36	5	1,600	8,000	3.7600	5,659					
Time Period Totals											0	0.0000	0			
Time Period Totals											194,800	91.5560	52,866	0.0257	619,349	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0267				
24 HR. COMPLIANCE STANDARD												0.105				
												IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-22-2017

CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
TIME START	(MG/M ³)	TIME END	(MG/M ³)		FLOOR ELEV.	LOCATION									
0.00	0.039	7.00	0.039	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	4,434				
0.00	0.042	7.00	0.042	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	10,347				
0.00	0.039	7.00	0.039	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	6,652				
0.00	0.041	7.00	0.041	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	15,539				
0.00	0.014	7.00	0.014	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	4,245				
0.00	0.008	7.00	0.008	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,364				
0.00	0.003	7.00	0.003	South Flue Gas Duct - El. 95	95	W	16	1,600	25,600	12.0320	910				
0.00	0.005	7.00	0.005	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	190				
0.00	0	7.00	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0				
0.00	0.037	7.00	0.037	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	3,506				
Time Period Totals										207,600	97.5720	47,186	0.0192	837,987	0.1403
7.00	0.039	9.75	0.044	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,854				
7.00	0.042	9.75	0.049	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,404				
7.00	0.039	9.75	0.048	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,915				
7.00	0.041	9.75	0.053	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	6,998				
7.00	0.014	9.75	0.035	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	2,918				
7.00	0.008	9.75	0.015	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	771				
7.00	0.003	9.75	0.015	South Flue Gas Duct - El. 95	95	W	6	1,600	9,600	4.5120	402				
7.00	0.005	9.75	0.045	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	372				
7.00	0	9.75	0.025	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	3,141				
7.00	0.037	9.75	0.08	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,178				
Time Period Totals										191,600	90.0520	25,952	0.0291	743,814	0.1610
9.75	0.044	12.75	0.033	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,876				
9.75	0.049	12.75	0.047	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,068				
9.75	0.048	12.75	0.035	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,033				
9.75	0.053	12.75	0.042	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	7,716				
9.75	0.035	12.75	0.017	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	3,379				
9.75	0.015	12.75	0	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	548				
9.75	0.015	12.75	0	South Flue Gas Duct - El. 95	95	W	6	1,600	9,600	4.5120	365				
9.75	0.045	12.75	0.016	Pipe Insulation Containment - El. 24	24	W	4	1,600	6,400	3.0080	991				
9.75	0.025	12.75	0.007	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	4,386				
9.75	0.08	12.75	0.017	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,969				
Time Period Totals										194,800	91.5560	29,331	0.0297	728,127	0.1964
12.75	0.033	14.50	0.023	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	796				
12.75	0.047	14.50	0.021	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,094				
12.75	0.035	14.50	0.021	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,194				
12.75	0.042	14.50	0.021	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,985				
12.75	0.017	14.50	0.022	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	1,478				
12.75	0	14.50	0.023	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	490				
12.75	0	14.50	0.003	South Flue Gas Duct - El. 95	95	W	6	1,600	9,600	4.5120	43				
12.75	0.016	14.50	0.021	Pipe Insulation Containment - El. 24	24	W	4	1,600	6,400	3.0080	351				
12.75	0.007	14.50	0.009	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,279				
12.75	0.017	14.50	0.019	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	426				
Time Period Totals										194,800	91.5560	11,136	0.0193	716,991	0.2290
14.50	0.023	23.99	0.023	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	3,545				
14.50	0.021	23.99	0.021	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,014				
14.50	0.021	23.99	0.021	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,856				
14.50	0.021	23.99	0.021	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	10,790				
14.50	0.022	23.99	0.022	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	9,043				
14.50	0.023	23.99	0.023	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	5,318				
14.50	0.003	23.99	0.003	South Flue Gas Duct - El. 95	95	W	6	1,600	9,600	4.5120	462				
14.50	0.021	23.99	0.021	Pipe Insulation Containment - El. 24	24	W	4	1,600	6,400	3.0080	2,158				
14.50	0.009	23.99	0.009	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	7,804				
14.50	0.019	23.99	0.019	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,441				
Time Period Totals										194,800	91.5560	53,432	0.0171	663,559	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0211			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-23-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.044	7.00	0.044	7.00	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	5,003				
0.00	0.057	7.00	0.057	7.00	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	14,042				
0.00	0.043	7.00	0.043	7.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	7,334				
0.00	0.053	7.00	0.053	7.00	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	20,087				
0.00	0	7.00	0	7.00	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	0				
0.00	0	7.00	0	7.00	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	0				
0.00	0.003	7.00	0.003	7.00	South Flue Gas Duct - El. 95	95 W	W	16	1,600	25,600	12.0320	910				
0.00	0.005	7.00	0.005	7.00	Pipe Insulation Containment - El. 24	24 W	W	2	1,600	3,200	1.5040	190				
0.00	0	7.00	0	7.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0	7.00	0	7.00	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	0				
Time Period																
Totals											207,600	97.5720	47,566	0.0193	837,608	0.1403
7.00	0.044	10.00	0.1	10.00	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	3,509				
7.00	0.057	10.00	0.103	10.00	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	8,446				
7.00	0.043	10.00	0.116	10.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,811				
7.00	0.053	10.00	0.128	10.00	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	14,700				
7.00	0	10.00	0.034	10.00	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	2,209				
7.00	0	10.00	0.033	10.00	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	1,206				
7.00	0.003	10.00	0	10.00	South Flue Gas Duct - El. 95	95 W	W	6	1,600	9,600	4.5120	73				
7.00	0.005	10.00	0.057	10.00	Pipe Insulation Containment - El. 24	24 W	W	2	1,600	3,200	1.5040	504				
7.00	0	10.00	0.003	10.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	411				
7.00	0	10.00	0.034	10.00	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	690				
Time Period																
Totals											191,600	90.0520	37,559	0.0386	731,827	0.1612
10.00	0.1	13.75	0.099	13.75	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	6,061				
10.00	0.103	13.75	0.117	13.75	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	14,517				
10.00	0.116	13.75	0.111	13.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	10,370				
10.00	0.128	13.75	0.108	13.75	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	23,959				
10.00	0.034	13.75	0.031	13.75	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	5,279				
10.00	0.033	13.75	0.003	13.75	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	1,645				
10.00	0	13.75	0	13.75	South Flue Gas Duct - El. 95	95 W	W	6	1,600	9,600	4.5120	0				
10.00	0.057	13.75	0.005	13.75	Pipe Insulation Containment - El. 24	24 W	W	4	1,600	6,400	3.0080	1,259				
10.00	0.003	13.75	0.007	13.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,713				
10.00	0.034	13.75	0.101	13.75	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	3,426				
Time Period																
Totals											194,800	91.5560	68,229	0.0552	677,242	0.2005
13.75	0.099	17.50	0.013	17.50	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	3,411				
13.75	0.117	17.50	0.01	17.50	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	8,380				
13.75	0.111	17.50	0	17.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,071				
13.75	0.108	17.50	0	17.50	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	10,964				
13.75	0.031	17.50	0.013	17.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	3,574				
13.75	0.003	17.50	0	17.50	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	137				
13.75	0	17.50	0	17.50	South Flue Gas Duct - El. 95	95 W	W	6	1,600	9,600	4.5120	0				
13.75	0.005	17.50	0	17.50	Pipe Insulation Containment - El. 24	24 W	W	4	1,600	6,400	3.0080	102				
13.75	0.007	17.50	0	17.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,199				
13.75	0.101	17.50	0.027	17.50	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	3,249				
Time Period																
Totals											194,800	91.5560	36,087	0.0292	641,156	0.2993
17.50	0.013	23.99	0.013	23.99	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	1,370				
17.50	0.01	23.99	0.01	23.99	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	2,284				
17.50	0	23.99	0	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	0				
17.50	0	23.99	0	23.99	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	0				
17.50	0.013	23.99	0.013	23.99	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	3,655				
17.50	0	23.99	0	23.99	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	0				
17.50	0	23.99	0	23.99	South Flue Gas Duct - El. 95	95 W	W	6	1,600	9,600	4.5120	0				
17.50	0	23.99	0	23.99	Pipe Insulation Containment - El. 24	24 W	W	4	1,600	6,400	3.0080	0				
17.50	0	23.99	0	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
17.50	0.027	23.99	0.027	23.99	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	2,372				
Time Period																
Totals											194,800	91.5560	9,681	0.0045	631,475	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0252			
24 HR. COMPLIANCE STANDARD													0.105		IN COMPLIANCE	

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADI. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-24-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.008	6.50	0.008	6.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	845				
0.00	0.013	6.50	0.013	6.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,974				
0.00	0.008	6.50	0.008	6.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,267				
0.00	0.007	6.50	0.007	6.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,464				
0.00	0.014	6.50	0.014	6.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	3,942				
0.00	0.003	6.50	0.003	6.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	475				
0.00	0	6.50	0	6.50	South Flue Gas Duct - El 95	95	W	16	1,600	25,600	12.0320	0				
0.00	0.005	6.50	0.005	6.50	Pipe Insulation Containment - El. 24	24	W	2	1,600	3,200	1.5040	176				
0.00	0.003	6.50	0.003	6.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,782				
0.00	0.02	6.50	0.02	6.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,760				
Time Period											0	0.0000	0			
Totals											207,600	97.5720	15,683	0.0069	869,490	0.1414
6.50	0.008	9.75	0.021	9.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	765				
6.50	0.013	9.75	0.022	9.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,002				
6.50	0.008	9.75	0.019	9.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,069				
6.50	0.007	9.75	0.013	9.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	1,760				
6.50	0.014	9.75	0.017	9.75	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	2,182				
6.50	0.003	9.75	0.008	9.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	436				
6.50	0	9.75	0	9.75	South Flue Gas Duct - El 95	95	W	6	1,600	9,600	4.5120	0				
6.50	0.005	9.75	0	9.75	Pipe Insulation Containment - El. 24	24	W	0	1,600	0	0.0000	0				
6.50	0.003	9.75	0.004	9.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,039				
6.50	0.02	9.75	0.166	9.75	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	4,091				
Time Period											0	0.0000	0			
Totals											188,400	88.5480	13,344	0.0129	774,280	0.1705
9.75	0.021	13.00	0.012	13.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	871				
9.75	0.022	13.00	0.016	13.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,173				
9.75	0.019	13.00	0.017	13.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,425				
9.75	0.013	13.00	0.004	13.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	1,496				
9.75	0.017	13.00	0.009	13.00	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	1,830				
9.75	0.008	13.00	0.006	13.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	554				
9.75	0	13.00	0.004	13.00	South Flue Gas Duct - El 95	95	W	6	1,600	9,600	4.5120	106				
9.75	0	13.00	0	13.00	Pipe Insulation Containment - El. 24	24	W	0	1,600	0	0.0000	0				
9.75	0.004	13.00	0.003	13.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,039				
9.75	0.166	13.00	0.046	13.00	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	4,663				
Time Period											0	0.0000	0			
Totals											188,400	88.5480	14,158	0.0137	760,123	0.2168
13.00	0.012	13.01	0.012	13.01	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	2				
13.00	0.016	13.01	0.016	13.01	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6				
13.00	0.017	13.01	0.017	13.01	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4				
13.00	0.004	13.01	0.004	13.01	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2				
13.00	0.009	13.01	0.009	13.01	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	4				
13.00	0.006	13.01	0.006	13.01	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1				
13.00	0.004	13.01	0.004	13.01	South Flue Gas Duct - El 95	95	W	6	1,600	9,600	4.5120	1				
13.00	0	13.01	0	13.01	Pipe Insulation Containment - El. 24	24	W	0	1,600	0	0.0000	0				
13.00	0.003	13.01	0.003	13.01	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3				
13.00	0.046	13.01	0.046	13.01	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	6				
Time Period											0	0.0000	0			
Totals											188,400	88.5480	29	0.0091	760,094	0.2170
13.01	0.012	23.99	0.012	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	2,140				
13.01	0.016	23.99	0.016	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,183				
13.01	0.017	23.99	0.017	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,548				
13.01	0.004	23.99	0.004	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,378				
13.01	0.009	23.99	0.009	23.99	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	16	1,600	25,600	12.0320	4,280				
13.01	0.006	23.99	0.006	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,605				
13.01	0.004	23.99	0.004	23.99	South Flue Gas Duct - El 95	95	W	6	1,600	9,600	4.5120	713				
13.01	0	23.99	0	23.99	Pipe Insulation Containment - El. 24	24	W	0	1,600	0	0.0000	0				
13.01	0.003	23.99	0.003	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,010				
13.01	0.046	23.99	0.046	23.99	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	6,837				
Time Period											0	0.0000	0			
Totals											188,400	88.5480	31,694	0.0091	728,400	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0098			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-27-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION										
0.00	0.008	6.50	0.008	6.50	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	845					
0.00	0.011	6.50	0.011	6.50	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	2,516					
0.00	0.012	6.50	0.012	6.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,900					
0.00	0.007	6.50	0.007	6.50	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	2,464					
0.00	0.008	6.50	0.008	6.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	3,097					
0.00	0	6.50	0	6.50	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	0					
0.00	0	6.50	0	6.50	South Flue Gas Duct - El 95	95 W	W	16	1,600	25,600	12.0320	0					
0.00	0	6.50	0	6.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0					
0.00	0.025	6.50	0.025	6.50	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	2,200					
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												214,000	100.5800	13,022	0.0055	899,440	0.1419
6.50	0.008	9.75	0.058	9.75	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	1,742					
6.50	0.011	9.75	0.11	9.75	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	6,920					
6.50	0.012	9.75	0.085	9.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,841					
6.50	0.007	9.75	0.11	9.75	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	10,294					
6.50	0.008	9.75	0.03	9.75	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	3,678					
6.50	0	9.75	0.009	9.75	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	356					
6.50	0	9.75	0	9.75	South Flue Gas Duct - El 95	95 W	W	16	1,600	25,600	12.0320	0					
6.50	0	9.75	0.004	9.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	594					
6.50	0.025	9.75	0.187	9.75	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	4,663					
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												214,000	100.5800	32,088	0.0273	867,352	0.1681
9.75	0.058	13.75	0.128	13.75	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	4,418					
9.75	0.11	13.75	0.128	13.75	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	16,752					
9.75	0.085	13.75	0.11	13.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	9,502					
9.75	0.11	13.75	0.115	13.75	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	24,365					
9.75	0.03	13.75	0.038	13.75	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	8,100					
9.75	0.009	13.75	0.014	13.75	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	1,121					
9.75	0	13.75	0	13.75	South Flue Gas Duct - El 95	95 W	W	16	1,600	25,600	12.0320	0					
9.75	0.004	13.75	0.005	13.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,645					
9.75	0.187	13.75	0.185	13.75	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	10,071					
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												214,000	100.5800	75,974	0.0525	791,379	0.2132
13.75	0.078	16.00	0.04	16.00	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	2,156					
13.75	0.128	16.00	0.052	16.00	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	7,127					
13.75	0.11	16.00	0.051	16.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,413					
13.75	0.115	16.00	0.058	16.00	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	10,538					
13.75	0.038	16.00	0.038	16.00	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	5,092					
13.75	0.014	16.00	0.006	16.00	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	548					
13.75	0	16.00	0.004	16.00	South Flue Gas Duct - El 95	95 W	W	16	1,600	25,600	12.0320	195					
13.75	0.005	16.00	0.007	16.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,233					
13.75	0.185	16.00	0.094	16.00	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	4,249					
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												214,000	100.5800	35,551	0.0436	755,828	0.2609
16.00	0.04	23.99	0.04	23.99	Boiler #1& #2 - El. 89 to El. 59	59 SW	W	6	1,600	9,600	4.5120	5,191					
16.00	0.052	23.99	0.052	23.99	Boiler #1& #2 - El. 89 to El. 59	59 W	W	13	1,600	20,800	9.7760	14,622					
16.00	0.051	23.99	0.051	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	9,928					
16.00	0.058	23.99	0.058	23.99	Boiler #1& #2 - El. 89 to El. 59	82 E	E	20	1,600	32,000	15.0400	25,091					
16.00	0.038	23.99	0.038	23.99	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	18,083					
16.00	0.006	23.99	0.006	23.99	Coal Bunker Containment	59 N	N	9	1,600	14,400	6.7680	1,168					
16.00	0.004	23.99	0.004	23.99	South Flue Gas Duct - El 95	95 W	W	16	1,600	25,600	12.0320	1,384					
16.00	0.007	23.99	0.007	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	5,110					
16.00	0.094	23.99	0.094	23.99	Turbine #1 - El. 36	36	E	5	1,600	8,000	3.7600	10,166					
												0	0.0000	0			
												0	0.0000	0			
Time Period Totals												214,000	100.5800	90,745	0.0314	665,082	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0285				
24 HR. COMPLIANCE STANDARD													0.105				
													IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-28-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.011	6.75	0.011	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,206				
0.00	0.01	6.75	0.01	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,376				
0.00	0.009	6.75	0.009	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,480				
0.00	0.016	6.75	0.016	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	5,848				
0.00	0.01	6.75	0.01	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	4,020				
0.00	0	6.75	0	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0				
0.00	0	6.75	0	South Flue Gas Duct - El 95	95	W	16	1,600	25,600	12.0320	0				
0.00	0	6.75	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.044	6.75	0.044	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	4,020				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										214,000	100.5800	18,950	0.0078	893,512	0.1431
6.75	0.011	10.50	0.09	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	3,076				
6.75	0.01	10.50	0.169	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	11,812				
6.75	0.009	10.50	0.141	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	6,853				
6.75	0.016	10.50	0.157	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	17,563				
6.75	0.01	10.50	0.047	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	6,365				
6.75	0	10.50	0.008	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	365				
6.75	0	10.50	0	South Flue Gas Duct - El 95	95	W	16	1,600	25,600	12.0320	0				
6.75	0	10.50	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	514				
6.75	0.044	10.50	0.035	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,005				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										214,000	100.5800	48,553	0.0358	844,959	0.1729
10.50	0.09	14.00	0.125	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	6,112				
10.50	0.169	14.00	0.214	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	23,589				
10.50	0.141	14.00	0.186	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	13,943				
10.50	0.157	14.00	0.165	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	30,510				
10.50	0.047	14.00	0.043	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	9,380				
10.50	0.008	14.00	0.011	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	810				
10.50	0	14.00	0	South Flue Gas Duct - El 95	95	W	16	1,600	25,600	12.0320	0				
10.50	0.003	14.00	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	480				
10.50	0.035	14.00	0.033	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,611				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										188,400	88.5480	86,434	0.0775	649,371	0.2037
14.00	0.125	17.50	0.148	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	7,760				
14.00	0.214	17.50	0.165	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	23,342				
14.00	0.186	17.50	0.187	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	15,904				
14.00	0.165	17.50	0.193	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	33,921				
14.00	0.043	17.50	0.042	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	8,859				
14.00	0.011	17.50	0.007	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	767				
14.00	0	17.50	0	South Flue Gas Duct - El 95	95	W	16	1,600	25,600	12.0320	0				
14.00	0	17.50	0.008	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,279				
14.00	0.033	17.50	0.032	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,540				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										188,400	88.5480	93,373	0.0837	555,997	0.2683
17.50	0.148	23.99	0.148	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	15,602				
17.50	0.165	23.99	0.165	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	37,687				
17.50	0.187	23.99	0.187	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	29,570				
17.50	0.193	23.99	0.193	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	67,819				
17.50	0.042	23.99	0.042	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	16,234				
17.50	0.007	23.99	0.007	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,107				
17.50	0	23.99	0	South Flue Gas Duct - El 95	95	W	16	1,600	25,600	12.0320	0				
17.50	0.008	23.99	0.008	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,744				
17.50	0.032	23.99	0.032	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,811				
									0	0.0000	0				
									0	0.0000	0				
Time Period															
Totals										188,400	88.5480	175,574	0.0849	380,423	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0553			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-29-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.016	6.50	0.016	6.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,689				
0.00	0.016	6.50	0.016	6.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,660				
0.00	0.017	6.50	0.017	6.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,692				
0.00	0.012	6.50	0.012	6.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,223				
0.00	0.013	6.50	0.013	6.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	5,033				
0.00	0	6.50	0	6.50	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
0.00	0	6.50	0	6.50	South Flue Gas Duct - El.95	95	W	16	1,600	25,600	12.0320	0				
0.00	0	6.50	0	6.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.032	6.50	0.032	6.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,815				
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											199,600	93.8120	20,113	0.0092	830,949	0.1406
6.50	0.016	10.50	0.027	10.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,397				
6.50	0.016	10.50	0.042	10.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,082				
6.50	0.017	10.50	0.048	10.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,167				
6.50	0.012	10.50	0.034	10.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,981				
6.50	0.013	10.50	0.033	10.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	5,479				
6.50	0	10.50	0	10.50	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
6.50	0	10.50	0	10.50	South Flue Gas Duct - El.95	95	W	16	1,600	25,600	12.0320	0				
6.50	0	10.50	0	10.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
6.50	0.032	10.50	0.036	10.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,841				
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											199,600	93.8120	20,948	0.0155	810,001	0.1777
10.50	0.027	14.00	0.02	14.00	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,336				
10.50	0.042	14.00	0.025	14.00	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	4,126				
10.50	0.048	14.00	0.025	14.00	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,113				
10.50	0.034	14.00	0.025	14.00	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	5,590				
10.50	0.033	14.00	0.035	14.00	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	7,087				
10.50	0	14.00	0.003	14.00	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	128				
10.50	0	14.00	0	14.00	South Flue Gas Duct - El.95	95	W	0	1,600	0	0.0000	0				
10.50	0	14.00	0.003	14.00	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	480				
10.50	0.036	14.00	0.048	14.00	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,990				
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											188,400	88.5480	23,850	0.0214	738,396	0.2316
14.00	0.02	17.50	0.046	17.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,876				
14.00	0.025	17.50	0.059	17.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	5,173				
14.00	0.025	17.50	0.074	17.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,221				
14.00	0.025	17.50	0.077	17.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	9,665				
14.00	0.035	17.50	0.046	17.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	8,442				
14.00	0.003	17.50	0.009	17.50	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	512				
14.00	0	17.50	0	17.50	South Flue Gas Duct - El.95	95	W	0	1,600	0	0.0000	0				
14.00	0.003	17.50	0.005	17.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,279				
14.00	0.048	17.50	0.046	17.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,227				
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											188,400	88.5480	33,395	0.0299	705,000	0.3402
17.50	0.046	23.99	0.046	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	4,849				
17.50	0.059	23.99	0.059	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	13,476				
17.50	0.074	23.99	0.074	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	11,701				
17.50	0.077	23.99	0.077	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	27,057				
17.50	0.046	23.99	0.046	23.99	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	17,781				
17.50	0.009	23.99	0.009	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,423				
17.50	0	23.99	0	23.99	South Flue Gas Duct - El.95	95	W	0	1,600	0	0.0000	0				
17.50	0.005	23.99	0.005	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,965				
17.50	0.046	23.99	0.046	23.99	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	4,041				
											0	0.0000	0			
											0	0.0000	0			
Time Period Totals											188,400	88.5480	83,294	0.0403	621,707	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0237			
24 HR. COMPLIANCE STANDARD													0.105			
													IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-30-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.017	6.50	0.017	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,795					
0.00	0.017	6.50	0.017	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,889					
0.00	0.022	6.50	0.022	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	3,484					
0.00	0.014	6.50	0.014	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,927					
0.00	0.021	6.50	0.021	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	8,130					
0.00	0.005	6.50	0.005	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0					
0.00	0	6.50	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0					
0.00	0.033	6.50	0.033	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,903					
									0	0.0000	0					
									0	0.0000	0					
									0	0.0000	0					
									0	0.0000	0					
Time Period																
Totals											174,000	81.7800	25,128	0.0131	716,780	0.1391
6.50	0.017	10.50	0.017	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,105					
6.50	0.017	10.50	0.018	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,464					
6.50	0.022	10.50	0.016	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,852					
6.50	0.014	10.50	0.016	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	3,249					
6.50	0.021	10.50	0.044	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	7,743					
6.50	0.005	10.50	0.006	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0					
6.50	0	10.50	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	914					
6.50	0.033	10.50	0.054	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,355					
									0	0.0000	0					
									0	0.0000	0					
									0	0.0000	0					
Time Period																
Totals											174,000	81.7800	19,680	0.0167	697,100	0.1754
10.50	0.017	14.25	0.017	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,036					
10.50	0.018	14.25	0.017	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,310					
10.50	0.016	14.25	0.021	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,690					
10.50	0.016	14.25	0.014	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	3,046					
10.50	0.044	14.25	0.034	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	8,710					
10.50	0.006	14.25	0.01	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	731					
10.50	0.005	14.25	0.009	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,398					
10.50	0.054	14.25	0.054	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,741					
									0	0.0000	0					
									0	0.0000	0					
									0	0.0000	0					
Time Period																
Totals											188,400	88.5480	22,662	0.0190	735,837	0.2368
14.25	0.017	17.25	0.015	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	780					
14.25	0.017	17.25	0.015	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	1,689					
14.25	0.021	17.25	0.013	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,243					
14.25	0.014	17.25	0.012	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	2,112					
14.25	0.034	17.25	0.03	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	5,718					
14.25	0.01	17.25	0.004	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	512					
14.25	0.009	17.25	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,233					
14.25	0.054	17.25	0.022	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,543					
									0	0.0000	0					
									0	0.0000	0					
									0	0.0000	0					
Time Period																
Totals											188,400	88.5480	14,829	0.0155	721,008	0.3351
17.25	0.015	23.99	0.015	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,642					
17.25	0.015	23.99	0.015	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	3,558					
17.25	0.013	23.99	0.013	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	2,135					
17.25	0.012	23.99	0.012	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	4,379					
17.25	0.03	23.99	0.03	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	12,043					
17.25	0.004	23.99	0.004	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	657					
17.25	0	23.99	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0					
17.25	0.022	23.99	0.022	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,007					
									0	0.0000	0					
									0	0.0000	0					
									0	0.0000	0					
Time Period																
Totals											188,400	88.5480	26,421	0.0123	694,587	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0142				
24 HR. COMPLIANCE STANDARD												0.105				
												IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS, 24 HOUR MERCURY DISCHARGE COMPLIANCE - 03-30-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.012	6.75	0.012	6.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	1,316			
0.00	0.011	6.75	0.011	6.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	2,613			
0.00	0.012	6.75	0.012	6.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	1,974			
0.00	0.01	6.75	0.01	6.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	3,655			
0.00	0.024	6.75	0.024	6.75	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	9,648			
0.00	0.008	6.75	0.008	6.75	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0			
0.00	0	6.75	0	6.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0			
0.00	0.022	6.75	0.022	6.75	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,010			
0.00	0.014	6.75	0.014	6.75	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,023			
0.00	0.043	6.75	0.043	6.75	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	1,572			
0.00	0.009	6.75	0.009	6.75	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	987			
Time Period Totals										193,200	90.8040	24,797	0.0112	798,977	0.1417
6.75	0.012	9.50	0.012	9.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	3,663			
6.75	0.011	9.50	0.011	9.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	8,130			
6.75	0.012	9.50	0.012	9.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,662			
6.75	0.01	9.50	0.01	9.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	12,284			
6.75	0.024	9.50	0.024	9.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	5,241			
6.75	0.008	9.50	0.008	9.50	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0			
6.75	0	9.50	0	9.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	628			
6.75	0.022	9.50	0.022	9.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	2,140			
6.75	0.014	9.50	0.014	9.50	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	581			
6.75	0.043	9.50	0.043	9.50	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	692			
6.75	0.009	9.50	0.009	9.50	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	581			
Time Period Totals										193,200	90.8040	39,602	0.0441	759,375	0.1602
9.50	0.152	11.75	0.152	11.75	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	3,454			
9.50	0.157	11.75	0.157	11.75	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	7,523			
9.50	0.157	11.75	0.157	11.75	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	5,235			
9.50	0.155	11.75	0.155	11.75	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	11,634			
9.50	0.04	11.75	0.04	11.75	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	4,757			
9.50	0.019	11.75	0.019	11.75	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0			
9.50	0.005	11.75	0.005	11.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	925			
9.50	0.093	11.75	0.093	11.75	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,964			
9.50	0.025	11.75	0.025	11.75	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	426			
9.50	0.05	11.75	0.05	11.75	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	707			
9.50	0.017	11.75	0.017	11.75	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	585			
Time Period Totals										207,600	97.5720	37,950	0.0480	782,824	0.1819
11.75	0.037	13.50	0.037	13.50	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	3,368			
11.75	0.033	13.50	0.033	13.50	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	6,775			
11.75	0.034	13.50	0.034	13.50	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	4,797			
11.75	0.036	13.50	0.036	13.50	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	17,671			
11.75	0.031	13.50	0.031	13.50	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	3,856			
11.75	0.008	13.50	0.008	13.50	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0			
11.75	0.004	13.50	0.004	13.50	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	720			
11.75	0.036	13.50	0.036	13.50	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	971			
11.75	0.01	13.50	0.01	13.50	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	540			
11.75	0.066	13.50	0.066	13.50	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	749			
11.75	0.015	13.50	0.015	13.50	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	625			
Time Period Totals										207,600	97.5720	40,328	0.0656	742,496	0.2013
13.50	0.2	23.99	0.2	23.99	Boiler #1& #2 - El. 89 to El. 59	59	SW	6	1,600	9,600	4.5120	34,078			
13.50	0.187	23.99	0.187	23.99	Boiler #1& #2 - El. 89 to El. 59	59	W	13	1,600	20,800	9.7760	69,037			
13.50	0.191	23.99	0.191	23.99	Boiler #1& #2 - El. 89 to El. 59	Mezzanine	W	9	1,600	14,400	6.7680	48,817			
13.50	0.337	23.99	0.337	23.99	Boiler #1& #2 - El. 89 to El. 59	82	E	20	1,600	32,000	15.0400	191,406			
13.50	0.043	23.99	0.043	23.99	Boiler #1& #2 - El. 49 to El. 36	49 & 36	N	22	1,600	35,200	16.5440	26,865			
13.50	0.004	23.99	0.004	23.99	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0			
13.50	0.005	23.99	0.005	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,792			
13.50	0.046	23.99	0.046	23.99	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	6,532			
13.50	0.047	23.99	0.047	23.99	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5,339			
13.50	0.092	23.99	0.092	23.99	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	5,275			
13.50	0.029	23.99	0.029	23.99	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	4,941			
Time Period Totals										207,600	97.5720	398,055	0.1080	344,440	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0641		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-03-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.012	6.75	0.012	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	1,316					
0.00	0.011	6.75	0.011	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	2,613					
0.00	0.016	6.75	0.016	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	2,631					
0.00	0.01	6.75	0.01	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	3,655					
0.00	0.012	6.75	0.012	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	4,824					
0.00	0.003	6.75	0.003	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	493					
0.00	0.003	6.75	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,850					
0.00	0.018	6.75	0.018	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,645					
0.00	0.008	6.75	0.008	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	585					
0.00	0.023	6.75	0.023	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	841					
0.00	0.004	6.75	0.004	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	439					
									0	0.0000	0					
Time Period Totals										207,600	97.5720	20,891	0.0088	864,282	0.1426	
6.75	0.012	9.50	0.138	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	3,350					
6.75	0.011	9.50	0.187	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	9,581					
6.75	0.016	9.50	0.168	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	5,164					
6.75	0.01	9.50	0.164	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	12,954					
6.75	0.012	9.50	0.064	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	6,224					
6.75	0.003	9.50	0.034	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,240					
6.75	0.003	9.50	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,005					
6.75	0.018	9.50	0.019	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	551					
6.75	0.008	9.50	0.056	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	953					
6.75	0.023	9.50	0.075	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	730					
6.75	0.004	9.50	0.028	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	715					
6.75	0	9.50	0.11	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	1,638					
Time Period Totals										212,400	99.8280	45,104	0.0456	839,644	0.1611	
9.50	0.138	13.75	0.332	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	16,223					
9.50	0.187	13.75	0.305	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	36,795					
9.50	0.168	13.75	0.407	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	29,771					
9.50	0.164	13.75	0.21	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	43,031					
9.50	0.064	13.75	0.065	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	16,326					
9.50	0.034	13.75	0.052	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	4,453					
9.50	0.005	13.75	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,942					
9.50	0.019	13.75	0.017	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	828					
9.50	0.056	13.75	0.028	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,933					
9.50	0.075	13.75	0.111	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,140					
9.50	0.028	13.75	0.023	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,760					
9.50	0.11	13.75	0.231	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	7,847					
Time Period Totals										212,400	99.8280	163,049	0.1068	676,595	0.1837	
13.75	0.332	15.75	0.128	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	7,472					
13.75	0.305	15.75	0.13	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	15,309					
13.75	0.407	15.75	0.098	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	12,304					
13.75	0.21	15.75	0.119	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	17,813					
13.75	0.065	15.75	0.083	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	8,815					
13.75	0.052	15.75	0.024	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,852					
13.75	0.005	15.75	0.004	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	822					
13.75	0.017	15.75	0.017	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	368					
13.75	0.028	15.75	0.016	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	476					
13.75	0.111	15.75	0.045	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	845					
13.75	0.023	15.75	0.022	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	731					
13.75	0.231	15.75	0.011	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	2,621					
Time Period Totals										212,400	99.8280	69,428	0.0966	607,167	0.2048	
15.75	0.128	23.99	0.128	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	17,132					
15.75	0.13	23.99	0.13	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	37,699					
15.75	0.098	23.99	0.098	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	19,675					
15.75	0.119	23.99	0.119	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	53,091					
15.75	0.083	23.99	0.083	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	40,733					
15.75	0.024	23.99	0.024	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	4,818					
15.75	0.004	23.99	0.004	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,011					
15.75	0.017	23.99	0.017	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,517					
15.75	0.016	23.99	0.016	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,428					
15.75	0.045	23.99	0.045	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,008					
15.75	0.022	23.99	0.022	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,945					
15.75	0.011	23.99	0.011	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	982					
Time Period Totals										212,400	99.8280	185,039	0.0625	422,128		
24 HR. ACTUAL COMPLIANCE TOTAL												0.0561				
24 HR. COMPLIANCE STANDARD												0.105				
												IN COMPLIANCE				

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-04-2017

TIME START	CONC. START	TIME END	CONC. END	CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE	TOTAL FLOWRATE	EMISSIONS (MG)	AVG. CONC.	BAL.	AVG. CONC.				
	(MG/M ³)		(MG/M ³)		FLOOR ELEV.	LOCATION			(CFM)	(M ³ /SEC)		(MG/M ³)	EMISSIONS (MG)	(MG/M ³)				
0.00	0.031	7.00	0.031	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	3,525							
0.00	0.053	7.00	0.053	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	13,057							
0.00	0.043	7.00	0.043	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	7,334							
0.00	0.028	7.00	0.028	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	10,612							
0.00	0.028	7.00	0.028	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	11,673							
0.00	0.029	7.00	0.029	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	4,946							
0.00	0.004	7.00	0.004	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,558							
0.00	0.02	7.00	0.02	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,895							
0.00	0.056	7.00	0.056	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	4,245							
0.00	0.095	7.00	0.095	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	3,601							
0.00	0.025	7.00	0.025	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,843							
0.00	0.277	7.00	0.277	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	20,997							
Time Period Totals											214,000	100,5800	87,285	0.0344	825,176	0.1341		
7.00	0.031	10.25	0.094	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	3,299							
7.00	0.053	10.25	0.139	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	10,980							
7.00	0.043	10.25	0.138	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	7,166							
7.00	0.028	10.25	0.114	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	12,494							
7.00	0.028	10.25	0.041	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	6,678							
7.00	0.029	10.25	0.029	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,296							
7.00	0.004	10.25	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	594							
7.00	0.02	10.25	0.022	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	739							
7.00	0.056	10.25	0.152	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	3,836							
7.00	0.095	10.25	0.189	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,499							
7.00	0.025	10.25	0.039	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,689							
7.00	0.277	10.25	0.078	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	6,247							
Time Period Totals											212,400	99,8280	58,518	0.0501	759,836	0.1538		
10.25	0.094	14.00	0.115	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	6,365							
10.25	0.139	14.00	0.136	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	18,147							
10.25	0.138	14.00	0.13	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	12,243							
10.25	0.114	14.00	0.132	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	24,974							
10.25	0.041	14.00	0.076	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	13,065							
10.25	0.029	14.00	0.017	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,101							
10.25	0	14.00	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	534							
10.25	0.022	14.00	0.021	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	873							
10.25	0.162	14.00	0.225	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	7,858							
10.25	0.189	14.00	0.119	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	3,127							
10.25	0.039	14.00	0.034	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,223							
10.25	0.078	14.00	0.007	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	1,726							
Time Period Totals											212,400	99,8280	93,217	0.0692	666,619	0.1855		
14.00	0.115	17.50	0.113	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	6,481							
14.00	0.136	17.50	0.108	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	15,028							
14.00	0.13	17.50	0.127	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	10,958							
14.00	0.132	17.50	0.093	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	21,319							
14.00	0.076	17.50	0.072	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	15,426							
14.00	0.017	17.50	0.017	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,450							
14.00	0.003	17.50	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	480							
14.00	0.021	17.50	0.019	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	758							
14.00	0.225	17.50	0.072	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5,628							
14.00	0.119	17.50	0.14	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,454							
14.00	0.034	17.50	0.038	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,047							
14.00	0.007	17.50	0.048	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	1,042							
Time Period Totals											212,400	99,8280	83,070	0.0660	583,549	0.2498		
17.50	0.113	23.99	0.113	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	11,912							
17.50	0.108	23.99	0.108	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	24,668							
17.50	0.127	23.99	0.127	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	20,082							
17.50	0.093	23.99	0.093	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	32,680							
17.50	0.072	23.99	0.072	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	27,830							
17.50	0.017	23.99	0.017	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,688							
17.50	0	23.99	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0							
17.50	0.019	23.99	0.019	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,335							
17.50	0.072	23.99	0.072	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5,060							
17.50	0.14	23.99	0.14	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	4,920							
17.50	0.038	23.99	0.038	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	4,006							
17.50	0.048	23.99	0.048	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	3,373							
Time Period Totals											212,400	99,8280	138,555	0.0594	444,994			
24 HR. ACTUAL COMPLIANCE TOTAL															0.0534			
24 HR. COMPLIANCE STANDARD																		0.105
															IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-05-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.016	7.00	0.016	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	1,819					
0.00	0.011	7.00	0.011	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	2,710					
0.00	0.011	7.00	0.011	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	1,876					
0.00	0.014	7.00	0.014	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	5,306					
0.00	0.02	7.00	0.02	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	8,338					
0.00	0.004	7.00	0.004	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	682					
0.00	0	7.00	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0					
0.00	0.018	7.00	0.018	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,706					
0.00	0.058	7.00	0.058	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	4,396					
0.00	0.078	7.00	0.078	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,956					
0.00	0.02	7.00	0.02	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,274					
0.00	0.047	7.00	0.047	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	3,563					
Time Period Totals											214,000	100.5800	35,627	0.0141	876,835	0.1424
7.00	0.016	10.00	0.022	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	926					
7.00	0.011	10.00	0.033	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	2,323					
7.00	0.011	10.00	0.038	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	1,791					
7.00	0.014	10.00	0.032	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	3,736					
7.00	0.02	10.00	0.07	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	8,040					
7.00	0.004	10.00	0.043	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,718					
7.00	0	10.00	0.013	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,782					
7.00	0.018	10.00	0.034	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	845					
7.00	0.058	10.00	0.123	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	2,940					
7.00	0.078	10.00	0.149	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	1,844					
7.00	0.02	10.00	0.05	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,706					
7.00	0.047	10.00	0.004	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	828					
Time Period Totals											212,400	99.8280	28,477	0.0264	841,535	0.1673
10.00	0.022	14.75	0.052	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	2,855					
10.00	0.033	14.75	0.058	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	7,606					
10.00	0.038	14.75	0.049	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	5,034					
10.00	0.032	14.75	0.115	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	18,903					
10.00	0.07	14.75	0.053	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	17,398					
10.00	0.043	14.75	0.006	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,835					
10.00	0.013	14.75	0.011	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	5,208					
10.00	0.034	14.75	0.021	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,415					
10.00	0.123	14.75	0.089	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5,452					
10.00	0.149	14.75	0.118	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	3,433					
10.00	0.05	14.75	0.03	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	3,086					
10.00	0.004	14.75	0.021	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	643					
Time Period Totals											212,400	99.8280	73,870	0.0433	767,666	0.2309
14.75	0.052	17.50	0.07	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	2,725					
14.75	0.058	17.50	0.061	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	5,759					
14.75	0.049	17.50	0.096	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	4,858					
14.75	0.115	17.50	0.093	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	15,485					
14.75	0.053	17.50	0.054	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	8,763					
14.75	0.006	17.50	0.008	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	469					
14.75	0.011	17.50	0.003	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,759					
14.75	0.021	17.50	0.017	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	566					
14.75	0.089	17.50	0.021	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,638					
14.75	0.118	17.50	0.052	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	1,266					
14.75	0.03	17.50	0.02	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,117					
14.75	0.021	17.50	0.05	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	1,057					
Time Period Totals											212,400	99.8280	45,460	0.0460	722,206	0.3092
17.50	0.07	23.99	0.07	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	7,379					
17.50	0.061	23.99	0.061	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	13,933					
17.50	0.096	23.99	0.096	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	15,180					
17.50	0.093	23.99	0.093	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	32,680					
17.50	0.054	23.99	0.054	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	20,873					
17.50	0.008	23.99	0.008	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,265					
17.50	0.003	23.99	0.003	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,779					
17.50	0.017	23.99	0.017	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,195					
17.50	0.021	23.99	0.021	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,476					
17.50	0.052	23.99	0.052	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	1,827					
17.50	0.02	23.99	0.02	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,108					
17.50	0.05	23.99	0.05	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	3,514					
Time Period Totals											212,400	99.8280	103,209	0.0443	618,997	
24 HR. ACTUAL COMPLIANCE TOTAL														0.0332		
24 HR. COMPLIANCE STANDARD														0.105		
														IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-06-2017

CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
TIME START	(MG/M ³)	TIME END	(MG/M ³)		FLOOR ELEV.	LOCATION									
0.00	0.047	7.00	0.047	Boiler #1& #2 - El. 89 to El. 55	59 SW		6	1,600	9,600	4.5120	5,344				
0.00	0.077	7.00	0.077	Boiler #1& #2 - El. 89 to El. 55	59 W		13	1,600	20,800	9.7760	18,969				
0.00	0.044	7.00	0.044	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	7,504				
0.00	0.07	7.00	0.07	Boiler #1& #2 - El. 89 to El. 55	82 E		20	1,600	32,000	15.0400	26,531				
0.00	0.014	7.00	0.014	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	5,837				
0.00	0.009	7.00	0.009	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	1,535				
0.00	0	7.00	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.012	7.00	0.012	Turbine #1 - El. 36	36		5	1,600	8,000	3.7600	1,137				
0.00	0.036	7.00	0.036	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	2,729				
0.00	0.086	7.00	0.086	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	3,259				
0.00	0.019	7.00	0.019	Precipitator - El. 24	24 W		6	1,600	9,600	4.5120	2,160				
0.00	0.086	7.00	0.086	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	6,519				
Time Period Totals										214,000	100,5800	81,525	0.0322	830,937	0.1350
7.00	0.047	10.00	0.095	Boiler #1& #2 - El. 89 to El. 55	59 SW		6	1,600	9,600	4.5120	3,460				
7.00	0.077	10.00	0.088	Boiler #1& #2 - El. 89 to El. 55	59 W		13	1,600	20,800	9.7760	8,710				
7.00	0.044	10.00	0.108	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	5,555				
7.00	0.07	10.00	0.157	Boiler #1& #2 - El. 89 to El. 55	82 E		20	1,600	32,000	15.0400	18,436				
7.00	0.014	10.00	0.107	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	10,810				
7.00	0.009	10.00	0.014	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	841				
7.00	0	10.00	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	411				
7.00	0.012	10.00	0.019	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	504				
7.00	0.036	10.00	0.33	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5,945				
7.00	0.086	10.00	0.246	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,696				
7.00	0.019	10.00	0.063	Precipitator - El. 24	24 W		6	1,600	9,600	4.5120	1,998				
7.00	0.086	10.00	0.167	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	4,110				
Time Period Totals										212,400	99,8280	63,475	0.0589	760,640	0.1512
10.00	0.095	14.75	0.075	Boiler #1& #2 - El. 89 to El. 55	59 SW		6	1,600	9,600	4.5120	6,558				
10.00	0.088	14.75	0.067	Boiler #1& #2 - El. 89 to El. 55	59 W		13	1,600	20,800	9.7760	12,956				
10.00	0.108	14.75	0.091	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	11,515				
10.00	0.157	14.75	0.081	Boiler #1& #2 - El. 89 to El. 55	82 E		20	1,600	32,000	15.0400	30,605				
10.00	0.107	14.75	0.111	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	30,836				
10.00	0.014	14.75	0.015	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	1,678				
10.00	0.003	14.75	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,302				
10.00	0.019	14.75	0.022	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,054				
10.00	0.33	14.75	0.228	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	14,351				
10.00	0.246	14.75	0.185	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	5,542				
10.00	0.063	14.75	0.048	Precipitator - El. 24	24 W		6	1,600	9,600	4.5120	4,282				
10.00	0.167	14.75	0.242	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	10,519				
Time Period Totals										212,400	99,8280	131,199	0.0769	629,440	0.1893
14.75	0.075	17.50	0.034	Boiler #1& #2 - El. 89 to El. 55	59 SW		6	1,600	9,600	4.5120	2,434				
14.75	0.067	17.50	0.03	Boiler #1& #2 - El. 89 to El. 55	59 W		13	1,600	20,800	9.7760	4,694				
14.75	0.091	17.50	0.037	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	4,288				
14.75	0.081	17.50	0.033	Boiler #1& #2 - El. 89 to El. 55	82 E		20	1,600	32,000	15.0400	8,487				
14.75	0.111	17.50	0.083	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	15,887				
14.75	0.015	17.50	0.006	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	704				
14.75	0.003	17.50	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	754				
14.75	0.022	17.50	0.019	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	610				
14.75	0.228	17.50	0.053	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	4,184				
14.75	0.185	17.50	0.116	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,241				
14.75	0.048	17.50	0.057	Precipitator - El. 24	24 W		6	1,600	9,600	4.5120	2,345				
14.75	0.242	17.50	0.003	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	3,648				
Time Period Totals										212,400	99,8280	50,277	0.0509	579,164	0.2479
17.50	0.034	23.99	0.034	Boiler #1& #2 - El. 89 to El. 55	59 SW		6	1,600	9,600	4.5120	3,584				
17.50	0.03	23.99	0.03	Boiler #1& #2 - El. 89 to El. 55	59 W		13	1,600	20,800	9.7760	6,852				
17.50	0.037	23.99	0.037	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	5,851				
17.50	0.033	23.99	0.033	Boiler #1& #2 - El. 89 to El. 55	82 E		20	1,600	32,000	15.0400	11,596				
17.50	0.083	23.99	0.083	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	32,082				
17.50	0.006	23.99	0.006	Coal Bunker Containment	59 N		9	1,600	14,400	6.7680	949				
17.50	0.003	23.99	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,779				
17.50	0.019	23.99	0.019	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,335				
17.50	0.053	23.99	0.053	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	3,725				
17.50	0.116	23.99	0.116	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	4,076				
17.50	0.057	23.99	0.057	Precipitator - El. 24	24 W		6	1,600	9,600	4.5120	6,009				
17.50	0.003	23.99	0.003	Flue Gas Duct - El. 95	95		4	1,600	6,400	3.0080	211				
Time Period Totals										212,400	99,8280	78,049	0.0335	501,115	

24 HR. ACTUAL
COMPLIANCE
TOTAL
24 HR.
COMPLIANCE
STANDARD

0.0469

0.105
IN COMPLIANCE

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-07-2017

TIME START	CONC. START		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END		(MG/M ³)	FLOOR ELEV.									LOCATION
0.00	0.015	6.50	0.015 Boiler #1& #2 - El. 89 to El. 5E	59 SW		6	1,600	9,600	4.5120	1,584				
0.00	0.016	6.50	0.016 Boiler #1& #2 - El. 89 to El. 5E	59 W		13	1,600	20,800	9.7760	3,660				
0.00	0.015	6.50	0.015 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	2,376				
0.00	0.011	6.50	0.011 Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	3,871				
0.00	0.061	6.50	0.061 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	23,615				
0.00	0.003	6.50	0.003 Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	475				
0.00	0	6.50	0 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.022	6.50	0.022 Turbine #1 - El. 36		36	5	1,600	8,000	3.7600	1,936				
0.00	0.028	6.50	0.028 Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	1,971				
0.00	0.053	6.50	0.053 Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	1,865				
0.00	0.022	6.50	0.022 Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	2,323				
0.00	0.006	6.50	0.006 Flue Gas Duct - El. 95		95	4	1,600	6,400	3.0080	422				
Time Period Totals								214,000	100,5800	44,098	0.0187	868,364	0.1370	
6.50	0.015	9.00	0.1 Boiler #1& #2 - El. 89 to El. 5E	59 SW		6	1,600	9,600	4.5120	2,335				
6.50	0.016	9.00	0.102 Boiler #1& #2 - El. 89 to El. 5E	59 W		13	1,600	20,800	9.7760	5,191				
6.50	0.015	9.00	0.126 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	4,294				
6.50	0.011	9.00	0.263 Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	18,544				
6.50	0.061	9.00	0.08 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	10,497				
6.50	0.003	9.00	0.008 Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	335				
6.50	0	9.00	0.003 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	343				
6.50	0.022	9.00	0.023 Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	609				
6.50	0.028	9.00	0.128 Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	2,112				
6.50	0.053	9.00	0.148 Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	1,360				
6.50	0.022	9.00	0.038 Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	1,218				
6.50	0.006	9.00	0.02 Flue Gas Duct - El. 95		95	4	1,600	6,400	3.0080	352				
Time Period Totals								212,400	99,8280	47,191	0.0525	814,351	0.1511	
9.00	0.1	12.50	0.021 Boiler #1& #2 - El. 89 to El. 5E	59 SW		6	1,600	9,600	4.5120	3,439				
9.00	0.102	12.50	0.021 Boiler #1& #2 - El. 89 to El. 5E	59 W		13	1,600	20,800	9.7760	7,575				
9.00	0.126	12.50	0.017 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	6,097				
9.00	0.263	12.50	0.015 Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	26,341				
9.00	0.08	12.50	0.077 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	16,364				
9.00	0.008	12.50	0.006 Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	597				
9.00	0.003	12.50	0.003 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	959				
9.00	0.023	12.50	0.022 Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	853				
9.00	0.128	12.50	0.092 Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	4,169				
9.00	0.148	12.50	0.106 Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	2,407				
9.00	0.038	12.50	0.032 Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	1,990				
9.00	0.02	12.50	0.004 Flue Gas Duct - El. 95		95	4	1,600	6,400	3.0080	455				
Time Period Totals								212,400	99,8280	71,246	0.0566	743,105	0.1798	
12.50	0.021	14.00	0.088 Boiler #1& #2 - El. 89 to El. 5E	59 SW		6	1,600	9,600	4.5120	1,328				
12.50	0.021	14.00	0.083 Boiler #1& #2 - El. 89 to El. 5E	59 W		13	1,600	20,800	9.7760	2,745				
12.50	0.017	14.00	0.073 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	1,645				
12.50	0.015	14.00	0.072 Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	3,533				
12.50	0.077	14.00	0.055 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	5,896				
12.50	0.006	14.00	0.009 Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	274				
12.50	0.003	14.00	0.005 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	548				
12.50	0.022	14.00	0.023 Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	365				
12.50	0.092	14.00	0.166 Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	2,095				
12.50	0.106	14.00	0.187 Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	1,190				
12.50	0.032	14.00	0.038 Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	853				
12.50	0.004	14.00	0.008 Flue Gas Duct - El. 95		95	4	1,600	6,400	3.0080	97				
Time Period Totals								212,400	99,8280	20,570	0.0382	722,535	0.2010	
14.00	0.088	23.99	0.088 Boiler #1& #2 - El. 89 to El. 5E	59 SW		6	1,600	9,600	4.5120	14,280				
14.00	0.083	23.99	0.083 Boiler #1& #2 - El. 89 to El. 5E	59 W		13	1,600	20,800	9.7760	29,181				
14.00	0.073	23.99	0.073 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	17,769				
14.00	0.072	23.99	0.072 Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	38,945				
14.00	0.055	23.99	0.055 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	32,724				
14.00	0.009	23.99	0.009 Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	2,191				
14.00	0.005	23.99	0.005 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,564				
14.00	0.023	23.99	0.023 Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	2,488				
14.00	0.166	23.99	0.166 Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	17,958				
14.00	0.187	23.99	0.187 Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	10,115				
14.00	0.038	23.99	0.038 Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	6,166				
14.00	0.008	23.99	0.008 Flue Gas Duct - El. 95		95	4	1,600	6,400	3.0080	865				
Time Period Totals								212,400	99,8280	177,246	0.0494	545,289		
24 HR. ACTUAL COMPLIANCE											0.0418			
TOTAL														
24 HR. COMPLIANCE STANDARD											0.105			
											IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-10-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.014	6.50	0.014	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	1,478				
0.00	0.012	6.50	0.012	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	2,745				
0.00	0.011	6.50	0.011	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	1,742				
0.00	0.012	6.50	0.012	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	4,223				
0.00	0.013	6.50	0.013	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	5,033				
0.00	0.003	6.50	0.003	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	475				
0.00	0	6.50	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.046	6.50	0.046	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,238				
0.00	0.025	6.50	0.025	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,760				
0.00	0.075	6.50	0.075	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,640				
0.00	0.021	6.50	0.021	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,217				
0.00	0.011	6.50	0.011	Pipe Insulation - El. 24	24		2	1,600	3,200	1.5040	387				
Time Period Totals										209,200	98.3240	25,938	0.0113	866,058	0.1398
6.50	0.014	9.75	0.101	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	3,035				
6.50	0.012	9.75	0.106	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	6,748				
6.50	0.011	9.75	0.098	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	4,316				
6.50	0.012	9.75	0.118	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	11,438				
6.50	0.013	9.75	0.067	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	7,743				
6.50	0.003	9.75	0.009	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	475				
6.50	0	9.75	0.005	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	742				
6.50	0.046	9.75	0.02	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,161				
6.50	0.025	9.75	0.123	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	2,604				
6.50	0.075	9.75	0.255	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,903				
6.50	0.021	9.75	0.024	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,188				
6.50	0.011	9.75	0.009	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	176				
Time Period Totals										209,200	98.3240	42,530	0.0370	823,527	0.1633
9.75	0.101	13.00	0.055	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	4,118				
9.75	0.106	13.00	0.048	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	8,807				
9.75	0.098	13.00	0.058	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	6,176				
9.75	0.118	13.00	0.071	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	16,629				
9.75	0.067	13.00	0.035	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	9,872				
9.75	0.009	13.00	0.011	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	792				
9.75	0.005	13.00	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,188				
9.75	0.02	13.00	0.021	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	721				
9.75	0.123	13.00	0.11	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	4,100				
9.75	0.255	13.00	0.077	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,921				
9.75	0.024	13.00	0.015	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,029				
9.75	0.009	13.00	0.009	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	158				
Time Period Totals										209,200	98.3240	56,512	0.0491	767,015	0.1970
13.00	0.055	15.50	0.08	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	2,741				
13.00	0.048	15.50	0.075	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	5,411				
13.00	0.058	15.50	0.06	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	3,594				
13.00	0.071	15.50	0.099	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	11,506				
13.00	0.035	15.50	0.055	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	6,700				
13.00	0.011	15.50	0.03	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,249				
13.00	0.003	15.50	0.009	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,371				
13.00	0.021	15.50	0.032	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	717				
13.00	0.11	15.50	0.048	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	2,139				
13.00	0.077	15.50	0.09	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	1,130				
13.00	0.015	15.50	0.024	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	792				
13.00	0.009	15.50	0.02	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	196				
Time Period Totals										209,200	98.3240	37,545	0.0424	729,470	0.2425
15.50	0.08	23.99	0.075	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	11,032				
15.50	0.075	23.99	0.075	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	22,410				
15.50	0.06	23.99	0.06	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	12,411				
15.50	0.099	23.99	0.099	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	45,509				
15.50	0.055	23.99	0.055	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	27,811				
15.50	0.03	23.99	0.03	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	6,205				
15.50	0.009	23.99	0.009	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	6,981				
15.50	0.032	23.99	0.032	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,942				
15.50	0.048	23.99	0.048	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	4,413				
15.50	0.09	23.99	0.09	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	4,137				
15.50	0.024	23.99	0.024	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	3,310				
15.50	0.02	23.99	0.02	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	919				
Time Period Totals										209,200	98.3240	148,081	0.0493	581,389	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0366			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-11-2017

TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION									
0.00	0.03	6.75	0.03	6.75	0.03 Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	3,289				
0.00	0.041	6.75	0.041	6.75	0.041 Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	9,740				
0.00	0.033	6.75	0.033	6.75	0.033 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	5,427				
0.00	0.044	6.75	0.044	6.75	0.044 Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	16,081				
0.00	0.033	6.75	0.033	6.75	0.033 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	13,267				
0.00	0	6.75	0	6.75	0 Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
0.00	0	6.75	0	6.75	0 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0				
0.00	0.017	6.75	0.017	6.75	0.017 Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,243				
0.00	0.037	6.75	0.037	6.75	0.037 Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	2,704				
0.00	0.06	6.75	0.06	6.75	0.06 Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	2,193				
0.00	0.009	6.75	0.009	6.75	0.009 Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	987				
0.00	0.006	6.75	0.006	6.75	0.006 Pipe Insulation - El. 24	24		2	1,600	3,200	1.5040	219				
Time Period Totals											194,800	91.5560	55,150	0.0248	775,446	0.1364
6.75	0.03	10.25	0.078	10.25	0.078 Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	3,070				
6.75	0.041	10.25	0.097	10.25	0.097 Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	8,499				
6.75	0.033	10.25	0.13	10.25	0.13 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	6,950				
6.75	0.044	10.25	0.137	10.25	0.137 Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	17,150				
6.75	0.033	10.25	0.051	10.25	0.051 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	9,797				
6.75	0	10.25	0	10.25	0 Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
6.75	0	10.25	0.005	10.25	0.005 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	799				
6.75	0.017	10.25	0.027	10.25	0.027 Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	834				
6.75	0.037	10.25	0.388	10.25	0.388 Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	8,054				
6.75	0.06	10.25	0.105	10.25	0.105 Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	1,563				
6.75	0.009	10.25	0.022	10.25	0.022 Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	881				
6.75	0.006	10.25	0.015	10.25	0.015 Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	199				
Time Period Totals											194,800	91.5560	57,798	0.0501	717,649	0.1584
10.25	0.078	14.00	0.085	14.00	0.085 Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	4,964				
10.25	0.097	14.00	0.111	14.00	0.111 Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	13,726				
10.25	0.13	14.00	0.099	14.00	0.099 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	10,462				
10.25	0.137	14.00	0.109	14.00	0.109 Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	24,974				
10.25	0.051	14.00	0.038	14.00	0.038 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	11,056				
10.25	0	14.00	0	14.00	0 Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
10.25	0.005	14.00	0.005	14.00	0.005 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,713				
10.25	0.027	14.00	0.032	14.00	0.032 Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,198				
10.25	0.388	14.00	0.145	14.00	0.145 Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	10,822				
10.25	0.105	14.00	0.842	14.00	0.842 Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	9,614				
10.25	0.022	14.00	0.031	14.00	0.031 Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,614				
10.25	0.015	14.00	0.009	14.00	0.009 Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	244				
Time Period Totals											194,800	91.5560	90,386	0.0731	627,263	0.1903
14.00	0.085	16.00	0.1	16.00	0.1 Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	3,005				
14.00	0.111	16.00	0.116	16.00	0.116 Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	7,989				
14.00	0.099	16.00	0.086	16.00	0.086 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	4,507				
14.00	0.109	16.00	0.113	16.00	0.113 Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	12,020				
14.00	0.038	16.00	0.058	16.00	0.058 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	5,718				
14.00	0	16.00	0	16.00	0 Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
14.00	0.005	16.00	0.02	16.00	0.02 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,284				
14.00	0.032	16.00	0.042	16.00	0.042 Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	801				
14.00	0.145	16.00	0.252	16.00	0.252 Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	4,299				
14.00	0.842	16.00	0.454	16.00	0.454 Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	7,017				
14.00	0.031	16.00	0.07	16.00	0.07 Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,641				
14.00	0.009	16.00	0.018	16.00	0.018 Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	146				
Time Period Totals											194,800	91.5560	49,427	0.0750	577,836	0.2191
16.00	0.1	23.99	0.1	23.99	0.1 Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	12,978				
16.00	0.116	23.99	0.116	23.99	0.116 Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	32,619				
16.00	0.086	23.99	0.086	23.99	0.086 Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	16,742				
16.00	0.113	23.99	0.113	23.99	0.113 Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	48,885				
16.00	0.058	23.99	0.058	23.99	0.058 Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	27,601				
16.00	0	23.99	0	23.99	0 Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
16.00	0.02	23.99	0.02	23.99	0.02 Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	14,601				
16.00	0.042	23.99	0.042	23.99	0.042 Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,634				
16.00	0.252	23.99	0.252	23.99	0.252 Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	21,804				
16.00	0.454	23.99	0.454	23.99	0.454 Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	19,641				
16.00	0.07	23.99	0.07	23.99	0.07 Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	9,085				
16.00	0.018	23.99	0.018	23.99	0.018 Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	779				
Time Period Totals											194,800	91.5560	208,367	0.0791	369,469	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0583			
24 HR. COMPLIANCE STANDARD													0.105	IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-12-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)			
0.00	0.061	6.75	0.061	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	6,688						
0.00	0.055	6.75	0.055	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	13,066						
0.00	0.048	6.75	0.048	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	7,894						
0.00	0.049	6.75	0.049	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	17,908						
0.00	0.011	6.75	0.011	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	4,422						
0.00	0	6.75	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0						
0.00	0	6.75	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0						
0.00	0.029	6.75	0.029	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	2,120						
0.00	0.079	6.75	0.079	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	5,774						
0.00	0.024	6.75	0.024	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	877						
0.00	0.031	6.75	0.031	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	3,399						
0.00	0.008	6.75	0.008	Pipe Insulation - El. 24		24	2	1,600	3,200	1.5040	292						
Time Period Totals											194,800	91.5560	62,441	0.0281	768,155	0.1351	
6.75	0.061	10.50	0.137	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	6,030						
6.75	0.055	10.50	0.092	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	9,700						
6.75	0.048	10.50	0.102	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	6,853						
6.75	0.049	10.50	0.165	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	21,725						
6.75	0.011	10.50	0.023	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	3,797						
6.75	0	10.50	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0						
6.75	0	10.50	0.003	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	514						
6.75	0.029	10.50	0.026	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,117						
6.75	0.079	10.50	0.339	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	8,487						
6.75	0.024	10.50	0.373	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	4,030						
6.75	0.031	10.50	0.044	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	2,284						
6.75	0.008	10.50	0.013	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	213						
Time Period Totals											194,800	91.5560	64,751	0.0524	703,404	0.1581	
10.50	0.137	14.50	0.113	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	8,122						
10.50	0.092	14.50	0.135	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	15,978						
10.50	0.102	14.50	0.07	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	8,381						
10.50	0.165	14.50	0.147	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	33,786						
10.50	0.023	14.50	0.028	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	6,075						
10.50	0	14.50	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0						
10.50	0.003	14.50	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	548						
10.50	0.026	14.50	0.026	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,126						
10.50	0.339	14.50	0.184	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	11,327						
10.50	0.373	14.50	0.259	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	6,844						
10.50	0.044	14.50	0.059	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	3,346						
10.50	0.013	14.50	0.006	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	206						
Time Period Totals											194,800	91.5560	95,739	0.0726	607,666	0.1941	
14.50	0.113	15.75	0.091	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	2,071						
14.50	0.135	15.75	0.116	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	5,521						
14.50	0.07	15.75	0.088	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	2,406						
14.50	0.147	15.75	0.11	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	8,697						
14.50	0.028	15.75	0.031	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	2,196						
14.50	0	15.75	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0						
14.50	0	15.75	0.014	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	799						
14.50	0.026	15.75	0.026	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	352						
14.50	0.184	15.75	0.067	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	1,699						
14.50	0.259	15.75	0.126	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	1,303						
14.50	0.059	15.75	0.104	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	1,655						
14.50	0.006	15.75	0.019	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	85						
Time Period Totals											194,800	91.5560	26,784	0.0650	580,882	0.2136	
15.75	0.091	23.99	0.091	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	12,180						
15.75	0.116	23.99	0.116	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	33,639						
15.75	0.088	23.99	0.088	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	17,667						
15.75	0.11	23.99	0.11	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	49,076						
15.75	0.031	23.99	0.031	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	15,214						
15.75	0	23.99	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0						
15.75	0.014	23.99	0.014	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	10,540						
15.75	0.026	23.99	0.026	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	2,320						
15.75	0.067	23.99	0.067	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	5,978						
15.75	0.126	23.99	0.126	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	5,621						
15.75	0.104	23.99	0.104	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	13,920						
15.75	0.019	23.99	0.019	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	848						
Time Period Totals											194,800	91.5560	167,004	0.0615	413,878		
24 HR. ACTUAL COMPLIANCE TOTAL															0.0527		
24 HR. COMPLIANCE STANDARD															0.105		IN COMPLIANCE

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-13-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)		
0.00	0.072	7.00	0.072	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	8,187					
0.00	0.088	7.00	0.088	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	21,679					
0.00	0.057	7.00	0.057	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	11,427					
0.00	0.147	7.00	0.147	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	55,714					
0.00	0.014	7.00	0.014	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	5,837					
0.00	0	7.00	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0					
0.00	0	7.00	0	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0					
0.00	0.026	7.00	0.026	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,971					
0.00	0.265	7.00	0.265	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	20,087					
0.00	0.567	7.00	0.567	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	21,490					
0.00	0.125	7.00	0.125	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	14,213					
0.00	0.008	7.00	0.008	Pipe Insulation - El. 24		24	2	1,600	3,200	1.5040	303					
Time Period Totals											194,800	91.5560	160,908	0.0697	669,688	0.1195
7.00	0.072	10.50	0.065	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	3,894					
7.00	0.088	10.50	0.126	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	13,180					
7.00	0.057	10.50	0.116	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	7,803					
7.00	0.147	10.50	0.149	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	28,047					
7.00	0.014	10.50	0.024	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	3,961					
7.00	0	10.50	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0					
7.00	0	10.50	0.008	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,279					
7.00	0.026	10.50	0.028	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,023					
7.00	0.265	10.50	0.286	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	10,442					
7.00	0.567	10.50	0.556	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	10,641					
7.00	0.125	10.50	0.125	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	7,106					
7.00	0.008	10.50	0.014	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	208					
Time Period Totals											194,800	91.5560	87,584	0.0759	582,104	0.1308
10.50	0.065	14.50	0.069	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	4,353					
10.50	0.126	14.50	0.081	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	14,570					
10.50	0.116	14.50	0.088	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	9,941					
10.50	0.149	14.50	0.103	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	27,289					
10.50	0.024	14.50	0.024	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	5,718					
10.50	0	14.50	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0					
10.50	0.008	14.50	0.008	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,924					
10.50	0.028	14.50	0.027	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,191					
10.50	0.286	14.50	0.375	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	14,316					
10.50	0.556	14.50	0.55	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	11,977					
10.50	0.125	14.50	0.08	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	6,660					
10.50	0.014	14.50	0.014	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	303					
Time Period Totals											194,800	91.5560	99,241	0.0753	482,864	0.1542
14.50	0.069	17.75	0.091	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	4,223					
14.50	0.081	17.75	0.104	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	10,580					
14.50	0.088	17.75	0.083	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	6,770					
14.50	0.103	17.75	0.13	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	20,500					
14.50	0.024	17.75	0.036	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	22	1,600	35,200	16.5440	5,807					
14.50	0	17.75	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0					
14.50	0.008	17.75	0.009	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,524					
14.50	0.027	17.75	0.03	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,003					
14.50	0.375	17.75	0.124	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	8,781					
14.50	0.55	17.75	0.193	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	6,537					
14.50	0.08	17.75	0.044	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	3,273					
14.50	0.014	17.75	0.021	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	308					
Time Period Totals											194,800	91.5560	70,307	0.0656	412,557	0.2003
17.75	0.091	23.99	0.104	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	9,224					
17.75	0.104	23.99	0.104	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	22,839					
17.75	0.083	23.99	0.083	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	12,619					
17.75	0.13	23.99	0.13	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	43,922					
17.75	0.036	23.99	0.036	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	0	1,600	0	0.0000	0					
17.75	0	23.99	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0					
17.75	0.009	23.99	0.009	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	5,131					
17.75	0.03	23.99	0.03	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	2,027					
17.75	0.124	23.99	0.124	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	8,379					
17.75	0.193	23.99	0.193	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	6,521					
17.75	0.044	23.99	0.044	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	4,460					
17.75	0.021	23.99	0.021	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	710					
Time Period Totals											159,600	75.0120	115,831	0.0687	146,639	

24 HR. ACTUAL COMPLIANCE TOTAL
24 HR. COMPLIANCE STANDARD

0.0824
0.105
IN COMPLIANCE

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-14-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.022	6.50	0.022	Boiler #1& #2 - El. 89 to El. 55		59 SW	6	1,600	9,600	4.5120	2,323				
0.00	0.023	6.50	0.023	Boiler #1& #2 - El. 89 to El. 55		59 W	13	1,600	20,800	9.7760	5,251				
0.00	0.025	6.50	0.025	Boiler #1& #2 - El. 89 to El. 55		Mezzanine W	9	1,600	14,400	6.7680	3,959				
0.00	0.027	6.50	0.027	Boiler #1& #2 - El. 89 to El. 55		82 E	20	1,600	32,000	15.0400	9,502				
0.00	0.017	6.50	0.017	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	22	1,600	35,200	16.5440	6,581				
0.00	0	6.50	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0				
0.00	0.005	6.50	0.005	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	2,969				
0.00	0.026	6.50	0.026	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,830				
0.00	0.081	6.50	0.081	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	5,701				
0.00	0.117	6.50	0.117	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	4,118				
0.00	0.027	6.50	0.027	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	2,851				
0.00	0.006	6.50	0.006	Pipe Insulation - El. 24		24	2	1,600	3,200	1.5040	211				
Time Period Totals										194,800	91.5560	45,307	0.0211	785,289	0.1361
6.50	0.022	8.75	0.106	Boiler #1& #2 - El. 89 to El. 55		59 SW	6	1,600	9,600	4.5120	2,339				
6.50	0.023	8.75	0.195	Boiler #1& #2 - El. 89 to El. 55		59 W	13	1,600	20,800	9.7760	8,631				
6.50	0.025	8.75	0.132	Boiler #1& #2 - El. 89 to El. 55		Mezzanine W	9	1,600	14,400	6.7680	4,303				
6.50	0.027	8.75	0.166	Boiler #1& #2 - El. 89 to El. 55		82 E	20	1,600	32,000	15.0400	11,756				
6.50	0.017	8.75	0.026	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	22	1,600	35,200	16.5440	2,881				
6.50	0	8.75	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0				
6.50	0.005	8.75	0.009	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	1,439				
6.50	0.026	8.75	0.028	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	658				
6.50	0.081	8.75	0.282	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	4,422				
6.50	0.117	8.75	0.638	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	4,599				
6.50	0.027	8.75	0.084	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	2,028				
6.50	0.006	8.75	0.015	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	128				
Time Period Totals										194,800	91.5560	43,185	0.0582	742,104	0.1476
8.75	0.106	11.50	0.077	Boiler #1& #2 - El. 89 to El. 55		59 SW	6	1,600	9,600	4.5120	4,087				
8.75	0.195	11.50	0.081	Boiler #1& #2 - El. 89 to El. 55		59 W	13	1,600	20,800	9.7760	13,356				
8.75	0.132	11.50	0.093	Boiler #1& #2 - El. 89 to El. 55		Mezzanine W	9	1,600	14,400	6.7680	7,538				
8.75	0.166	11.50	0.104	Boiler #1& #2 - El. 89 to El. 55		82 E	20	1,600	32,000	15.0400	20,101				
8.75	0.026	11.50	0.021	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	22	1,600	35,200	16.5440	3,849				
8.75	0	11.50	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0				
8.75	0.009	11.50	0	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	1,131				
8.75	0.028	11.50	0.024	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	774				
8.75	0.282	11.50	0.249	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	7,906				
8.75	0.638	11.50	0.276	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	6,805				
8.75	0.084	11.50	0.065	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	3,328				
8.75	0.015	11.50	0.008	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	171				
Time Period Totals										194,800	91.5560	69,046	0.0762	673,058	0.1634
11.50	0.077	13.25	0.099	Boiler #1& #2 - El. 89 to El. 55		59 SW	6	1,600	9,600	4.5120	2,501				
11.50	0.081	13.25	0.117	Boiler #1& #2 - El. 89 to El. 55		59 W	13	1,600	20,800	9.7760	6,097				
11.50	0.093	13.25	0.08	Boiler #1& #2 - El. 89 to El. 55		Mezzanine W	9	1,600	14,400	6.7680	3,688				
11.50	0.104	13.25	0.133	Boiler #1& #2 - El. 89 to El. 55		82 E	20	1,600	32,000	15.0400	11,228				
11.50	0.021	13.25	0.021	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	22	1,600	35,200	16.5440	2,189				
11.50	0	13.25	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0				
11.50	0	13.25	0.004	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	320				
11.50	0.024	13.25	0.024	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	455				
11.50	0.249	13.25	0.294	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	5,145				
11.50	0.276	13.25	0.507	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	3,710				
11.50	0.065	13.25	0.124	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	2,686				
11.50	0.008	13.25	0.011	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	90				
Time Period Totals										194,800	91.5560	38,109	0.0661	634,948	0.1792
13.25	0.099	23.99	0.099	Boiler #1& #2 - El. 89 to El. 55		59 SW	6	1,600	9,600	4.5120	17,271				
13.25	0.117	23.99	0.117	Boiler #1& #2 - El. 89 to El. 55		59 W	13	1,600	20,800	9.7760	44,224				
13.25	0.08	23.99	0.08	Boiler #1& #2 - El. 89 to El. 55		Mezzanine W	9	1,600	14,400	6.7680	20,934				
13.25	0.133	23.99	0.133	Boiler #1& #2 - El. 89 to El. 55		82 E	20	1,600	32,000	15.0400	77,340				
13.25	0.021	23.99	0.021	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	0	1,600	0	0.0000	0				
13.25	0	23.99	0	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0				
13.25	0.004	23.99	0.004	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	3,925				
13.25	0.024	23.99	0.024	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	2,791				
13.25	0.294	23.99	0.294	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	34,193				
13.25	0.507	23.99	0.507	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	29,482				
13.25	0.124	23.99	0.124	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	21,632				
13.25	0.011	23.99	0.011	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	640				
Time Period Totals										159,500	75.0120	252,432	0.0870	232,429	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0691			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-17-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)	
0.00	0.024	6.50	0.024	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	2,534				
0.00	0.026	6.50	0.026	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	5,948				
0.00	0.04	6.50	0.04	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	6,335				
0.00	0.03	6.50	0.03	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	10,558				
0.00	0.013	6.50	0.013	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	2	1,600	3,200	1.5040	458				
0.00	0	6.50	0	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
0.00	0	6.50	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0				
0.00	0.048	6.50	0.048	Turbine #1 - El. 36	36	E	4	1,600	6,400	3.0080	3,379				
0.00	0.092	6.50	0.092	Turbine #2 - El. 36	36	E	4	1,600	6,400	3.0080	6,476				
0.00	0.155	6.50	0.155	Turbine #2 - El. 24	24	E	2	1,600	3,200	1.5040	5,455				
0.00	0.04	6.50	0.04	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	4,223				
0.00	0.014	6.50	0.014	Pipe Insulation - El. 24	24	E	2	1,600	3,200	1.5040	493				
Time Period Totals										162,800	76,5160	45,857	0.0256	648,296	0.1345
6.50	0.024	9.75	0.153	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	4,672				
6.50	0.026	9.75	0.16	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	10,637				
6.50	0.04	9.75	0.199	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	9,463				
6.50	0.03	9.75	0.782	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	71,443				
6.50	0.013	9.75	0.009	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	2	1,600	3,200	1.5040	194				
6.50	0	9.75	0.01	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	396				
6.50	0	9.75	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0				
6.50	0.048	9.75	0.054	Turbine #1 - El. 36	36	E	4	1,600	6,400	3.0080	1,795				
6.50	0.092	9.75	0.32	Turbine #2 - El. 36	36	E	4	1,600	6,400	3.0080	7,250				
6.50	0.155	9.75	0.431	Turbine #2 - El. 24	24	E	2	1,600	3,200	1.5040	5,156				
6.50	0.04	9.75	0.009	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,293				
6.50	0.014	9.75	0.023	Pipe Insulation - El. 24	95	E	2	1,600	3,200	1.5040	326				
Time Period Totals										177,200	83,2840	112,624	0.1156	597,071	0.1397
9.75	0.153	13.50	0.473	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	19,065				
9.75	0.16	13.50	0.563	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	47,709				
9.75	0.199	13.50	0.438	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	29,101				
9.75	0.782	13.50	0.535	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	133,702				
9.75	0.009	13.50	0.006	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	2	1,600	3,200	1.5040	152				
9.75	0.01	13.50	0.005	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	685				
9.75	0	13.50	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0				
9.75	0.054	13.50	0.048	Turbine #1 - El. 36	36	E	4	1,600	6,400	3.0080	2,071				
9.75	0.32	13.50	0.152	Turbine #2 - El. 36	36	E	4	1,600	6,400	3.0080	9,583				
9.75	0.431	13.50	0.499	Turbine #2 - El. 24	24	E	2	1,600	3,200	1.5040	9,441				
9.75	0.009	13.50	0.112	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	3,685				
9.75	0.023	13.50	0.009	Pipe Insulation - El. 24	95	E	2	1,600	3,200	1.5040	325				
Time Period Totals										177,200	83,2840	255,521	0.2273	341,551	0.1085
13.50	0.473	15.25	0.031	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	7,163				
13.50	0.563	15.25	0.03	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	18,261				
13.50	0.438	15.25	0.033	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	10,041				
13.50	0.535	15.25	0.123	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	31,173				
13.50	0.006	15.25	0.008	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	2	1,600	3,200	1.5040	66				
13.50	0.005	15.25	0.007	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	256				
13.50	0	15.25	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0				
13.50	0.048	15.25	0.04	Turbine #1 - El. 36	36	E	4	1,600	6,400	3.0080	834				
13.50	0.152	15.25	0.115	Turbine #2 - El. 36	36	E	4	1,600	6,400	3.0080	2,530				
13.50	0.499	15.25	0.224	Turbine #2 - El. 24	24	E	2	1,600	3,200	1.5040	3,425				
13.50	0.112	15.25	0.049	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,288				
13.50	0.009	15.25	0.01	Pipe Insulation - El. 24	95	E	2	1,600	3,200	1.5040	90				
Time Period Totals										177,200	83,2840	76,128	0.1451	265,422	0.1012
15.25	0.031	23.99	0.031	Boiler #1& #2 - El. 89 to El. 5E	59	SW	6	1,600	9,600	4.5120	4,401				
15.25	0.03	23.99	0.03	Boiler #1& #2 - El. 89 to El. 5E	59	W	13	1,600	20,800	9.7760	9,228				
15.25	0.033	23.99	0.033	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	9	1,600	14,400	6.7680	7,027				
15.25	0.123	23.99	0.123	Boiler #1& #2 - El. 89 to El. 5E	82	E	20	1,600	32,000	15.0400	58,206				
15.25	0.008	23.99	0.008	Boiler #1& #2 - El. 49 to El. 3E	49 & 36	N	0	1,600	0	0.0000	0				
15.25	0.007	23.99	0.007	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
15.25	0	23.99	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0				
15.25	0.04	23.99	0.04	Turbine #1 - El. 36	36	E	4	1,600	6,400	3.0080	3,786				
15.25	0.115	23.99	0.115	Turbine #2 - El. 36	36	E	4	1,600	6,400	3.0080	10,884				
15.25	0.224	23.99	0.224	Turbine #2 - El. 24	24	E	2	1,600	3,200	1.5040	10,600				
15.25	0.049	23.99	0.049	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	6,956				
15.25	0.01	23.99	0.01	Pipe Insulation - El. 24	95	E	2	1,600	3,200	1.5040	473				
Time Period Totals										159,600	75,0120	111,561	0.0473	78,817	
24 HR. ACTUAL COMPLIANCE TOTAL												0.0928			
24 HR. COMPLIANCE STANDARD												0.105			
												IN COMPLIANCE			

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-18-2017

TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)			
0.00	0.032	6.75	0.032	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	3,509						
0.00	0.036	6.75	0.036	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	8,552						
0.00	0.033	6.75	0.033	Boiler #1& #2 - El. 89 to El. 5E		Mezzanine W	9	1,600	14,400	6.7680	5,427						
0.00	0.05	6.75	0.05	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	18,274						
0.00	0.005	6.75	0.005	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	2	1,600	3,200	1.5040	183						
0.00	0.006	6.75	0.006	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0						
0.00	0	6.75	0	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	0						
0.00	0.017	6.75	0.017	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,243						
0.00	0.098	6.75	0.098	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	7,163						
0.00	0.155	6.75	0.155	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	5,665						
0.00	0.031	6.75	0.031	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	3,399						
0.00	0.003	6.75	0.003	Pipe Insulation - El. 24		24	2	1,600	3,200	1.5040	110						
Time Period Totals											162,800	76,5160	53,523	0.0288	640,630	0.1348	
6.75	0.032	10.00	0.034	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	1,742						
6.75	0.036	10.00	0.042	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	4,461						
6.75	0.033	10.00	0.042	Boiler #1& #2 - El. 89 to El. 5E		Mezzanine W	9	1,600	14,400	6.7680	2,969						
6.75	0.05	10.00	0.091	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	12,406						
6.75	0.005	10.00	0.013	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	2	1,600	3,200	1.5040	158						
6.75	0.006	10.00	0.017	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	911						
6.75	0	10.00	0.003	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	445						
6.75	0.017	10.00	0.027	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	774						
6.75	0.098	10.00	0.215	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	5,508						
6.75	0.155	10.00	0.402	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	4,901						
6.75	0.031	10.00	0.085	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	3,088						
6.75	0.003	10.00	0.007	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	88						
Time Period Totals											177,200	83,2840	37,451	0.0384	664,578	0.1583	
10.00	0.034	14.50	0.077	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	4,057						
10.00	0.042	14.50	0.066	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	8,552						
10.00	0.042	14.50	0.062	Boiler #1& #2 - El. 89 to El. 5E		Mezzanine W	9	1,600	14,400	6.7680	5,701						
10.00	0.091	14.50	0.084	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	21,319						
10.00	0.013	14.50	0.005	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	2	1,600	3,200	1.5040	219						
10.00	0.017	14.50	0.014	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	1,699						
10.00	0.003	14.50	0.005	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	1,645						
10.00	0.027	14.50	0.027	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,316						
10.00	0.215	14.50	0.098	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	7,626						
10.00	0.402	14.50	0.097	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	6,079						
10.00	0.086	14.50	0.037	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	4,495						
10.00	0.007	14.50	0.009	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	195						
Time Period Totals											177,200	83,2840	62,904	0.0466	601,674	0.2112	
14.50	0.077	17.25	0.038	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	2,568						
14.50	0.066	17.25	0.022	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	4,258						
14.50	0.062	17.25	0.027	Boiler #1& #2 - El. 89 to El. 5E		Mezzanine W	9	1,600	14,400	6.7680	2,982						
14.50	0.084	17.25	0.056	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	10,423						
14.50	0.005	17.25	0.007	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	2	1,600	3,200	1.5040	89						
14.50	0.014	17.25	0.012	Coal Bunker Containment		59 N	9	1,600	14,400	6.7680	871						
14.50	0.005	17.25	0.006	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	1,382						
14.50	0.027	17.25	0.024	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	759						
14.50	0.098	17.25	0.038	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	2,025						
14.50	0.097	17.25	0.067	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	1,221						
14.50	0.037	17.25	0.03	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	1,496						
14.50	0.009	17.25	0.009	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	134						
Time Period Totals											177,200	83,2840	28,209	0.0342	573,464	0.2834	
17.25	0.038	23.99	0.038	Boiler #1& #2 - El. 89 to El. 5E		59 SW	6	1,600	9,600	4.5120	4,160						
17.25	0.022	23.99	0.022	Boiler #1& #2 - El. 89 to El. 5E		59 W	13	1,600	20,800	9.7760	5,219						
17.25	0.027	23.99	0.027	Boiler #1& #2 - El. 89 to El. 5E		Mezzanine W	9	1,600	14,400	6.7680	4,434						
17.25	0.056	23.99	0.056	Boiler #1& #2 - El. 89 to El. 5E		82 E	20	1,600	32,000	15.0400	20,436						
17.25	0.007	23.99	0.007	Boiler #1& #2 - El. 49 to El. 3E		49 & 36 N	0	1,600	0	0.0000	0						
17.25	0.012	23.99	0.012	Coal Bunker Containment		59 N	0	1,600	0	0.0000	0						
17.25	0.006	23.99	0.006	Turbine Area Roof Fans		El. 82 Roof E	2	27,000	54,000	25.3800	3,695						
17.25	0.024	23.99	0.024	Turbine #1 - El. 36		36	4	1,600	6,400	3.0080	1,752						
17.25	0.038	23.99	0.038	Turbine #2 - El. 36		36	4	1,600	6,400	3.0080	2,773						
17.25	0.067	23.99	0.067	Turbine #2 - El. 24		24	2	1,600	3,200	1.5040	2,445						
17.25	0.03	23.99	0.03	Precipitator - El. 24		24 W	6	1,600	9,600	4.5120	3,284						
17.25	0.009	23.99	0.009	Pipe Insulation - El. 24		95	2	1,600	3,200	1.5040	328						
Time Period Totals											159,600	75,0120	48,527	0.0267	449,894		
24 HR. ACTUAL COMPLIANCE TOTAL															0.0356		
24 HR. COMPLIANCE STANDARD															0.105		
															IN COMPLIANCE		

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADI, IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-19-2017

TIME START	CONC. START	TIME END	CONC. END	CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE		EMISSIONS (MG)	AVG. CONC.	BAL.	AVG. CONC.	
	(MG/M ³)		(MG/M ³)		FLOOR ELEV.	LOCATION			(CFM)	(M ³ /SEC)		(MG/M ³)	EMISSIONS (MG)	(MG/M ³)	
0.00	0.027	6.75	0.027	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	2,960				
0.00	0.047	6.75	0.047	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	11,165				
0.00	0.044	6.75	0.044	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	7,236				
0.00	0.058	6.75	0.058	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	21,197				
0.00	0.007	6.75	0.007	Waste Loadout - El. 36	49 & 36	N	2	1,600	3,200	1.5040	256				
0.00	0.009	6.75	0.009	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,480				
0.00	0.003	6.75	0.003	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,850				
0.00	0.029	6.75	0.029	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,120				
0.00	0.048	6.75	0.048	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	3,509				
0.00	0.166	6.75	0.166	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	6,067				
0.00	0.026	6.75	0.026	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,851				
0.00	0.017	6.75	0.017	Pipe Insulation - El. 24	24		2	1,600	3,200	1.5040	621				
Time Period Totals															
6.75	0.027	10.50	0.074	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	3,076	0.0303	694,240	0.1342	
6.75	0.047	10.50	0.081	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	8,446				
6.75	0.044	10.50	0.096	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	6,396				
6.75	0.058	10.50	0.204	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	26,598				
6.75	0.007	10.50	0.019	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	264				
6.75	0.009	10.50	0.014	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,051				
6.75	0.003	10.50	0.008	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,884				
6.75	0.029	10.50	0.042	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,442				
6.75	0.048	10.50	0.224	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5,523				
6.75	0.166	10.50	0.493	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	6,690				
6.75	0.026	10.50	0.093	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	3,624				
6.75	0.017	10.50	0.013	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	305				
Time Period Totals															
10.50	0.074	14.25	0.07	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	4,386	0.0581	628,941	0.1554	
10.50	0.081	14.25	0.06	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	9,304				
10.50	0.096	14.25	0.073	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	7,721				
10.50	0.204	14.25	0.083	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	29,136				
10.50	0.019	14.25	0.021	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	406				
10.50	0.014	14.25	0.011	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,142				
10.50	0.008	14.25	0.006	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	2,398				
10.50	0.042	14.25	0.025	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,360				
10.50	0.224	14.25	0.29	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	10,436				
10.50	0.493	14.25	0.634	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	11,441				
10.50	0.093	14.25	0.03	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	3,746				
10.50	0.013	14.25	0.011	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	244				
Time Period Totals															
14.25	0.07	17.25	0.03	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	2,436	0.0727	547,220	0.1872	
14.25	0.06	17.25	0.02	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	4,223				
14.25	0.073	17.25	0.034	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	3,911				
14.25	0.083	17.25	0.021	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	8,446				
14.25	0.021	17.25	0.013	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	276				
14.25	0.011	17.25	0.013	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	877				
14.25	0.006	17.25	0.003	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,233				
14.25	0.025	17.25	0.025	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	812				
14.25	0.29	17.25	0.093	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	6,221				
14.25	0.634	17.25	0.177	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	6,587				
14.25	0.03	17.25	0.032	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1,511				
14.25	0.011	17.25	0.011	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	179				
Time Period Totals															
17.25	0.03	23.99	0.03	Boiler #1& #2 - El. 89 to El. 55	59	SW	6	1,600	9,600	4.5120	3,284	0.0408	510,507	0.2523	
17.25	0.02	23.99	0.02	Boiler #1& #2 - El. 89 to El. 55	59	W	13	1,600	20,800	9.7760	4,744				
17.25	0.034	23.99	0.034	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	9	1,600	14,400	6.7680	5,583				
17.25	0.021	23.99	0.021	Boiler #1& #2 - El. 89 to El. 55	82	E	20	1,600	32,000	15.0400	7,664				
17.25	0.013	23.99	0.013	Waste Loadout - El. 36	36	N	0	1,600	0	0.0000	0				
17.25	0.013	23.99	0.013	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0				
17.25	0.003	23.99	0.003	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,847				
17.25	0.025	23.99	0.025	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,825				
17.25	0.093	23.99	0.093	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	6,788				
17.25	0.177	23.99	0.177	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	6,459				
17.25	0.032	23.99	0.032	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	3,503				
17.25	0.011	23.99	0.011	Pipe Insulation - El. 24	95		2	1,600	3,200	1.5040	401				
Time Period Totals															
Totals															
											159,600	75.0120	42,099	0.0231	393,364
24 HR. ACTUAL COMPLIANCE TOTAL														0.0443	
24 HR. COMPLIANCE STANDARD														0.105	
														IN COMPLIANCE	

SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-20-2017



TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC. (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION								
0.00	0.025	6.75	0.025	6.75	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	5,482			
0.00	0.024	6.75	0.024	6.75	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	1,754			
0.00	0.022	6.75	0.022	6.75	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	4,020			
0.00	0.07	6.75	0.07	6.75	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	28,141			
0.00	0.009	6.75	0.009	6.75	Waste Loadout - El. 36	49 & 36	N	2	1,600	3,200	1.5040	329			
0.00	0.005	6.75	0.005	6.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	822			
0.00	0.007	6.75	0.007	6.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	4,317			
0.00	0.025	6.75	0.025	6.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,827			
0.00	0.095	6.75	0.095	6.75	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5,944			
0.00	0.252	6.75	0.252	6.75	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	9,210			
0.00	0.033	6.75	0.033	6.75	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	3,618			
Time Period Totals										174,000	81,7800	66,466	0.0334	675,443	0.1330
6.75	0.025	10.25	0.072	10.25	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	5,515			
6.75	0.024	10.25	0.066	10.25	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	1,705			
6.75	0.022	10.25	0.071	10.25	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	4,406			
6.75	0.07	10.25	0.198	10.25	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	27,933			
6.75	0.009	10.25	0.028	10.25	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	351			
6.75	0.005	10.25	0.028	10.25	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,407			
6.75	0.007	10.25	0.015	10.25	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	3,518			
6.75	0.025	10.25	0.04	10.25	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,232			
6.75	0.095	10.25	0.28	10.25	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	7,106			
6.75	0.252	10.25	0.364	10.25	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	5,837			
6.75	0.033	10.25	0.061	10.25	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,672			
Time Period Totals										174,000	81,7800	61,681	0.0599	613,761	0.1516
10.25	0.072	14.25	0.06	14.25	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	8,576			
10.25	0.066	14.25	0.025	14.25	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	1,971			
10.25	0.071	14.25	0.044	14.25	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	6,227			
10.25	0.198	14.25	0.128	14.25	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	38,832			
10.25	0.028	14.25	0.025	14.25	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	574			
10.25	0.028	14.25	0.016	14.25	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	2,144			
10.25	0.015	14.25	0.014	14.25	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	5,299			
10.25	0.04	14.25	0.032	14.25	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,559			
10.25	0.28	14.25	0.177	14.25	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	9,898			
10.25	0.364	14.25	0.367	14.25	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	7,916			
10.25	0.061	14.25	0.064	14.25	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	4,061			
Time Period Totals										174,000	81,7800	87,057	0.0739	526,705	0.1835
14.25	0.06	17.25	0.035	17.25	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	4,629			
14.25	0.025	17.25	0.028	17.25	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	861			
14.25	0.044	17.25	0.041	17.25	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	3,452			
14.25	0.128	17.25	0.155	17.25	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	25,283			
14.25	0.025	17.25	0.007	17.25	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	260			
14.25	0.016	17.25	0.007	17.25	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	841			
14.25	0.014	17.25	0	17.25	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	1,919			
14.25	0.032	17.25	0.025	17.25	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	926			
14.25	0.177	17.25	0.03	17.25	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	3,362			
14.25	0.367	17.25	0.097	17.25	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	3,768			
14.25	0.064	17.25	0.023	17.25	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,120			
Time Period Totals										174,000	81,7800	47,420	0.0537	479,285	0.2412
17.25	0.035	23.99	0.035	23.99	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	7,664			
17.25	0.028	23.99	0.028	23.99	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	2,044			
17.25	0.041	23.99	0.041	23.99	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	7,481			
17.25	0.155	23.99	0.155	23.99	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	62,221			
17.25	0.007	23.99	0.007	23.99	Waste Loadout - El. 36	36	N	0	1,600	0	0.0000	0			
17.25	0.007	23.99	0.007	23.99	Coal Bunker Containment	59	N	0	1,600	0	0.0000	0			
17.25	0	23.99	0	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0			
17.25	0.025	23.99	0.025	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,825			
17.25	0.03	23.99	0.03	23.99	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	2,190			
17.25	0.097	23.99	0.097	23.99	Turbine #2 - El. 24	24		2	1,600	3,200	1.5040	3,540			
17.25	0.023	23.99	0.023	23.99	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,518			
Time Period Totals										156,400	73,5080	89,481	0.0502	314,760	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0554		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		



SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-21-2017



TIME START	CONC. START		CONC. END		CONTAINMENT DESCRIPTION	HEPA INTAKE		# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE		EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL. EMISSIONS (MG)	AVG. CONC. TO FINISH (MG/M ³)
	(MG/M ³)	TIME END	(MG/M ³)	TIME END		FLOOR ELEV.	LOCATION			(CFM)	(M ³ /SEC)				
0.00	0.019	6.75	0.019	6.75	Boiler #1& #2 - El. 89 to El. 5E	59	SW	12	1,600	19,200	9.0240	4,166			
0.00	0.012	6.75	0.012	6.75	Boiler #1& #2 - El. 89 to El. 5E	59	W	4	1,600	6,400	3.0080	877			
0.00	0.026	6.75	0.026	6.75	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	10	1,600	16,000	7.5200	4,751			
0.00	0.023	6.75	0.023	6.75	Boiler #1& #2 - El. 89 to El. 5E	82	S	22	1,600	35,200	16.5440	9,246			
0.00	0.003	6.75	0.003	6.75	Waste Loadout - El. 36	49 & 36	N	2	1,600	3,200	1.5040	110			
0.00	0	6.75	0	6.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0			
0.00	0	6.75	0	6.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	0			
0.00	0.025	6.75	0.025	6.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,827			
0.00	0.045	6.75	0.045	6.75	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	3,289			
0.00	0	6.75	0	6.75	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0			
0.00	0.005	6.75	0.005	6.75	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	548			
Time Period Totals										170,800	80.2760	24,816	0.0127	703,448	0.1411
6.75	0.019	10.25	0.061	10.25	Boiler #1& #2 - El. 89 to El. 5E	59	SW	12	1,600	19,200	9.0240	4,548			
6.75	0.012	10.25	0.081	10.25	Boiler #1& #2 - El. 89 to El. 5E	59	W	4	1,600	6,400	3.0080	1,762			
6.75	0.026	10.25	0.073	10.25	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	10	1,600	16,000	7.5200	4,690			
6.75	0.023	10.25	0.139	10.25	Boiler #1& #2 - El. 89 to El. 5E	82	S	22	1,600	35,200	16.5440	16,885			
6.75	0.003	10.25	0.008	10.25	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	104			
6.75	0	10.25	0.008	10.25	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	341			
6.75	0	10.25	0.005	10.25	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	799			
6.75	0.025	10.25	0.026	10.25	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	966			
6.75	0.045	10.25	0.044	10.25	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,687			
6.75	0	10.25	0	10.25	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0			
6.75	0.005	10.25	0	10.25	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	142			
Time Period Totals										170,800	80.2760	31,926	0.0316	671,523	0.1690
10.25	0.061	12.75	0.028	12.75	Boiler #1& #2 - El. 89 to El. 5E	59	SW	12	1,600	19,200	9.0240	3,614			
10.25	0.081	12.75	0.023	12.75	Boiler #1& #2 - El. 89 to El. 5E	59	W	4	1,600	6,400	3.0080	1,408			
10.25	0.073	12.75	0.04	12.75	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	10	1,600	16,000	7.5200	3,824			
10.25	0.139	12.75	0.034	12.75	Boiler #1& #2 - El. 89 to El. 5E	82	S	22	1,600	35,200	16.5440	12,880			
10.25	0.008	12.75	0.009	12.75	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	115			
10.25	0.008	12.75	0.004	12.75	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	365			
10.25	0.005	12.75	0.014	12.75	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	2,170			
10.25	0.026	12.75	0.027	12.75	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	717			
10.25	0.044	12.75	0.044	12.75	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,191			
10.25	0	12.75	0	12.75	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0			
10.25	0	12.75	0.005	12.75	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	102			
Time Period Totals										170,800	80.2760	26,386	0.0365	645,137	0.1984
12.75	0.028	12.76	0.028	12.76	Boiler #1& #2 - El. 89 to El. 5E	59	SW	12	1,600	19,200	9.0240	9			
12.75	0.023	12.76	0.023	12.76	Boiler #1& #2 - El. 89 to El. 5E	59	W	4	1,600	6,400	3.0080	2			
12.75	0.04	12.76	0.04	12.76	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	10	1,600	16,000	7.5200	11			
12.75	0.034	12.76	0.034	12.76	Boiler #1& #2 - El. 89 to El. 5E	82	S	22	1,600	35,200	16.5440	20			
12.75	0.009	12.76	0.009	12.76	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	0			
12.75	0.004	12.76	0.004	12.76	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1			
12.75	0.014	12.76	0.014	12.76	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	13			
12.75	0.027	12.76	0.027	12.76	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3			
12.75	0.044	12.76	0.044	12.76	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	5			
12.75	0	12.76	0	12.76	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0			
12.75	0.005	12.76	0.005	12.76	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	1			
Time Period Totals										170,800	80.2760	65	0.0226	645,072	0.1986
12.76	0.028	23.99	0.035	23.99	Boiler #1& #2 - El. 89 to El. 5E	59	SW	12	1,600	19,200	9.0240	11,492			
12.76	0.023	23.99	0.028	23.99	Boiler #1& #2 - El. 89 to El. 5E	59	W	4	1,600	6,400	3.0080	3,101			
12.76	0.04	23.99	0.041	23.99	Boiler #1& #2 - El. 89 to El. 5E	Mezzanine	W	10	1,600	16,000	7.5200	12,313			
12.76	0.034	23.99	0.155	23.99	Boiler #1& #2 - El. 89 to El. 5E	82	S	22	1,600	35,200	16.5440	63,205			
12.76	0.009	23.99	0.007	23.99	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	486			
12.76	0.004	23.99	0.007	23.99	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	1,505			
12.76	0.014	23.99	0	23.99	Turbine Area Roof Fans	El. 82 Roof	E	2	27,000	54,000	25.3800	7,182			
12.76	0.027	23.99	0.025	23.99	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	3,162			
12.76	0.044	23.99	0.03	23.99	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	4,499			
12.76	0	23.99	0	23.99	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0			
12.76	0.005	23.99	0.023	23.99	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	2,554			
Time Period Totals										170,800	80.2760	109,500	0.0337	535,572	
24 HR. ACTUAL COMPLIANCE TOTAL													0.0278		
24 HR. COMPLIANCE STANDARD													0.105		
													IN COMPLIANCE		



SCHILLER - MERCURY BOILER FACILITY ABATEMENT, DECOMMISSIONING & DEMOLITION PROJECT - ADJ. IN-STACK CONCENTRATION ACTUAL EMISSIONS 24 HOUR MERCURY DISCHARGE COMPLIANCE - 04-24-2017



TIME START	CONC. START (MG/M ³)	TIME END	CONC. END (MG/M ³)	CONTAINMENT DESCRIPTION	HEPA INTAKE FLOOR ELEV.	LOCATION	# OF UNITS	CFM PER UNIT	TOTAL FLOWRATE (CFM)	TOTAL FLOWRATE (M ³ /SEC)	EMISSIONS (MG)	AVG. CONC (MG/M ³)	BAL EMISSIONS (MG)	AVG. CONC TO FINISH (MG/M ³)		
0.00	0.021	6.50	0.021	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	4,434					
0.00	0.014	6.50	0.014	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	985					
0.00	0.022	6.50	0.022	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	3,871					
0.00	0.019	6.50	0.019	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	7,355					
0.00	0	6.50	0	Waste Loadout - El. 36	49 & 36	N	2	1,600	3,200	1.5040	0					
0.00	0	6.50	0	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	0					
0.00	0	6.50	0	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	0					
0.00	0.017	6.50	0.017	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	1,197					
0.00	0.023	6.50	0.023	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,619					
0.00	0	6.50	0	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0					
0.00	0	6.50	0	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	0					
Time Period Totals											170,800	80.2760	19,462	0.0104	708,802	0.1402
6.50	0.021	10.25	0.038	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	3,594					
6.50	0.014	10.25	0.049	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	1,279					
6.50	0.022	10.25	0.056	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	3,959					
6.50	0.019	10.25	0.064	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	9,269					
6.50	0	10.25	0.005	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	51					
6.50	0	10.25	0.003	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	137					
6.50	0	10.25	0.005	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	857					
6.50	0.017	10.25	0.023	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	812					
6.50	0.023	10.25	0.033	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,137					
6.50	0	10.25	0	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0					
6.50	0	10.25	0.019	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	579					
Time Period Totals											170,800	80.2760	21,673	0.0200	687,129	0.1729
10.25	0.038	13.50	0.054	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	4,857					
10.25	0.049	13.50	0.065	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	2,006					
10.25	0.056	13.50	0.041	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	4,267					
10.25	0.064	13.50	0.138	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	19,550					
10.25	0.005	13.50	0.005	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	88					
10.25	0.003	13.50	0.004	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	277					
10.25	0.005	13.50	0.004	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,336					
10.25	0.023	13.50	0.022	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	792					
10.25	0.033	13.50	0.031	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,126					
10.25	0	13.50	0	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0					
10.25	0.019	13.50	0	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	502					
Time Period Totals											170,800	80.2760	34,801	0.0371	652,328	0.2150
13.50	0.054	15.50	0.083	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	4,451					
13.50	0.065	15.50	0.064	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	1,397					
13.50	0.041	15.50	0.078	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	3,222					
13.50	0.138	15.50	0.113	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	14,949					
13.50	0.005	15.50	0.022	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	146					
13.50	0.004	15.50	0.027	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	755					
13.50	0.004	15.50	0.01	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	1,279					
13.50	0.022	15.50	0.027	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	531					
13.50	0.031	15.50	0.021	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	563					
13.50	0	15.50	0	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0					
13.50	0	15.50	0.007	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	114					
Time Period Totals											170,800	80.2760	27,406	0.0474	624,921	0.2544
15.50	0.083	23.99	0.083	Boiler #1& #2 - El. 89 to El. 55	59	SW	12	1,600	19,200	9.0240	22,892					
15.50	0.064	23.99	0.064	Boiler #1& #2 - El. 89 to El. 55	59	W	4	1,600	6,400	3.0080	5,884					
15.50	0.078	23.99	0.078	Boiler #1& #2 - El. 89 to El. 55	Mezzanine	W	10	1,600	16,000	7.5200	17,928					
15.50	0.113	23.99	0.113	Boiler #1& #2 - El. 89 to El. 55	82	S	22	1,600	35,200	16.5440	57,139					
15.50	0.022	23.99	0.022	Waste Loadout - El. 36	36	N	2	1,600	3,200	1.5040	1,011					
15.50	0.027	23.99	0.027	Coal Bunker Containment	59	N	9	1,600	14,400	6.7680	5,585					
15.50	0.01	23.99	0.01	Turbine Area Roof Fans	El. 82	Roof	2	27,000	54,000	25.3800	7,757					
15.50	0.027	23.99	0.027	Turbine #1 - El. 36	36		4	1,600	6,400	3.0080	2,482					
15.50	0.021	23.99	0.021	Turbine #2 - El. 36	36		4	1,600	6,400	3.0080	1,931					
15.50	0	23.99	0	Turbine #2 - El. 24	24		0	1,600	0	0.0000	0					
15.50	0.007	23.99	0.007	Precipitator - El. 24	24	W	6	1,600	9,600	4.5120	965					
Time Period Totals											170,800	80.2760	123,574	0.0504	501,347	
24 HR. ACTUAL COMPLIANCE TOTAL														0.0327		
24 HR. COMPLIANCE STANDARD														0.105		
														IN COMPLIANCE		


































































































































































































$$\text{Daily Efficiency} = (1 - (\text{Daily Outlet Sum (g/min)} / \text{Daily Inlet Sum (g/min)})) \times 100$$








$$\text{Daily Efficiency} = (1 - (\text{Daily Outlet Sum (g/min)} / \text{Daily Inlet Sum (g/min)})) \times 100$$











$$\text{Daily Efficiency} = (1 - (\text{Daily Outlet Sum (g/min)} / \text{Daily Inlet Sum (g/min)})) \times 100$$





$$\text{Daily Efficiency} = (1 - (\text{Daily Outlet Sum (g/min)} / \text{Daily Inlet Sum (g/min)})) \times 100$$





$$\text{Daily Efficiency} = (1 - (\text{Daily Outlet Sum (g/min)} / \text{Daily Inlet Sum (g/min)})) \times 100$$

