



780 N. Commercial Street
P.O. Box 330
Manchester, NH 03105-0330

Erik Newman
Senior Counsel

603-634-2459
Erik.newman@eversource.com

December 22, 2020

Ms. Debra A. Howland
Executive Director and Secretary
New Hampshire Public Utilities Commission
21 S. Fruit Street, Suite 10
Concord, New Hampshire 03301

**Re: DOCKET 20-195
REVISED PETITION OF PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
D/B/A EVERSOURCE ENERGY FOR AMENDED LICENSE TO CONSTRUCT
AND MAINTAIN ELECTRIC LINES OVER AND ACROSS PUBLIC WATERS
IN DEERFIELD, NEW HAMPSHIRE**

Dear Director Howland:

Enclosed for filing with the Commission please find Public Service Company of New Hampshire d/b/a Eversource Energy's revised petition and replacement exhibits for an amended license to cross public waters. The revised petition incorporates a restated minimum clearance requirement of 23.2' in Section 7 and a replacement Exhibit 2 which adopts a similar revision under the NESC Vertical Clearance table as well as a revised clearance measurement which changed from 43.9' to 41.0'. Also enclosed is a letter discussing the reason for that change in the clearance measurement as requested by Ken Walsh of the Safety Division.

Pursuant to the Commission's notice of March 17, 2020, this filing is only being provided by email.

Thank you for your assistance. Please let me know if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Erik Newman".

Erik Newman
Senior Counsel

CC: Service List